

QURGONTEPPA, Tajikistan

WMO: 389330

Lat: 37.817N

Lon: 68.783E

Elev: 429

StdP: 96.28

Time Zone: 5.00 (E05)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.8	-3.9	-10.7	1.6	-5.3	-7.6	2.1	-1.2	6.3	5.3	4.4	6.4	0.9	50	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	38.9	24.8	37.9	24.2	36.8	23.6	25.6	37.1	24.9	36.5	24.2	35.5	1.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	17.5	34.3	21.1	16.6	33.7	20.3	15.7	32.9	81.7	37.4	78.7	36.4	75.6	35.5	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	4.5	4.1	3.5	DB	-8.8	40.8	4.9	0.8	-12.3	41.4	-15.1	41.8	-17.9	42.3	-21.4	42.8
(5)				WB	-9.1	27.3	4.8	0.9	-12.6	28.0	-15.4	28.5	-18.0	29.0	-21.5	29.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	5.4	6.7	14.1	18.8	24.1	28.1	29.4	27.5	23.6	17.7	10.4	5.8	(6)
		DBStd	9.32	3.86	5.63	4.32	3.68	2.77	2.08	1.51	1.95	2.13	3.55	4.14	4.02	
		HDD10.0	453	147	113	15	1	0	0	0	0	1	39	137		
		HDD18.3	1590	401	327	141	37	1	0	0	1	55	240	388		
		CDD10.0	3262	4	20	142	266	437	543	602	541	409	238	52	7	
		CDD18.3	1356	0	0	9	52	179	293	344	283	159	34	2	0	
		CDH23.3	17138	0	6	113	519	1967	3964	4830	3565	1768	391	15	0	
(13)		CDH26.7	9508	0	1	24	169	939	2337	2978	2087	861	109	2	0	(13)
(14)	Wind	WSAvg	1.4	1.4	1.6	1.6	1.5	1.6	1.5	1.4	1.3	1.2	1.3	1.2	1.2	(14)
(15)	Precipitation	PrecAvg	273	36	40	66	42	25	2	0	0	8	21	31		(15)
(16)		PrecMax	427	109	84	118	102	71	10	5	1	3	67	81		(16)
(17)		PrecMin	160	6	8	31	10	0	0	0	0	0	0	6		(17)
(18)		PrecStd	66	20	20	25	22	19	2	1	0	1	9	19	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	17.3	23.3	29.3	33.6	36.8	40.0	40.4	39.0	35.9	32.5	25.9	19.2		(19)
(20)		0.4% MCWB	9.5	12.8	16.1	19.4	22.0	24.9	25.8	24.9	22.1	19.7	15.2	10.7		(20)
(21)		2% DB	14.9	18.8	26.3	30.6	35.2	38.6	39.1	37.8	34.5	29.3	21.6	16.5		(21)
(22)		2% MCWB	8.4	10.9	14.9	18.1	21.2	24.2	25.2	24.1	21.4	18.4	12.9	9.3		(22)
(23)		5% DB	13.2	16.1	23.8	28.5	33.7	37.4	38.1	36.6	33.3	27.5	19.4	14.3		(23)
(24)		5% MCWB	7.7	9.3	14.0	17.3	20.4	23.6	24.7	23.6	21.0	17.0	11.6	8.4		(24)
(25)		10% DB	11.4	14.1	21.3	26.3	31.8	36.0	37.1	35.3	31.5	25.4	17.1	12.1		(25)
(26)		10% MCWB	6.9	8.7	13.1	16.5	19.8	23.0	24.2	22.8	19.8	15.7	10.6	7.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	10.5	13.8	17.0	20.5	22.7	26.1	26.9	25.7	23.1	20.2	15.4	11.2		(27)
(28)		0.4% MCDB	15.4	22.7	28.1	30.5	34.5	37.9	38.3	37.2	34.3	30.7	24.3	17.4		(28)
(29)		2% WB	9.3	11.4	15.6	19.0	21.9	25.1	25.9	24.8	22.0	18.9	13.6	9.9		(29)
(30)		2% MCDB	13.4	17.2	24.3	27.4	33.9	37.0	37.4	36.5	33.5	28.7	19.6	15.0		(30)
(31)		5% WB	8.3	10.3	14.5	18.1	21.0	24.1	25.3	24.1	21.1	17.5	12.2	8.8		(31)
(32)		5% MCDB	12.1	14.7	22.2	26.3	31.9	35.9	36.7	35.3	32.3	26.4	17.8	12.7		(32)
(33)		10% WB	7.3	9.3	13.7	17.3	20.2	23.4	24.6	23.3	20.1	16.2	11.1	8.0		(33)
(34)		10% MCDB	10.7	13.3	20.3	24.6	30.5	34.8	35.9	34.3	30.7	24.2	16.0	11.8		(34)
(35)	Mean Daily Temperature Range	MDBR	8.6	9.1	10.9	11.8	13.4	15.0	15.4	15.7	16.1	13.8	10.3	9.1		(35)
(36)		5% DB MCDBR	12.0	12.9	14.9	15.9	16.4	17.1	16.8	17.0	17.7	16.6	14.4	13.7		(36)
(37)		5% WB MCWBR	6.6	6.4	6.2	6.1	6.4	7.6	7.6	7.6	7.9	7.7	6.7	7.4		(37)
(38)		5% WB MCDBR	9.9	10.7	12.9	13.5	14.7	16.0	16.2	16.5	17.2	15.4	12.6	11.4		(38)
(39)		5% WB MCWBR	5.7	5.7	5.8	5.6	6.3	7.6	7.7	7.8	8.0	7.4	6.1	6.4		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.388	0.440	0.495	0.500	0.510	0.542	0.532	0.500	0.465	0.492	0.454	0.403		(40)
(41)		taud	2.111	1.985	1.879	1.906	1.911	1.829	1.842	1.910	1.954	1.858	1.938	2.047		(41)
(42)		Ebn at Noon	757	762	760	787	787	760	763	777	778	694	667	700		(42)
(43)		Edh at Noon	117	151	185	190	192	209	205	187	169	169	138	117		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.10	2.80	4.11	5.49	6.79	7.84	7.84	7.20	6.01	4.20	2.58	1.90		(44)
(45)		RadStd	0.24	0.38	0.36	0.52	0.43	0.30	0.22	0.21	0.16	0.33	0.30	0.26		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page