

PARKHAR, Tajikistan

WMO: 389440

Lat: 37.483N

Lon: 69.383E

Elev: 447

StdP: 96.07

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.2	-4.6	-9.5	1.8	-7.0	-6.3	2.3	-2.6	9.7	4.9	8.2	5.1	1.4	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	39.2	20.9	38.1	20.2	37.1	19.7	22.2	35.7	21.2	35.1	20.5	34.4	2.5	160

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	13.5	27.6	16.8	12.6	26.3	15.8	11.9	25.6	67.8	36.0	64.0	35.0	61.3	34.6	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.6	6.4	5.4	-10.3	41.1	5.7	0.5	-14.4	41.5	-17.7	41.8	-20.9	42.1	-25.0	42.5
			-10.5	23.4	5.6	1.2	-14.5	24.3	-17.7	25.0	-20.9	25.6	-24.9	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	4.9	6.0	13.2	18.3	23.9	28.8	30.7	28.6	24.2	17.8	10.3	5.5	(6)
		DBStd	9.87	3.81	5.51	4.19	3.85	3.12	2.30	1.69	2.03	2.35	3.62	4.42	3.93	
		HDD10.0	496	161	127	19	2	0	0	0	0	1	43	143		
		HDD18.3	1669	418	346	164	45	2	0	0	1	53	244	397		
		CDD10.0	3330	2	14	118	252	432	565	642	577	427	244	53	4	
		CDD18.3	1462	0	0	5	45	175	315	384	319	177	38	3	0	
		CDH23.3	18009	0	1	46	344	1757	4092	5464	4061	1853	365	27	0	
		CDH26.7	9942	0	0	9	90	792	2374	3367	2336	881	91	4	0	
(14)	Wind	WSAvg	2.0	2.0	2.2	2.4	2.1	2.5	2.4	2.2	1.9	1.7	1.4	1.4		(14)
(15)	Precipitation	PrecAvg	482	57	83	84	69	45	15	15	13	8	16	36	40	(15)
(16)		PrecMax	634	143	169	148	105	129	47	42	26	30	44	107	86	(16)
(17)		PrecMin	270	21	32	14	22	6	2	2	2	1	7	8		(17)
(18)		PrecStd	90	27	33	32	22	26	10	9	6	7	12	24	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	15.8	21.4	27.3	32.5	37.1	39.9	41.0	39.2	35.2	31.5	26.9	16.9		(19)
(20)		0.4% MCWB	9.4	12.2	15.5	18.6	19.9	20.6	21.7	21.5	18.8	16.8	15.5	9.9		(20)
(21)		2% DB	13.7	17.2	24.2	29.2	34.7	38.6	39.7	37.9	34.2	28.9	22.0	14.8		(21)
(22)		2% MCWB	8.7	11.4	14.6	17.5	18.9	20.1	21.5	20.3	18.3	15.6	13.0	9.1		(22)
(23)		5% DB	11.9	14.8	21.8	27.1	33.0	37.4	38.6	36.8	33.1	27.4	19.1	13.0		(23)
(24)		5% MCWB	7.9	10.1	13.7	17.0	18.6	19.6	20.7	19.6	17.8	15.1	12.1	8.4		(24)
(25)		10% DB	10.2	13.0	19.6	25.1	31.3	36.0	37.6	35.5	31.6	25.4	16.8	11.1		(25)
(26)		10% MCWB	7.2	9.1	12.9	16.6	18.3	19.2	20.0	19.2	17.2	14.3	10.9	7.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	10.5	13.2	16.7	21.2	21.6	22.9	24.6	23.0	19.6	17.1	15.7	11.6		(27)
(28)		0.4% MCDB	14.8	19.1	24.0	28.2	31.6	34.8	39.0	37.6	33.9	30.0	25.4	15.5		(28)
(29)		2% WB	9.4	11.6	15.3	19.5	20.5	21.2	22.7	21.2	18.8	16.1	13.9	9.7		(29)
(30)		2% MCDB	12.7	16.3	22.4	26.3	30.3	34.9	36.9	35.8	32.6	27.5	21.2	13.4		(30)
(31)		5% WB	8.4	10.5	14.2	18.4	19.7	20.5	21.6	20.5	18.1	15.3	12.4	8.9		(31)
(32)		5% MCDB	11.2	14.1	20.1	24.8	29.3	34.6	36.5	35.2	32.0	25.9	17.9	12.0		(32)
(33)		10% WB	7.3	9.5	13.3	17.3	19.1	19.9	20.6	19.7	17.4	14.6	11.3	7.9		(33)
(34)		10% MCDB	9.9	12.4	18.6	23.3	28.2	34.2	35.9	34.1	30.8	24.3	16.1	10.7		(34)
(35)	Mean Daily Temperature Range	MDBR	7.7	8.1	9.5	10.5	12.5	13.9	14.1	14.0	14.5	12.4	9.4	8.1		(35)
(36)		5% DB MCDBR	10.4	10.8	12.6	13.6	14.8	15.5	14.9	14.8	15.7	14.6	13.1	11.3		(36)
(37)		5% WB MCWBR	6.7	6.4	5.7	5.6	4.7	5.0	5.6	5.5	6.4	6.3	7.1	7.1		(37)
(38)		5% WB MCDBR	9.2	9.8	10.7	11.5	12.6	14.3	13.9	13.7	14.9	13.4	11.5	9.5		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.393	0.449	0.504	0.514	0.528	0.561	0.547	0.511	0.472	0.500	0.462	0.407		(40)
(41)		taud	2.088	1.956	1.856	1.871	1.865	1.782	1.804	1.879	1.932	1.838	1.916	2.038		(41)
(42)		Ebn at Noon	753	754	753	776	772	745	751	769	772	689	661	699		(42)
(43)		Edh at Noon	120	156	189	197	202	219	213	193	173	173	142	119		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.13	2.84	4.20	5.54	6.90	7.93	7.92	7.27	6.08	4.29	2.63	1.94		(44)
(45)		RadStd	0.23	0.40	0.35	0.51	0.44	0.30	0.24	0.18	0.15	0.31	0.29	0.27		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	-0.36	-0.68	N/A	N/A	N/A	N/A

Nomenclature: See separate page