

KHOROG, Tajikistan

WMO: 389540

Lat: 37.501N

Lon: 71.515E

Elev: 6814

StdP: 11.42

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.0	(c) 5.9	(d) -5.4	(e) 5.3	(f) 8.8	(g) -1.9	(h) 6.4	(i) 12.8	(j) 6.8	(k) 26.5	(l) 4.9	(m) 28.4	(n) 0.1	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 25.0	(c) 90.0	(d) 65.7	(e) 87.6	(f) 63.8	(g) 85.2	(h) 62.4	(i) 67.6	(j) 87.3	(k) 65.5	(l) 85.3	(m) 63.6	(n) 83.2	(o) 2.3	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.6	102.0	81.4	58.0	92.9	80.4	55.6	85.1	77.5	36.6	87.4	34.6	85.5	32.8	83.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.1	(b) 10.6	(c) 7.8	(e) -2.7	(f) 93.7	(g) 5.3	(h) 1.6	(i) -6.4	(j) 94.8	(k) -9.5	(l) 95.8	(m) -12.5	(n) 96.6	(o) -16.3	(p) 97.8		
(a) 14.1	(b) 10.6	(c) 7.8	(e) -4.3	(f) 71.2	(g) 6.0	(h) 2.7	(i) -8.6	(j) 73.1	(k) -12.1	(l) 74.7	(m) -15.5	(n) 76.2	(o) -19.9	(p) 78.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	20.0	25.3	38.6	51.4	59.4	66.6	72.6	72.3	64.1	52.2	40.6	29.0		
	DBStd	18.53	7.46	7.18	7.34	5.95	4.25	4.56	4.64	4.20	4.77	5.50	4.98	5.92		
	HDD50	3010	930	692	357	53	1	0	0	0	0	42	283	652		
	HDD65	6274	1395	1112	819	409	180	34	4	2	73	397	732	1117		
	CDD50	2811	0	0	3	94	292	499	700	691	422	109	1	0		
	CDD65	600	0	0	0	0	5	83	239	228	45	0	0	0		
	CDH74	6672	0	0	0	9	106	907	2576	2481	585	8	0	0		
	CDH80	2188	0	0	0	0	8	228	983	876	93	0	0	0		
(14) Wind	WSAvg	1.4	0.2	0.6	1.1	2.2	2.4	2.0	1.9	1.8	1.7	1.2	1.0	0.8		
(15) Precipitation	PrecAvg	9.4	1.1	1.4	2.0	1.6	1.3	0.3	0.1	0.0	0.0	0.6	0.7	1.3		
	PrecMax	17.8	4.8	3.5	5.3	4.5	3.6	1.3	0.7	0.2	0.4	4.9	3.0	7.2		
	PrecMin	2.8	0.0	0.2	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.0	0.9	0.8	1.2	1.1	0.9	0.3	0.2	0.0	0.1	1.1	0.8	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	43.4	60.9	73.8	80.9	89.2	93.7	92.4	85.3	74.6	60.2	46.7		
		MCWB	30.9	34.2	43.9	51.6	56.9	63.3	68.2	68.3	63.6	54.3	45.0	36.7		
	2%	DB	34.7	39.8	56.5	68.9	77.0	85.3	90.9	89.7	82.6	70.7	56.4	42.9		
		MCWB	29.6	32.2	42.0	49.8	54.0	61.0	66.4	65.3	61.3	52.3	42.9	34.6		
	5%	DB	32.5	37.0	52.9	65.8	74.0	82.5	88.3	87.4	80.2	67.8	53.0	40.4		
		MCWB	27.9	31.3	40.1	48.3	52.9	59.6	64.4	63.9	59.5	50.7	40.8	32.7		
	10%	DB	30.3	34.7	49.5	62.5	70.9	79.3	85.7	85.1	77.5	64.2	49.8	37.9		
		MCWB	26.8	30.2	38.7	46.5	51.4	58.0	63.0	62.5	58.0	48.7	38.8	31.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.2	36.6	45.8	54.0	58.7	65.2	69.8	71.4	66.3	55.5	45.7	38.9		
		MCDB	35.1	39.8	54.7	71.7	76.4	85.7	91.4	88.3	82.8	71.5	57.4	43.5		
	2%	WB	30.8	34.4	43.7	51.0	55.6	62.3	67.6	68.3	63.0	53.4	44.0	36.5		
		MCDB	33.2	37.0	52.4	64.6	73.0	82.6	88.5	86.8	79.5	68.8	53.3	41.0		
	5%	WB	28.9	32.8	41.9	49.4	54.2	60.5	65.7	65.7	60.6	51.5	42.3	33.9		
		MCDB	31.5	35.4	50.2	61.3	70.1	80.0	86.3	85.1	77.8	65.8	50.6	39.0		
	10%	WB	27.1	31.1	40.1	48.0	52.7	58.8	63.8	63.6	58.6	49.5	40.4	31.9		
		MCDB	29.9	34.1	48.0	59.3	67.1	77.5	84.0	83.3	75.9	62.3	47.8	36.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	14.8	14.8	17.3	21.2	23.9	25.0	25.7	25.7	22.5	17.8	14.5		
		MCDBR	14.7	13.9	18.8	22.2	26.6	28.2	28.1	27.5	28.6	27.4	22.3	16.2		
	5% WB	MCWBR	9.8	8.8	8.9	10.1	10.7	12.0	12.9	13.8	14.7	13.4	11.6	10.0		
		MCWBR	12.0	11.8	16.4	19.3	22.8	26.2	26.4	25.8	27.1	25.7	20.0	14.7		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.377	0.448	0.478	0.481	0.482	0.470	0.429	0.369	0.387	0.364	0.317		
	taud		2.002	1.864	1.758	1.789	1.838	1.859	1.911	2.043	2.188	2.038	2.025	2.095		
	Ebn at Noon		262	261	254	255	257	256	258	266	278	256	245	257		
	Edh at Noon		41	54	66	68	66	64	61	52	42	44	40	35		
(44) All-Sky Solar Radiation	RadAvg		855	1103	1595	1938	2047	2230	2362	2337	1980	1290	840	740		
	RadStd		53	97	97	146	147	175	152	113	79	140	96	49		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page