

QAMISHLI, Syrian Arab Republic

WMO: 400010

Lat: 37.021N

Lon: 41.191E

Elev: 1480

StdP: 13.93

Time Zone: 2.00 (SYR)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	32.3	10.8	10.1	43.3	14.7	12.2	45.9	29.7	47.4	26.2	46.7	8.6	0	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.8	109.6	67.4	107.6	67.0	105.5	66.7	71.9	99.0	70.2	98.3	68.8	97.9	10.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.9	90.6	83.6	60.3	82.7	80.7	58.3	76.8	78.7	36.6	98.3	35.1	98.3	33.9	97.9	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.0	21.2	18.5	DB	25.8	112.9	3.4	3.0	23.3	115.1	21.3	116.8	19.4	118.5	17.0	120.7
			WB	23.6	74.8	3.3	3.2	21.2	77.1	19.2	78.9	17.4	80.7	15.0	83.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	44.5	47.2	54.0	61.7	73.8	85.6	91.1	90.5	82.0	72.5	58.0	48.6	(6)
	DBStd	17.57	4.95	5.73	6.63	6.77	6.57	5.29	4.55	4.42	5.21	6.72	6.45	5.66	(7)
	HDD50	428	178	109	32	3	0	0	0	0	0	0	13	93	(8)
	HDD65	2377	636	499	347	141	9	0	0	0	0	15	220	510	(9)
	CDD50	6841	7	30	156	354	737	1069	1275	1254	961	698	252	48	(10)
	CDD65	3317	0	0	5	43	281	619	810	789	512	248	10	0	(11)
	CDH74	48440	0	0	38	464	3420	9234	13333	12724	6698	2444	80	5	(12)
	CDH80	30637	0	0	7	126	1630	5865	9279	8752	3959	1016	3	0	(13)
(14) Wind	WSAvg	8.2	8.8	8.5	8.5	7.9	8.3	9.2	8.6	7.5	7.5	7.3	7.0	8.9	(14)
(15) Precipitation	PrecAvg	16.5	3.6	2.6	3.0	2.5	1.1	0.1	0.0	0.0	0.0	0.9	1.6	2.7	(15)
	PrecMax	28.7	15.7	6.3	18.4	10.5	6.7	1.2	0.2	0.1	0.6	3.5	6.0	9.0	(16)
	PrecMin	8.6	0.2	0.5	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
	PrecStd	5.3	2.9	1.6	3.0	2.0	1.5	0.2	0.0	0.0	0.1	0.9	1.2	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.6	66.3	78.6	90.0	99.2	109.1	113.0	112.8	106.0	95.5	79.6	72.8	(19)
		MCWB	48.7	50.9	54.9	59.5	63.6	65.6	67.6	68.0	64.4	62.1	56.0	52.2	(20)
	2%	DB	57.7	63.0	73.4	83.6	95.1	105.5	110.2	109.5	102.4	92.3	76.4	64.8	(21)
		MCWB	46.8	50.1	54.9	59.9	62.7	66.0	67.8	67.3	64.7	61.8	54.7	49.5	(22)
	5%	DB	55.3	60.1	70.0	80.0	91.8	102.6	108.0	107.5	99.0	89.2	73.1	61.1	(23)
		MCWB	45.5	48.4	53.6	59.0	62.3	65.1	67.2	67.3	64.2	61.4	54.4	48.7	(24)
	10%	DB	52.6	57.1	66.4	75.9	88.9	100.3	105.9	105.4	96.5	85.8	69.6	57.7	(25)
		MCWB	45.0	46.9	52.6	57.7	61.9	64.6	66.8	67.0	63.7	60.3	53.3	47.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	54.7	61.5	66.3	70.2	74.3	73.5	73.8	73.7	66.4	61.0	54.0	(27)
		MCDB	58.2	62.2	69.3	81.6	88.1	93.2	103.2	101.6	92.9	87.6	68.8	63.4	(28)
	2%	WB	49.7	51.6	57.8	62.6	66.5	69.5	71.4	71.7	68.3	64.4	58.7	52.5	(29)
		MCDB	54.1	59.1	68.2	74.5	84.5	95.0	102.3	98.5	92.0	84.6	68.1	60.0	(30)
	5%	WB	48.1	49.9	55.5	60.8	64.7	67.3	69.9	70.1	66.4	62.9	56.9	51.2	(31)
		MCDB	52.4	56.8	66.3	74.3	84.3	95.4	100.8	98.4	92.5	83.0	66.8	57.5	(32)
	10%	WB	46.6	48.5	53.7	59.2	63.4	65.8	68.5	68.8	64.9	61.6	55.1	49.8	(33)
		MCDB	51.1	55.1	64.5	72.9	83.6	96.4	100.4	98.3	92.3	80.8	66.4	55.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	16.3	19.1	21.8	25.1	26.7	27.8	28.4	26.8	22.2	19.6	15.8	(35)
		MCDBR	19.0	20.2	23.2	26.2	28.1	28.0	28.8	29.3	29.2	25.1	23.5	21.3	(36)
	5% WB	MCWBR	11.0	10.9	11.6	11.5	9.8	10.1	10.9	11.6	12.4	10.9	11.1	11.5	(37)
		MCWBR	12.9	16.6	20.2	21.7	24.7	25.9	26.6	27.6	26.3	21.5	18.2	15.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.373	0.403	0.433	0.497	0.477	0.422	0.419	0.415	0.391	0.439	0.376	0.370	(40)
		taud	2.185	2.104	2.042	1.895	1.982	2.134	2.158	2.166	2.233	2.062	2.215	2.198	(41)
	Ebn at Noon		249	257	261	251	259	273	273	271	272	241	246	241	(42)
		Edh at Noon	35	43	50	61	57	49	48	46	41	44	34	32	(43)
(44) All-Sky Solar Radiation	RadAvg		725	988	1410	1750	2167	2571	2504	2241	1853	1281	918	663	(44)
	RadStd		80	117	98	136	142	105	57	67	70	90	86	88	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	-3.01	N/A	N/A	N/A	+92

Nomenclature: See separate page