

ALEPPO INTL, Syrian Arab Republic

WMO: 400070

Lat: 36.181N

Lon: 37.224E

Elev: 1276

StdP: 14.03

Time Zone: 2.00 (SYR)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.5	31.2	15.2	12.5	39.6	19.3	15.2	42.6	22.8	48.1	19.6	48.0	2.5	280	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.8	103.7	67.8	100.5	67.6	98.1	67.5	73.5	91.0	72.2	89.5	71.1	88.3	10.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.2	108.7	81.7	66.6	102.7	80.6	65.8	99.9	80.2	38.1	91.3	36.9	89.3	35.9	88.3	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.8	21.4	19.2	DB	24.2	108.8	2.7	4.0	22.2	111.7	20.6	114.0	19.1	116.2	17.1	119.2
			WB	22.4	75.8	2.7	1.5	20.4	76.9	18.8	77.7	17.3	78.6	15.3	79.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	43.7	46.3	52.7	61.1	71.5	80.6	85.6	85.2	78.6	69.0	55.1	46.1	(6)
		DBStd	15.97	4.45	5.17	5.55	6.32	5.84	4.47	3.53	3.50	4.41	5.85	6.31	5.18	(7)
		HDD50	527	200	121	35	4	0	0	0	0	0	0	27	140	(8)
		HDD65	2647	661	525	382	151	13	0	0	0	0	31	298	586	(9)
		CDD50	5901	4	16	118	335	667	918	1104	1091	859	589	181	19	(10)
		CDD65	2546	0	0	1	32	215	468	639	626	409	155	1	0	(11)
		CDH74	31495	0	0	19	411	2594	5802	8560	8182	4462	1432	33	0	(12)
		CDH80	17000	0	0	1	113	1136	3208	5068	4784	2231	459	0	0	(13)
(14)	Wind	WSAvg	7.9	5.6	6.3	6.8	7.8	9.0	11.6	13.1	11.7	8.8	5.6	4.3	4.8	(14)
(15)	Precipitation	PrecAvg	12.7	2.3	2.0	1.7	1.3	0.6	0.1	0.0	0.1	0.9	1.4	2.2		(15)
(16)		PrecMax	19.7	5.4	4.9	6.1	3.8	3.3	0.8	0.0	0.1	1.5	3.0	6.4		(16)
(17)		PrecMin	5.6	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		(17)
(18)		PrecStd	3.4	1.2	1.1	1.1	0.9	0.8	0.2	0.0	0.3	0.9	0.8	1.2		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	60.4	64.5	76.7	89.2	97.9	104.1	109.1	107.3	100.2	92.3	77.3	65.8		(19)
(20)		0.4% MCWB	51.6	52.5	56.9	62.2	64.4	65.6	67.8	68.3	66.7	62.6	56.6	52.8		(20)
(21)		2% DB	56.3	61.2	71.5	82.8	93.7	100.4	104.1	102.8	96.5	88.1	73.8	60.7		(21)
(22)		2% MCWB	48.5	50.6	54.8	59.6	63.1	65.1	68.2	68.8	65.9	62.0	55.7	51.4		(22)
(23)		5% DB	53.7	59.0	67.9	78.7	90.0	97.1	100.6	100.2	93.6	85.1	70.9	57.4		(23)
(24)		5% MCWB	47.4	50.1	53.9	58.6	62.0	64.8	68.2	68.4	65.8	61.4	55.3	49.6		(24)
(25)		10% DB	51.6	55.9	64.4	74.8	86.5	94.5	97.8	97.1	91.3	82.1	67.1	54.8		(25)
(26)		10% MCWB	46.1	48.7	52.3	57.5	61.5	64.5	68.2	68.8	65.3	60.9	54.5	49.0		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	53.2	54.7	60.2	64.7	67.4	70.9	75.4	75.3	72.0	67.9	61.2	55.7		(27)
(28)		0.4% MCDB	58.0	61.4	70.8	79.2	86.2	89.6	94.5	93.1	87.6	80.6	69.2	60.0		(28)
(29)		2% WB	50.7	52.4	57.1	61.9	65.6	69.5	73.6	73.8	70.6	65.8	59.4	53.3		(29)
(30)		2% MCDB	54.3	58.8	67.0	76.8	85.3	88.0	92.2	90.7	86.2	79.0	68.1	57.9		(30)
(31)		5% WB	49.2	50.9	55.0	60.1	64.2	68.2	72.1	72.7	69.6	64.5	57.8	51.9		(31)
(32)		5% MCDB	52.1	57.0	64.6	74.7	83.5	87.6	90.2	89.6	85.1	78.2	65.8	55.7		(32)
(33)		10% WB	47.6	49.5	53.4	58.4	62.9	67.1	71.0	71.6	68.4	63.2	56.2	50.3		(33)
(34)		10% MCDB	50.2	54.9	62.8	71.9	82.1	86.6	89.0	88.5	83.6	76.4	63.5	53.8		(34)
(35)	Mean Daily Temperature Range	MDBR	14.6	17.0	20.0	22.3	25.7	25.5	24.8	24.7	24.5	23.0	20.3	15.5		(35)
(36)		5% DB MCDBR	18.5	21.1	25.8	27.9	30.5	29.2	28.8	28.1	27.2	27.3	26.0	20.6		(36)
(37)		5% DB MCWBR	12.1	12.7	12.8	11.2	10.0	8.7	8.2	7.8	8.6	10.8	12.5	12.7		(37)
(38)		5% WB MCDBR	14.7	18.5	22.2	25.0	26.4	25.2	24.8	24.7	23.9	22.7	19.6	15.9		(38)
(39)		5% WB MCWBR	10.8	12.1	11.9	11.2	9.4	8.1	7.7	7.6	7.7	9.6	10.8	10.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.394	0.421	0.478	0.460	0.411	0.411	0.425	0.398	0.424	0.381	0.367		(40)
(41)		taud	2.243	2.162	2.097	1.959	2.053	2.216	2.233	2.186	2.258	2.144	2.234	2.252		(41)
(42)		Ebn at Noon	254	262	266	257	264	276	275	269	271	248	248	246		(42)
(43)		Edh at Noon	34	41	48	57	53	45	44	45	40	41	34	31		(43)
(44)	All-Sky Solar Radiation	RadAvg	720	995	1453	1829	2218	2558	2514	2235	1836	1310	931	674		(44)
(45)		RadStd	80	133	93	120	107	62	45	56	61	70	83	97		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (12 neighbors)	N/A	N/A	-3.46	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page