

LATAKIA, Syrian Arab Republic

WMO: 400220

Lat: 35.533N

Lon: 35.767E

Elev: 23

StdP: 14.68

Time Zone: 2.00 (SYR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.8	42.6	20.9	15.7	47.9	25.0	19.1	49.8	33.4	57.0	27.9	58.7	5.2	60	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	90.6	74.5	88.8	76.0	87.6	76.4	80.1	87.1	79.2	86.2	78.4	85.3	6.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.0	145.8	85.9	77.0	140.6	85.1	76.1	136.3	84.4	43.9	87.5	42.8	86.4	42.0	85.6	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.1	19.0	16.0	DB	33.9	98.0	3.7	4.1	31.2	100.9	29.0	103.3	26.9	105.6	24.2	108.5
			WB	30.4	83.1	3.1	1.9	28.1	84.5	26.3	85.6	24.6	86.7	22.3	88.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	54.0	55.7	59.5	64.2	70.5	76.1	80.5	82.2	78.9	73.4	64.7	57.1
	DBStd	10.63	4.67	4.81	5.21	5.13	4.30	2.98	2.12	2.08	2.80	4.49	5.48	4.72
	HDD50	39	19	10	3	0	0	0	0	0	0	0	0	7
	HDD65	1183	341	261	186	73	4	0	0	0	0	3	69	246
	CDD50	6655	143	169	296	425	636	784	945	998	867	724	441	227
	CDD65	2325	0	1	14	48	174	334	480	533	417	262	60	2
	CDH74	21883	0	3	84	314	944	2608	5327	6405	4106	1806	281	5
	CDH80	6552	0	0	17	98	259	501	1612	2377	1221	427	40	0
(14) Wind	WSAvg	6.5	7.0	7.8	7.2	6.8	6.5	6.3	7.0	6.6	5.9	5.3	5.5	6.3
(15) Precipitation	PrecAvg	29.9	6.5	4.4	3.7	1.9	0.9	0.2	0.0	0.1	0.6	3.0	3.5	6.3
	PrecMax	43.3	23.4	13.8	14.7	7.2	4.5	0.8	0.8	1.1	3.3	14.2	12.3	18.1
	PrecMin	17.1	1.2	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
	PrecStd	7.9	5.0	2.7	2.8	1.7	0.9	0.2	0.2	0.2	0.9	2.6	2.6	4.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.9	73.6	81.5	89.6	92.8	92.6	91.4	91.7	92.4	93.4	84.9	73.0
		MCWB	57.1	59.0	60.1	65.4	67.9	70.2	76.2	80.0	73.6	66.0	64.0	58.0
	2%	DB	65.9	69.4	75.2	82.0	86.5	86.4	88.5	89.7	88.3	87.3	80.3	69.4
		MCWB	56.9	57.2	59.3	63.3	67.3	74.0	77.5	78.9	76.0	69.3	62.7	58.4
	5%	DB	64.1	66.2	71.3	76.8	82.1	84.4	87.2	88.5	86.9	84.2	77.1	67.1
		MCWB	55.6	56.4	58.7	62.2	68.3	74.3	77.3	78.3	75.6	70.3	62.8	57.7
	10%	DB	62.1	63.9	67.7	73.2	78.5	82.7	86.0	87.6	85.7	82.0	74.5	65.1
		MCWB	54.3	55.5	58.3	62.3	68.3	73.7	77.0	77.9	75.0	70.0	62.2	56.5
	0.4%	WB	61.3	62.2	64.7	68.8	73.8	78.8	81.3	82.0	80.3	76.3	69.5	62.8
		MCDB	66.0	68.4	73.7	79.1	82.1	85.6	87.8	89.0	87.6	84.1	76.7	68.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	58.5	59.9	62.4	66.6	71.9	77.0	79.7	80.6	78.4	74.2	67.0	60.9
		MCDB	64.0	66.0	69.5	75.4	79.3	83.4	86.2	87.8	85.8	82.3	75.6	66.7
	5%	WB	56.8	58.0	60.8	65.1	70.6	75.7	78.7	79.6	77.2	72.8	65.2	59.3
		MCDB	62.6	64.4	67.7	73.1	77.9	82.2	85.3	86.8	84.7	80.9	74.1	65.5
	10%	WB	55.0	56.5	59.4	63.5	69.4	74.7	77.9	78.9	76.3	71.5	63.5	57.6
		MCDB	60.8	62.9	66.2	70.9	76.6	81.2	84.4	86.0	83.9	79.7	72.3	63.7
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	14.1	14.7	14.9	14.4	12.6	11.2	10.7	13.7	16.4	17.2	14.9
		MCDBR	16.2	18.1	21.3	22.8	22.3	16.4	13.7	12.4	15.8	19.4	20.8	17.6
		MCWBR	10.1	11.4	12.7	12.6	12.7	10.7	9.7	8.2	10.2	11.8	12.0	10.9
	5% WB	MCDBR	13.4	15.1	16.9	18.5	16.5	14.1	12.3	11.8	14.0	16.4	17.7	14.4
		MCWBR	9.5	10.6	11.3	12.2	10.8	10.0	9.3	8.3	9.8	11.2	12.0	9.9
(40) Clear-Sky Solar Irradiance	taub		0.381	0.406	0.441	0.493	0.483	0.444	0.466	0.475	0.437	0.439	0.396	0.380
	taud		2.305	2.226	2.130	2.009	2.095	2.257	2.209	2.171	2.280	2.224	2.297	2.313
	Ebn at Noon		253	261	261	253	258	267	260	256	260	246	246	245
	Edh at Noon		32	39	46	55	51	43	45	46	39	38	32	30
(44) All-Sky Solar Radiation	RadAvg		747	1045	1504	1876	2274	2521	2455	2194	1834	1334	947	692
	RadStd		71	117	72	129	107	49	46	50	56	75	68	88

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	+0.50	N/A	-2.86	N/A	N/A	N/A	N/A	N/A	+254	N/A

Nomenclature: See separate page