

DEIR EZ-ZUR, Syrian Arab Republic

WMO: 400450

Lat: 35.285N

Lon: 40.176E

Elev: 213

StdP: 98.79

Time Zone: 2.00 (SYR)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.6	0.0	-9.9	1.6	4.5	-7.9	2.0	7.0	11.9	8.2	10.2	8.8	1.7	290	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	42.6	21.3	41.3	20.9	40.0	20.6	23.8	38.2	23.0	37.0	22.2	36.3	4.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	14.0	32.9	17.8	13.1	31.6	16.9	12.4	30.8	72.5	38.5	69.1	37.3	66.1	36.4	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	9.8	8.4	DB	-4.0	45.0	2.5	1.2	-5.8	45.9	-7.2	46.6	-8.6	47.3	-10.4	48.2	(4)
(5)			WB	-5.0	25.1	2.3	1.0	-6.7	25.9	-8.0	26.5	-9.3	27.1	-11.0	27.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.7	7.5	9.9	14.3	19.4	25.6	30.8	33.7	33.0	28.4	22.6	13.8	9.1	(6)	
	DBStd	9.70	2.65	3.05	3.18	3.49	3.25	2.44	1.97	1.91	2.48	3.21	3.56	2.93	(7)	
	HDD10.0	187	85	36	4	1	0	0	0	0	0	0	10	52	(8)	
	HDD18.3	1161	337	236	131	27	1	0	0	0	0	6	138	286	(9)	
	CDD10.0	4107	6	33	137	282	484	624	736	713	553	391	125	24	(10)	
	CDD18.3	2039	0	0	6	58	226	374	477	454	303	138	3	0	(11)	
	CDH23.3	29158	0	0	79	627	2753	5541	7781	7159	3846	1339	32	1	(12)	
	CDH26.7	17984	0	0	17	217	1434	3484	5348	4775	2165	543	2	0	(13)	
(14) Wind	WSAvg	2.9	1.9	2.5	3.0	3.2	3.5	4.5	4.7	3.6	3.0	1.9	1.7	1.8	(14)	
(15) Precipitation	PrecAvg	154	27	24	26	19	8	0	1	0	1	7	15	21	(15)	
	PrecMax	299	91	81	132	97	58	8	29	1	15	33	65	72	(16)	
	PrecMin	49	1	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	59	21	20	30	22	12	1	4	0	2	10	17	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	20.9	29.0	35.2	39.4	42.8	44.6	43.7	40.1	35.3	26.2	20.0	(19)	
		MCWB	11.6	11.8	15.2	17.8	20.4	20.0	22.2	21.9	20.3	19.0	14.1	12.6	(20)	
	2%	DB	15.2	19.0	25.2	31.8	37.0	40.8	43.0	42.2	38.1	33.3	24.0	17.4	(21)	
		MCWB	10.4	11.3	13.5	16.8	18.7	19.7	21.5	21.8	20.2	18.6	14.1	11.7	(22)	
	5%	DB	13.9	17.4	23.1	29.3	35.2	39.4	41.7	40.8	36.8	31.5	22.4	15.8	(23)	
		MCWB	9.9	10.8	13.1	15.8	18.2	19.3	21.0	21.3	20.0	17.9	13.7	11.0	(24)	
	10%	DB	12.6	15.9	21.1	27.2	33.5	38.1	40.4	39.5	35.4	29.7	20.8	14.3	(25)	
		MCWB	9.1	10.2	12.3	15.2	17.7	19.0	20.7	21.1	19.8	17.6	13.3	10.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	13.7	16.9	19.2	21.8	22.3	24.8	25.4	23.2	20.8	17.1	13.6	(27)	
		MCDB	15.5	17.7	23.8	31.2	36.2	37.8	40.3	39.1	35.5	31.9	22.2	17.2	(28)	
	2%	WB	11.5	12.3	15.2	17.7	20.3	21.3	23.8	24.0	22.1	19.8	16.1	12.6	(29)	
		MCDB	14.1	16.8	21.8	28.1	33.1	36.7	39.1	38.0	34.8	30.4	20.9	15.8	(30)	
	5%	WB	10.6	11.5	14.2	16.7	19.2	20.5	22.9	23.2	21.3	18.9	15.1	11.8	(31)	
		MCDB	12.9	16.1	20.7	26.8	32.2	35.9	37.7	37.0	34.0	29.2	19.9	14.8	(32)	
	10%	WB	9.6	10.7	13.1	15.8	18.4	19.9	22.0	22.4	20.6	18.1	14.0	11.0	(33)	
		MCDB	11.8	15.0	19.8	25.4	31.2	35.1	37.0	36.2	33.1	27.7	19.1	13.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	10.5	12.0	12.9	13.6	13.5	13.5	13.6	13.9	13.4	12.6	10.3	(35)	
		MCDBR	11.3	12.7	14.8	15.8	15.8	14.7	14.4	14.8	15.3	15.7	14.6	12.0	(36)	
	5% WB	MCWBR	7.2	6.7	7.1	6.2	5.9	5.2	5.3	5.9	6.9	7.2	7.7	7.3	(37)	
		MCWBR	9.4	10.8	12.6	13.8	14.3	13.8	13.7	13.8	13.9	13.5	11.9	10.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.387	0.417	0.450	0.529	0.530	0.480	0.478	0.471	0.445	0.483	0.408	0.392	(40)	
		taud	2.087	2.008	1.933	1.765	1.785	1.911	1.930	1.950	2.002	1.898	2.054	2.072	(41)	
	Ebn at Noon	Ebn at Noon	780	802	812	769	774	812	811	808	807	722	747	742	(42)	
		Edh at Noon	125	151	178	221	220	194	189	181	164	167	128	120	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.73	3.63	4.97	6.04	7.13	8.04	7.70	6.89	5.80	4.29	3.19	2.47	(44)	
	RadStd	RadStd	0.17	0.30	0.24	0.31	0.36	0.27	0.19	0.23	0.24	0.25	0.23	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page