

SAFITA, Syrian Arab Republic

WMO: 400660

Lat: 34.817N

Lon: 36.133E

Elev: 1178

StdP: 14.08

Time Zone: 2.00 (SYR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 38.2	(c) 40.7	(d) 15.2	(e) 12.4	(f) 49.5	(g) 19.6	(h) 15.4	(i) 50.8	(j) 34.0	(k) 46.9	(l) 31.1	(m) 47.2	(n) 10.3	(o) 90	(p) 0.322

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.9	(c) 92.5	(d) 69.2	(e) 89.8	(f) 69.8	(g) 87.6	(h) 70.3	(i) 76.5	(j) 84.9	(k) 75.4	(l) 83.3	(m) 74.5	(n) 81.9	(o) 5.4	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.2	133.6	80.3	73.2	128.8	79.4	72.3	124.8	78.9	41.0	85.6	39.9	83.5	39.0	82.2	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 26.0	(b) 20.2	(c) 16.4	(e) 33.9	(f) 99.1	(g) 3.0	(h) 3.4	(i) 31.7	(j) 101.5	(k) 30.0	(l) 103.5	(m) 28.3	(n) 105.4	(o) 26.2	(p) 107.9		
			DB													
			WB													
				33.9	99.1	3.0	3.4	31.7	101.5	30.0	103.5	28.3	105.4	26.2	107.9	
				29.8	79.7	3.3	2.8	27.4	81.7	25.5	83.3	23.6	84.9	21.2	86.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.3	50.9	52.5	56.7	63.0	70.1	75.3	78.9	80.2	77.5	72.5	62.6	54.1
	DBStd	11.66	5.00	5.31	6.19	7.00	5.95	4.07	2.77	2.80	3.34	5.59	6.58	5.97
	HDD50	125	50	31	12	2	0	0	0	0	0	0	2	28
	HDD65	1662	439	349	269	118	17	0	0	0	0	9	121	340
	CDD50	6059	76	102	219	392	623	758	897	935	826	697	378	156
	CDD65	2121	0	0	11	58	174	308	432	470	376	241	48	3
	CDH74	15307	0	0	47	414	1158	2084	3476	4081	2599	1320	119	9
	CDH80	4672	0	0	11	112	348	617	1072	1355	790	351	15	1
(14) Wind	WSAvg	5.2	6.7	6.8	6.1	6.0	4.4	4.1	4.3	3.8	3.6	3.5	5.7	7.2
(15) Precipitation	PrecAvg	36.4	7.6	6.2	4.4	2.1	1.0	0.2	0.1	0.1	0.8	2.7	4.3	6.5
	PrecMax	60.9	16.8	15.5	13.2	9.1	4.4	1.7	1.0	0.6	4.8	7.8	10.8	12.1
	PrecMin	17.0	2.6	1.3	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1
	PrecStd	10.7	3.2	3.1	2.7	1.9	0.9	0.4	0.2	0.1	1.3	2.4	2.7	3.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.9	68.5	80.2	89.8	93.9	94.8	95.1	95.9	94.4	91.7	82.1	71.7
		MCWB	54.0	53.6	57.9	63.8	64.9	67.9	73.1	72.7	65.7	64.2	60.0	54.8
	2%	DB	62.4	65.2	73.9	82.4	87.9	89.7	90.1	90.9	89.9	87.5	77.1	67.4
		MCWB	52.4	52.7	55.7	60.5	63.3	67.3	72.2	73.9	68.2	63.6	58.3	53.4
	5%	DB	59.5	62.3	69.7	78.5	83.7	86.2	87.5	88.4	86.8	83.9	73.8	64.1
		MCWB	51.2	51.7	54.1	58.9	63.7	67.9	72.4	73.8	69.5	63.3	57.4	53.4
	10%	DB	57.2	59.6	66.3	74.5	80.4	83.4	85.4	86.5	84.4	81.1	71.0	61.2
		MCWB	50.3	50.4	53.3	58.1	63.3	68.1	72.3	73.5	69.2	63.7	56.6	52.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	57.1	60.7	66.2	70.9	74.6	78.3	78.3	75.6	71.7	66.3	58.8
		MCDB	61.8	62.9	74.1	78.4	82.1	84.2	87.7	87.9	83.8	79.7	72.2	64.7
	2%	WB	54.5	54.8	58.1	63.2	68.5	72.7	76.0	76.9	74.2	70.1	63.0	56.9
		MCDB	59.7	61.4	67.5	76.2	78.9	81.5	85.3	85.2	82.2	77.9	71.2	62.8
	5%	WB	52.9	53.3	56.6	61.3	67.0	71.6	74.9	76.0	73.1	68.7	60.9	55.3
		MCDB	57.9	59.5	65.2	73.3	76.9	79.8	82.9	83.7	80.8	76.2	69.1	60.7
	10%	WB	51.2	51.9	55.2	59.7	65.5	70.5	74.0	75.1	72.0	67.4	59.1	53.7
		MCDB	56.4	58.0	62.9	70.7	75.3	78.5	81.5	82.3	79.6	75.2	67.3	59.7
(35) Mean Daily Temperature Range	MDBR		9.5	10.4	11.4	13.1	14.2	13.7	12.4	12.9	13.7	13.1	11.3	10.1
	5% DB	MCDBR	12.8	13.6	16.6	18.2	19.2	18.2	15.5	15.6	17.2	16.8	14.1	13.8
		MCWBR	7.5	7.9	9.3	10.0	9.7	9.5	7.8	6.1	7.0	9.1	8.1	8.3
	5% WB	MCDBR	11.1	11.8	13.6	16.1	16.0	14.2	13.5	14.1	14.4	14.4	11.7	11.5
		MCWBR	7.2	7.6	8.3	9.9	9.5	8.3	6.8	6.1	6.1	8.9	8.3	7.4
(40) Clear-Sky Solar Irradiance	taub		0.362	0.389	0.427	0.477	0.467	0.416	0.428	0.437	0.418	0.430	0.380	0.365
	taud		2.328	2.230	2.117	1.989	2.067	2.261	2.241	2.205	2.257	2.189	2.307	2.325
	Ebn at Noon		263	267	266	259	262	275	271	266	266	250	253	253
	Edh at Noon		31	39	47	56	53	43	44	45	41	40	32	30
(44) All-Sky Solar Radiation	RadAvg		754	1032	1499	1883	2274	2554	2504	2261	1887	1370	970	710
	RadStd		65	112	89	122	125	52	41	45	63	70	74	73

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.54	N/A	-2.23	N/A	N/A	N/A	N/A	+311	+198

Nomenclature: See separate page