

SAFITA, Syrian Arab Republic

WMO: 400660

Lat: 34.817N

Lon: 36.133E

Elev: 359

StdP: 97.09

Time Zone: 2.00 (SYR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.5	(c) 4.9	(d) -9.3	(e) 1.8	(f) 9.7	(g) -6.9	(h) 2.2	(i) 10.5	(j) 15.2	(k) 8.3	(l) 13.9	(m) 8.4	(n) 4.6	(o) 90	(p) 0.322

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.2	(c) 33.6	(d) 20.7	(e) 32.1	(f) 21.0	(g) 30.9	(h) 21.3	(i) 24.7	(j) 29.4	(k) 24.1	(l) 28.5	(m) 23.6	(n) 27.7	(o) 2.4	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	19.1	26.8	22.9	18.4	26.3	22.4	17.8	26.0	77.5	29.8	74.9	28.6	72.9	27.9	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.6	(b) 9.0	(c) 7.4	(e) 1.0	(f) 37.3	(g) 1.6	(h) 1.9	(i) -0.1	(j) 38.6	(k) -1.1	(l) 39.7	(m) -2.0	(n) 40.8	(o) -3.2	(p) 42.2		
(a) 11.6	(b) 9.0	(c) 7.4	(e) -1.2	(f) 26.5	(g) 1.8	(h) 1.5	(i) -2.5	(j) 27.6	(k) -3.6	(l) 28.5	(m) -4.6	(n) 29.4	(o) -6.0	(p) 30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	10.5	11.4	13.7	17.2	21.2	24.0	26.1	26.8	25.3	22.5	17.0	12.3
	DBStd	6.48	2.78	2.95	3.44	3.89	3.30	2.26	1.54	1.56	1.86	3.11	3.65	3.32
	HDD10.0	69	28	17	7	1	0	0	0	0	0	0	1	16
	HDD18.3	923	244	194	149	66	9	0	0	0	0	5	67	189
	CDD10.0	3366	42	57	122	218	346	421	498	519	459	387	210	87
	CDD18.3	1178	0	0	6	32	97	171	240	261	209	134	27	2
	CDH23.3	8504	0	0	26	230	643	1158	1931	2267	1444	733	66	5
CDH26.7	2596	0	0	6	62	193	343	596	753	439	195	8	1	
Wind	WSAvg	2.3	3.0	3.0	2.7	2.7	2.0	1.8	1.9	1.7	1.6	1.5	2.5	3.2
Precipitation	PrecAvg	925	192	157	113	53	26	6	2	2	20	68	109	164
	PrecMax	1548	427	393	335	230	113	42	25	15	123	199	274	307
	PrecMin	432	67	34	18	1	0	0	0	0	0	1	0	29
	PrecStd	271	82	80	68	48	24	9	5	3	34	60	69	82
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	20.3	26.8	32.1	34.4	34.9	35.1	35.5	34.7	33.2	27.9	22.1
		MCWB	12.2	12.0	14.4	17.7	18.3	20.0	22.8	22.6	18.7	17.9	15.5	12.7
	2%	DB	16.9	18.4	23.3	28.0	31.1	32.1	32.3	32.7	32.2	30.8	25.1	19.6
		MCWB	11.3	11.5	13.2	15.8	17.4	19.6	22.4	23.3	20.1	17.5	14.6	11.9
	5%	DB	15.3	16.8	20.9	25.9	28.7	30.1	30.8	31.3	30.5	28.8	23.2	17.8
		MCWB	10.7	10.9	12.3	15.0	17.6	19.9	22.4	23.2	20.8	17.4	14.1	11.9
	10%	DB	14.0	15.3	19.0	23.6	26.9	28.5	29.7	30.3	29.1	27.3	21.6	16.2
		MCWB	10.2	10.2	11.8	14.5	17.4	20.1	22.4	23.0	20.7	17.6	13.6	11.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	13.9	16.0	19.0	21.6	23.7	25.7	25.7	24.2	22.1	19.1	14.9
		MCDB	16.6	17.2	23.4	25.8	27.8	29.0	30.9	31.1	28.8	26.5	22.3	18.2
	2%	WB	12.5	12.7	14.5	17.4	20.3	22.6	24.5	25.0	23.5	21.2	17.2	13.8
		MCDB	15.4	16.3	19.7	24.6	26.1	27.5	29.6	29.6	27.9	25.5	21.8	17.1
	5%	WB	11.6	11.8	13.7	16.3	19.4	22.0	23.8	24.4	22.8	20.4	16.0	12.9
		MCDB	14.4	15.3	18.4	23.0	25.0	26.6	28.3	28.7	27.1	24.6	20.6	16.0
	10%	WB	10.7	11.1	12.9	15.4	18.6	21.4	23.3	23.9	22.2	19.7	15.0	12.1
		MCDB	13.6	14.4	17.2	21.5	24.1	25.8	27.5	27.9	26.5	24.0	19.6	15.4
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.8	6.3	7.3	7.9	7.6	6.9	7.2	7.6	7.3	6.3	5.6
		MCDBR	7.1	7.5	9.2	10.1	10.7	10.1	8.6	8.6	9.6	9.3	7.8	7.7
		MCWBR	4.2	4.4	5.1	5.6	5.4	5.3	4.3	3.4	3.9	5.1	4.5	4.6
	5% WB	MCDBR	6.2	6.5	7.6	9.0	8.9	7.9	7.5	7.8	8.0	8.0	6.5	6.4
		MCWBR	4.0	4.2	4.6	5.5	5.3	4.6	3.8	3.4	3.4	4.9	4.6	4.1
Clear-Sky Solar Irradiance	taub	0.362	0.389	0.427	0.477	0.467	0.416	0.428	0.437	0.418	0.430	0.380	0.365	
	taud	2.328	2.230	2.117	1.989	2.067	2.261	2.241	2.205	2.257	2.189	2.307	2.325	
	Ebn at Noon	828	843	840	815	827	868	855	840	839	787	798	797	
	Edh at Noon	99	122	149	177	166	136	139	141	128	126	101	95	
All-Sky Solar Radiation	RadAvg	2.38	3.25	4.73	5.93	7.17	8.05	7.89	7.13	5.95	4.32	3.06	2.24	
	RadStd	0.21	0.35	0.28	0.39	0.39	0.16	0.13	0.14	0.20	0.22	0.23	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	+0.30	N/A	-1.24	N/A	N/A	N/A	N/A	N/A	+173	+110

Nomenclature: See separate page