

DAMASCUS INTL, Syrian Arab RepublicWMO: **400800**Lat: **33.412N**Lon: **36.516E**Elev: **2020**StdP: **13.65**Time Zone: **2.00 (SYR)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	29.8	10.0	9.9	45.6	14.4	12.3	48.9	32.8	49.9	29.0	49.7	2.9	350	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.3	104.0	66.1	101.2	65.3	98.8	64.9	70.8	88.5	69.4	86.8	68.3	85.8	10.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	105.3	74.4	64.8	99.2	73.7	64.0	96.1	73.3	35.9	88.2	34.8	86.1	33.9	85.7	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.3	24.6	21.9	21.0	108.5	4.1	2.9	18.1	110.5	15.7	112.2	13.4	113.8	10.5	115.9		
			18.9	74.6	4.4	2.8	15.7	76.7	13.2	78.3	10.7	79.9	7.6	82.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.3	44.7	48.0	54.3	62.1	71.0	78.2	82.9	82.6	76.8	67.6	55.2	46.9	(6)
(7)		DBStd	14.56	4.61	5.19	5.90	6.51	5.71	4.00	3.08	3.27	4.31	5.92	5.95	4.99	(7)
(8)		HDD50	427	172	89	22	3	0	0	0	0	0	0	20	121	(8)
(9)		HDD65	2488	631	477	337	131	15	0	0	0	0	39	297	561	(9)
(10)		CDD50	5638	7	32	153	365	651	847	1018	1012	805	547	176	25	(10)
(11)		CDD65	2226	0	0	4	44	201	397	553	547	356	121	3	0	(11)
(12)		CDH74	30296	0	7	148	890	3105	5540	7386	6994	4450	1680	96	0	(12)
(13)		CDH80	17509	0	0	36	304	1545	3316	4743	4413	2487	653	12	0	(13)
(14)	Wind	WSAvg	8.8	7.2	8.4	9.4	9.4	9.6	11.0	12.3	11.0	8.8	6.5	5.7	6.3	(14)
(15)	Precipitation	PrecAvg	6.8	1.6	1.3	0.9	0.5	0.3	0.0	0.0	0.0	0.0	0.4	1.1	1.6	(15)
(16)		PrecMax	11.0	12.2	4.6	5.3	2.2	3.0	0.6	0.0	0.0	0.3	1.8	3.7	11.9	(16)
(17)		PrecMin	2.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.3	1.9	1.1	0.9	0.6	0.6	0.1	0.0	0.0	0.0	0.4	1.0	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.7	73.8	84.5	92.7	100.0	104.2	108.7	107.2	102.5	94.8	82.0	69.7	(19)
MCWB			50.6	53.6	56.6	59.8	63.4	64.3	66.1	68.0	65.3	62.4	57.2	52.3	(20)	
2%		DB	60.9	67.7	78.2	87.6	95.4	100.7	104.4	103.6	98.7	91.0	76.7	64.4	(21)	
		MCWB	49.4	50.2	54.4	58.1	61.4	63.7	65.9	67.0	64.8	61.5	55.9	51.2	(22)	
5%		DB	57.9	63.3	73.3	83.8	92.8	98.3	101.2	100.6	95.3	87.4	73.1	60.9	(23)	
		MCWB	48.1	49.0	52.5	56.8	60.8	63.3	65.1	66.1	63.7	60.8	54.8	49.9	(24)	
10%		DB	55.2	59.8	68.5	79.0	89.2	95.2	98.6	98.3	92.9	83.7	69.4	57.8	(25)	
		MCWB	46.8	47.9	51.1	55.0	59.7	62.7	65.1	65.8	63.4	59.9	53.6	48.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.5	54.6	59.4	62.5	65.6	69.0	72.0	73.3	70.6	67.6	61.0	57.7	(27)
MCD B			59.6	68.7	76.6	83.7	90.0	91.6	91.6	90.8	87.0	80.4	72.6	61.5	(28)	
2%		WB	50.9	52.3	56.2	60.0	63.7	67.1	70.3	71.1	68.4	64.3	58.5	53.4	(29)	
		MCD B	58.4	64.5	73.5	80.5	88.3	88.8	89.1	88.4	84.6	81.1	69.3	59.9	(30)	
5%		WB	49.2	50.3	53.9	58.1	62.2	65.7	68.9	69.9	67.1	62.8	57.1	51.5	(31)	
		MCD B	56.0	60.4	69.5	78.9	86.1	87.5	87.5	86.5	84.0	79.8	68.0	58.3	(32)	
10%		WB	47.8	48.8	52.0	56.4	60.9	64.6	67.8	68.7	65.9	61.4	55.4	50.0	(33)	
		MCD B	54.1	57.9	66.1	76.1	84.0	87.1	86.4	85.4	83.5	78.5	66.1	56.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.1	23.1	26.9	30.0	32.7	33.8	33.3	33.2	33.1	30.6	27.1	22.7	(35)
MCDBR			25.8	29.7	33.6	35.8	37.7	37.7	37.1	35.6	36.3	34.7	32.3	27.6	(36)	
MCWBR			16.0	15.9	15.7	15.0	14.3	12.1	10.5	10.5	12.8	15.0	17.4	17.4	(37)	
5% WB		MCD BR	23.0	25.1	30.1	32.3	33.7	34.0	32.8	32.6	32.2	30.1	26.1	22.6	(38)	
		MCWBR	15.1	14.2	14.9	14.2	13.1	11.0	9.5	9.9	11.2	13.9	14.8	15.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.340	0.370	0.416	0.467	0.465	0.394	0.398	0.403	0.392	0.415	0.366	0.348	(40)	
(41)		taud	2.299	2.197	2.046	1.915	1.956	2.189	2.187	2.170	2.199	2.118	2.244	2.283	(41)	
(42)		Ebn at Noon	273	276	271	262	263	282	280	277	275	256	260	262	(42)	
(43)		Edh at Noon	33	41	51	61	59	47	46	47	43	43	35	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	897	1166	1640	2005	2369	2663	2596	2354	1997	1473	1067	833	(44)	
(45)		RadStd	63	91	84	92	108	37	28	55	58	71	62	56	(45)	