

AL NABK, Syrian Arab Republic

WMO: 400830

Lat: 34.033N

Lon: 36.717E

Elev: 4373

StdP: 12.52

Time Zone: 2.00 (SYR)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	27.9	9.0	10.2	44.4	13.2	12.7	43.7	23.6	38.7	20.8	41.2	4.7	180	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	91.0	61.2	88.5	60.5	86.3	60.1	65.8	79.1	64.4	79.0	63.2	78.8	6.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.6	96.6	71.5	59.6	89.7	71.3	57.6	83.5	70.4	33.2	78.4	32.0	79.1	31.0	78.4	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	14.9	12.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	19.0	70.0	3.7	1.7	16.3	71.3	14.1	72.3	12.0	73.2	9.3	74.5	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	39.4	41.7	47.2	55.4	62.7	70.2	74.7	74.9	69.1	61.7	50.3	43.8
	DBStd	13.63	5.67	5.86	6.88	6.49	5.68	4.62	3.80	4.06	4.59	5.52	5.98	5.59
	HDD50	1006	333	242	138	18	1	0	0	0	15	132	442	206
	HDD65	3670	795	653	555	298	113	9	0	0	15	132	442	658
	CDD50	3805	3	9	50	179	393	606	767	773	572	365	75	13
	CDD65	992	0	0	2	8	40	166	302	308	136	30	0	0
	CDH74	9387	0	0	13	70	364	1577	3030	3007	1121	203	2	0
	CDH80	3050	0	0	0	11	49	417	1123	1173	262	15	0	0
(14) Wind	WSAvg	4.2	4.6	4.7	5.1	5.3	4.4	4.5	4.4	3.4	3.7	3.3	3.9	3.6
(15) Precipitation	PrecAvg	10.0	1.9	1.7	1.4	0.7	0.5	0.1	0.1	0.0	0.1	0.7	1.3	1.5
	PrecMax	16.1	3.3	4.3	4.4	2.3	2.6	0.7	2.2	0.5	0.6	2.8	4.1	3.5
	PrecMin	5.6	0.7	0.5	0.4	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	2.7	0.7	1.0	0.9	0.5	0.7	0.2	0.4	0.1	0.2	0.7	0.9	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.0	64.9	75.3	81.3	84.4	90.0	95.4	94.4	89.7	81.8	72.6	66.7
		MCWB	43.8	49.3	51.0	53.1	56.4	59.1	62.3	61.6	60.2	55.8	50.6	46.1
	2%	DB	54.5	57.8	69.0	74.9	80.8	87.0	91.2	91.2	85.7	79.1	67.6	60.3
		MCWB	42.6	43.9	48.6	51.4	55.1	58.4	61.4	61.6	59.2	55.6	49.6	44.9
	5%	DB	50.9	54.2	63.8	71.4	78.2	84.6	88.6	88.6	82.8	75.9	63.8	55.7
		MCWB	41.3	42.5	46.5	50.5	54.5	58.2	60.9	60.7	58.5	55.0	48.7	43.6
	10%	DB	47.8	50.9	59.6	68.0	75.3	82.4	86.3	86.1	80.5	72.8	60.6	52.1
		MCWB	40.0	41.2	45.0	49.4	54.0	57.8	60.4	60.7	57.7	54.6	47.9	42.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	48.9	52.7	55.9	60.4	64.0	68.2	68.1	65.1	60.1	54.2	49.2
		MCDB	54.6	60.7	69.1	70.4	74.1	77.5	83.1	81.8	76.6	71.0	63.8	59.3
	2%	WB	44.1	45.7	49.9	54.0	58.4	62.0	65.8	66.1	63.5	58.5	52.1	47.2
		MCDB	51.6	55.5	63.4	69.1	71.3	76.9	80.0	78.6	75.5	70.3	61.8	55.2
	5%	WB	42.3	43.6	48.3	52.3	57.1	60.8	64.4	64.6	62.1	57.3	50.4	45.6
		MCDB	49.1	51.8	61.4	67.5	71.4	77.7	80.1	78.9	75.0	69.7	60.4	53.0
	10%	WB	41.0	41.9	46.5	50.8	55.8	59.5	63.0	63.4	60.7	56.1	49.0	44.0
		MCDB	46.6	49.2	57.5	65.0	70.6	77.1	80.3	79.1	75.2	69.0	58.7	50.7
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	14.9	17.0	19.5	21.5	23.0	22.9	23.4	22.3	19.6	17.2	15.7
		MCDBR	18.1	18.1	20.6	22.4	23.5	24.1	24.2	24.3	24.1	22.3	21.1	19.6
		MCWBR	10.5	10.4	9.9	10.0	10.1	10.7	11.3	11.0	11.4	10.0	10.9	11.5
	5% WB	MCDBR	15.8	16.5	19.3	21.1	21.4	23.6	23.1	23.3	22.7	20.2	18.2	16.4
		MCWBR	10.1	10.8	10.9	10.3	10.8	11.9	13.2	13.1	12.5	10.6	10.6	10.8
(40) Clear-Sky Solar Irradiance	taub		0.300	0.323	0.363	0.409	0.407	0.353	0.354	0.361	0.352	0.369	0.324	0.307
	taud		2.354	2.278	2.148	2.016	2.063	2.245	2.249	2.224	2.253	2.194	2.315	2.347
	Ebn at Noon		288	292	287	278	279	293	293	289	288	271	276	278
	Edh at Noon		30	37	46	55	53	44	44	44	41	40	32	29
(44) All-Sky Solar Radiation	RadAvg		840	1110	1583	1958	2319	2628	2570	2331	1959	1437	1030	784
	RadStd		57	96	87	101	126	44	35	52	65	70	69	56

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+0.54	N/A	-2.39	N/A	N/A	N/A	N/A	N/A	N/A	+311	+198

Nomenclature: See separate page