

ZEFAT HAR KENAN, Israel

WMO: 401530

Lat: 32.9800N

Lon: 35.5070E

Elev: 3071

StdP: 13.14

Time Zone: 2.00 (ISR)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.1	35.8	10.3	10.4	50.3	15.1	13.3	53.5	39.8	41.7	35.4	41.0	13.6	300	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	91.6	64.9	88.6	65.1	86.4	65.3	71.6	84.5	70.1	82.8	68.8	81.3	9.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	113.0	78.4	66.0	107.6	76.2	64.7	102.5	75.1	37.5	84.5	36.1	82.6	35.0	81.7	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	23.1	20.6	DB	30.7	96.5	3.1	2.8	28.5	98.5	26.7	100.1	24.9	101.6	22.7	103.6	(4)
(5)			WB	27.6	74.6	3.8	1.4	24.9	75.6	22.7	76.4	20.6	77.2	17.8	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.5	45.4	48.2	53.5	60.1	67.3	73.4	76.8	76.8	73.1	67.5	57.7	49.4	(6)
(7)		DBStd	12.53	5.38	6.34	7.04	7.74	7.26	5.67	4.08	3.92	4.35	6.03	6.35	5.37	(7)
(8)		HDD50	376	158	100	37	4	0	0	0	0	0	0	6	71	(8)
(9)		HDD65	2452	607	471	366	188	59	2	0	1	39	236	483		(9)
(10)		CDD50	4944	16	49	145	309	538	702	830	829	693	542	237	54	(10)
(11)		CDD65	1543	0	0	9	42	132	254	365	364	244	116	17	0	(11)
(12)		CDH74	10590	0	0	23	191	925	2063	2899	2646	1346	483	14	0	(12)
(13)		CDH80	3333	0	0	3	34	265	694	1021	893	337	86	0	0	(13)
(14)	Wind	WSAvg	10.9	12.6	12.4	11.5	10.5	10.4	11.0	10.9	10.4	9.7	8.8	10.5	11.8	(14)
(15)	Precipitation	PrecAvg	27.2	6.8	4.9	3.9	1.6	0.3	0.0	0.0	0.0	1.1	3.1	5.7		(15)
(16)		PrecMax	37.4	18.7	11.7	7.2	9.4	1.6	0.0	0.2	0.1	1.1	2.9	11.1	13.6	(16)
(17)		PrecMin	16.0	2.6	1.0	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.7	(17)
(18)		PrecStd	6.1	3.5	2.9	1.8	1.8	0.4	0.0	0.0	0.0	0.2	0.9	2.5	3.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.5	68.0	77.1	83.9	91.2	93.4	95.0	96.1	90.3	86.4	75.9	65.6	(19)
(20)			MCWB	47.8	51.8	55.0	56.2	60.7	63.9	69.3	66.8	64.2	59.9	54.1	46.9	(20)
(21)		2%	DB	57.2	63.9	71.5	78.8	86.4	90.2	90.8	89.9	86.4	82.4	72.7	62.3	(21)
(22)			MCWB	46.3	49.4	51.8	54.8	59.6	64.1	66.2	67.5	65.2	59.9	53.3	46.6	(22)
(23)		5%	DB	54.5	60.6	68.1	75.3	82.6	87.0	87.7	87.0	83.8	79.2	69.6	59.3	(23)
(24)			MCWB	45.8	47.0	51.6	54.7	58.9	63.4	66.9	67.2	65.4	59.1	51.6	46.8	(24)
(25)		10%	DB	52.1	57.3	64.6	72.0	79.2	83.9	85.5	84.7	81.2	76.2	66.8	56.3	(25)
(26)			MCWB	44.8	45.9	49.4	53.4	58.1	62.7	66.5	67.5	65.0	58.8	50.7	46.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	54.0	57.8	60.7	65.1	70.5	73.2	74.4	72.7	67.5	58.8	54.2	(27)
(28)			MCDWB	55.5	63.7	70.8	73.8	80.3	86.6	88.3	87.5	84.0	76.1	66.7	58.1	(28)
(29)		2%	WB	49.3	50.9	54.9	58.2	62.7	68.0	71.1	71.8	70.3	64.5	57.0	52.1	(29)
(30)			MCDWB	53.3	60.1	66.8	72.3	80.0	83.6	85.1	84.1	81.5	73.9	63.7	55.8	(30)
(31)		5%	WB	47.8	49.1	52.9	56.5	61.1	66.2	69.5	70.3	68.4	62.9	55.6	50.6	(31)
(32)			MCDWB	51.6	56.3	63.9	71.6	78.1	81.7	83.5	82.4	78.5	71.8	62.7	54.0	(32)
(33)		10%	WB	46.5	47.6	51.0	54.7	59.4	64.6	68.2	69.0	66.9	61.4	54.1	49.3	(33)
(34)			MCDWB	50.3	53.7	61.0	69.4	75.7	79.5	82.1	80.9	76.3	70.0	61.0	52.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	9.4	12.3	14.9	17.1	18.2	17.8	17.1	16.2	13.4	9.5	7.4	(35)
(36)			MCDBR	10.3	13.0	15.1	17.1	18.6	19.6	18.1	17.7	17.5	15.4	11.4	9.2	(36)
(37)			MCWBR	7.5	9.0	10.3	10.6	10.9	12.6	14.4	13.0	11.9	9.6	6.6	6.0	(37)
(38)		5% WB	MCDBR	9.1	11.3	14.8	16.9	17.8	18.5	18.2	17.3	16.6	14.5	10.4	7.4	(38)
(39)			MCWBR	7.2	8.2	11.0	11.9	12.2	13.6	14.4	13.2	11.4	9.9	7.3	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.351	0.383	0.419	0.416	0.361	0.372	0.377	0.366	0.378	0.343	0.331	(40)	
(41)		taud	2.415	2.326	2.215	2.114	2.160	2.361	2.341	2.328	2.367	2.316	2.410	2.422	(41)	
(42)		Ebn at Noon	281	284	283	276	277	292	288	285	285	271	272	272	(42)	
(43)		Edh at Noon	30	36	43	50	48	39	40	40	36	36	30	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	862	1109	1569	1963	2331	2593	2528	2305	1942	1446	1057	814	(44)	
(45)		RadStd	72	114	110	127	105	46	30	41	52	70	62	69	(45)	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (17 neighbors)	+0.79	N/A	-3.46	N/A	N/A	N/A	-126	+288	+193	(47)

Nomenclature: See separate page