

ZEFAT HAR KENAN, Israel

WMO: 401530

Lat: 32.9800N

Lon: 35.5070E

Elev: 936

StdP: 90.57

Time Zone: 2.00 (ISR)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.6	2.1	-12.1	1.5	10.2	-9.4	1.9	11.9	17.8	5.4	15.8	5.0	6.1	300	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	33.1	18.3	31.5	18.4	30.2	18.5	22.0	29.2	21.2	28.2	20.5	27.4	4.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	16.1	25.8	18.9	15.4	24.6	18.1	14.6	23.9	69.3	29.2	66.2	28.1	63.5	27.6	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.3	9.2	DB	-0.7	35.8	1.7	1.5	-2.0	36.9	-3.0	37.8	-3.9	38.7	-5.2	39.8	(4)
(5)			WB	-2.5	23.6	2.1	0.8	-4.0	24.2	-5.2	24.7	-6.4	25.1	-7.9	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	7.4	9.0	11.9	15.6	19.6	23.0	24.9	24.9	22.8	19.7	14.3	9.7	(6)
(7)		DBStd	6.96	2.99	3.52	3.91	4.30	4.03	3.15	2.26	2.18	2.42	3.35	3.53	2.98	(7)
(8)		HDD10.0	209	88	56	21	2	0	0	0	0	0	0	3	39	(8)
(9)		HDD18.3	1362	337	262	203	104	33	1	0	0	1	22	131	268	(9)
(10)		CDD10.0	2747	9	27	81	172	299	390	461	461	385	301	132	30	(10)
(11)		CDD18.3	857	0	0	5	23	73	141	203	202	136	64	9	0	(11)
(12)		CDH23.3	5883	0	0	13	106	514	1146	1611	1470	748	268	8	0	(12)
(13)		CDH26.7	1852	0	0	2	19	147	386	567	496	187	48	0	0	(13)
(14)	Wind	WSAvg	4.9	5.6	5.5	5.2	4.7	4.9	4.9	4.6	4.3	3.9	4.7	5.3	(14)	
(15)	Precipitation	PrecAvg	690	172	124	99	40	8	0	0	1	28	78	145	(15)	
(16)		PrecMax	951	476	297	182	239	40	1	6	2	28	73	283	346	(16)
(17)		PrecMin	406	66	25	16	0	0	0	0	0	0	4	17	(17)	
(18)		PrecStd	156	88	74	46	45	11	0	1	0	5	22	63	93	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	20.0	25.1	28.9	32.9	34.1	35.0	32.4	30.2	24.4	18.7	(19)	
(20)			MCWB	8.8	11.0	12.8	13.4	15.9	17.7	20.7	19.4	17.9	15.5	12.3	8.3	(20)
(21)		2%	DB	14.0	17.7	22.0	26.0	30.2	32.3	32.7	32.2	30.2	28.0	22.6	16.8	(21)
(22)			MCWB	8.0	9.7	11.0	12.7	15.3	17.8	19.0	19.7	18.4	15.5	11.9	8.1	(22)
(23)		5%	DB	12.5	15.9	20.1	24.1	28.1	30.6	30.9	30.6	28.8	26.2	20.9	15.2	(23)
(24)			MCWB	7.7	8.3	10.9	12.6	14.9	17.4	19.4	19.5	18.5	15.1	10.9	8.2	(24)
(25)		10%	DB	11.2	14.0	18.1	22.2	26.2	28.8	29.7	29.3	27.3	24.6	19.3	13.5	(25)
(26)			MCWB	7.1	7.7	9.7	11.9	14.5	17.1	19.2	19.7	18.4	14.9	10.4	8.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	12.2	14.3	16.0	18.4	21.4	22.9	23.5	22.6	19.7	14.9	12.3	(27)
(28)			MCDWB	13.1	17.6	21.6	23.2	26.8	30.3	31.3	30.9	28.9	24.5	19.3	14.5	(28)
(29)		2%	WB	9.6	10.5	12.7	14.6	17.1	20.0	21.7	22.1	21.3	18.0	13.9	11.2	(29)
(30)			MCDWB	11.8	15.6	19.3	22.4	26.7	28.7	29.5	29.0	27.5	23.3	17.6	13.2	(30)
(31)		5%	WB	8.8	9.5	11.6	13.6	16.2	19.0	20.9	21.3	20.2	17.2	13.1	10.3	(31)
(32)			MCDWB	10.9	13.5	17.7	22.0	25.6	27.6	28.6	28.0	25.9	22.1	17.1	12.2	(32)
(33)		10%	WB	8.1	8.7	10.6	12.6	15.2	18.1	20.1	20.6	19.4	16.4	12.3	9.6	(33)
(34)			MCDWB	10.1	12.1	16.1	20.8	24.3	26.4	27.8	27.2	24.6	21.1	16.1	11.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	6.8	8.3	9.5	10.1	9.9	9.5	9.0	7.4	5.3	4.1	(35)
(36)			MCDBR	5.7	7.2	8.4	9.5	10.4	10.9	10.1	9.8	9.7	8.5	6.4	5.1	(36)
(37)			MCWBR	4.2	5.0	5.7	5.9	6.1	7.0	8.0	7.2	6.6	5.3	3.7	3.4	(37)
(38)		5% WB	MCDWB	5.1	6.3	8.2	9.4	9.9	10.3	10.1	9.6	9.2	8.1	5.8	4.1	(38)
(39)			MCWBR	4.0	4.6	6.1	6.6	6.8	7.5	8.0	7.3	6.3	5.5	4.0	3.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.351	0.383	0.419	0.416	0.361	0.372	0.377	0.366	0.378	0.343	0.331	(40)	
(41)		taud	2.415	2.326	2.215	2.114	2.160	2.361	2.341	2.328	2.367	2.316	2.410	2.422	(41)	
(42)		Ebn at Noon	885	896	891	871	874	919	907	900	898	854	859	859	(42)	
(43)		Edh at Noon	93	113	136	157	152	124	126	125	115	113	93	88	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.72	3.50	4.95	6.19	7.35	8.17	7.97	7.26	6.12	4.56	3.33	2.57	(44)	
(45)		RadStd	0.23	0.36	0.35	0.40	0.33	0.15	0.10	0.13	0.16	0.22	0.19	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.44	N/A	-1.92	N/A	N/A	N/A	N/A	-70	+160	+107

Nomenclature: See separate page