

TEL AVIV SDE DOV, Israel

WMO: 401762

Lat: 32.114N

Lon: 34.782E

Elev: 43

StdP: 14.67

Time Zone: 2.00 (ISR)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.3	49.1	29.2	23.3	63.7	33.6	28.2	61.0	32.7	58.6	30.1	58.7	6.6	100	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	88.2	75.9	86.9	76.1	86.0	75.8	80.3	85.2	79.1	84.6	78.1	84.0	11.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.3	84.3	77.3	142.4	83.6	76.2	137.1	83.1	44.1	85.2	42.8	84.7	41.7	84.3	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	21.1	18.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.5	57.4	57.7	60.6	65.6	71.0	76.4	80.4	81.7	79.8	75.0	67.8	60.2
	DBStd	9.40	3.36	3.28	4.39	5.23	3.66	2.41	1.60	1.57	2.15	3.92	3.79	3.62
	HDD50	2	1	1	0	0	0	0	0	0	0	0	0	0
	HDD65	809	236	206	154	44	1	0	0	0	0	1	14	153
	CDD50	7133	232	217	327	469	652	793	943	983	893	774	533	317
	CDD65	2463	1	2	16	63	188	343	478	518	443	309	97	5
	CDH74	21669	7	12	108	379	602	2387	5121	5989	4620	2100	335	9
	CDH80	5326	1	2	33	165	109	290	1291	1908	1176	311	40	0
Wind	WSAvg	8.6	8.8	9.9	9.3	9.2	8.5	8.5	8.3	7.9	8.3	8.3	8.3	8.1
Precipitation	PrecAvg	21.6	6.0	3.8	2.1	0.7	0.2	0.0	0.0	0.0	0.0	0.9	3.0	5.0
	PrecMax	40.5	14.9	11.3	6.1	3.9	1.3	0.2	0.0	0.0	0.4	4.9	14.3	15.7
	PrecMin	10.4	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.5
	PrecStd	7.5	3.0	2.4	1.9	0.9	0.2	0.0	0.0	0.0	0.1	1.3	3.2	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.1	74.8	86.1	95.2	90.1	86.3	88.4	88.8	89.2	89.9	85.3	75.1
		MCWB	57.4	56.1	60.7	64.6	68.1	73.6	78.9	78.4	77.4	69.1	61.4	60.3
	2%	DB	68.3	68.5	77.0	83.8	82.4	84.3	86.5	87.7	87.0	85.6	80.5	71.6
		MCWB	57.1	57.9	58.9	63.0	67.1	74.2	77.8	78.3	75.8	72.3	63.2	59.7
	5%	DB	66.3	65.8	70.5	76.8	78.9	82.7	85.8	86.7	85.9	82.9	77.7	69.3
		MCWB	58.0	57.4	60.0	62.6	68.6	74.1	77.4	77.4	75.2	72.6	65.2	59.5
	10%	DB	64.4	63.9	67.1	72.5	77.0	81.6	84.6	86.0	84.8	81.2	75.6	67.4
		MCWB	57.1	56.6	60.1	63.4	68.6	73.6	76.5	76.9	74.6	72.1	64.6	58.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.7	62.8	65.7	68.0	73.5	78.2	82.2	82.7	79.9	78.1	72.6	64.7
		MCDB	67.4	69.0	70.1	74.5	78.4	83.5	85.8	86.9	85.5	81.8	78.3	70.7
	2%	WB	61.0	60.4	64.3	66.5	71.8	76.7	80.2	80.7	78.5	76.8	70.3	62.8
		MCDB	65.3	65.2	69.7	74.2	77.4	81.7	85.0	85.5	84.6	81.6	76.4	68.3
	5%	WB	59.2	59.2	62.7	65.4	70.6	75.5	78.9	79.4	77.3	75.3	68.4	61.1
		MCDB	64.4	63.9	67.4	73.3	76.3	81.0	84.1	84.9	84.0	80.7	74.7	67.1
	10%	WB	57.5	57.7	61.2	64.2	69.6	74.6	77.9	78.3	76.3	73.6	66.5	59.8
		MCDB	62.9	62.8	66.3	72.0	75.2	80.3	83.4	84.5	83.2	80.0	73.5	66.1
Mean Daily Temperature Range	5% DB	MDBR	11.6	11.5	11.2	11.6	10.7	9.3	8.8	9.2	10.3	11.2	13.1	11.9
		MCDBR	14.7	15.6	18.2	22.1	15.3	10.9	9.6	9.7	11.5	13.1	16.7	15.1
		MCWBR	10.2	10.6	9.8	9.3	8.8	6.8	5.8	5.7	7.4	8.2	10.6	10.0
	5% WB	MCDBR	12.4	12.9	12.3	15.0	11.9	10.1	8.7	9.0	11.2	11.0	13.0	12.1
		MCWBR	10.4	10.5	8.6	8.9	8.0	7.0	6.2	6.8	9.1	8.6	11.4	9.8
Clear-Sky Solar Irradiance	taub	0.388	0.421	0.463	0.496	0.491	0.425	0.439	0.446	0.435	0.447	0.400	0.383	
	taud	2.265	2.154	2.033	1.965	2.014	2.252	2.222	2.206	2.237	2.182	2.286	2.306	
	Ebn at Noon	259	261	259	255	257	273	269	266	264	249	252	253	
	Edh at Noon	35	43	52	58	56	44	45	45	42	41	34	32	
All-Sky Solar Radiation	RadAvg	937	1207	1657	2026	2348	2567	2493	2274	1942	1468	1091	870	
	RadStd	58	90	93	88	93	39	27	36	48	63	55	54	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.83	N/A	-4.45	N/A	N/A	N/A	N/A	-139	+274	+185

Nomenclature: See separate page