

BET DAGAN, IsraelWMO: **401790**Lat: **32.0073N**Lon: **34.8138E**Elev: **102**StdP: **14.64**Time Zone: **2.00 (ISR)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	41.5	44.2	22.8	17.2	67.6	29.7	23.9	63.5	25.5	56.2	22.7	57.1	3.9	110	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.3	93.6	70.3	91.1	73.7	89.7	74.6	78.8	88.4	77.8	87.6	77.0	86.9	9.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.8	135.2	85.7	74.7	130.2	85.0	73.7	126.1	84.4	42.4	88.6	41.4	87.6	40.6	87.0	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.2	14.9	12.9	DB	37.0	102.2	3.3	3.3	34.6	104.5	32.6	106.4	30.8	108.3	28.4	110.6
			WB	34.7	79.6	4.0	1.6	31.9	80.8	29.6	81.7	27.3	82.6	24.4	83.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.8	55.8	57.9	62.3	66.7	72.3	77.6	81.3	82.7	79.9	74.5	66.9	59.4
	DBStd	9.96	3.95	4.56	5.12	5.00	4.55	2.78	2.02	1.51	2.36	3.62	4.59	4.33
	HDD50	10	7	1	0	0	0	0	0	0	0	0	0	2
	HDD65	852	287	204	118	32	1	0	0	0	0	0	30	180
	CDD50	7244	185	222	382	500	690	827	969	1014	897	760	506	292
	CDD65	2614	0	6	35	82	226	377	504	549	447	296	86	6
	CDH74	27655	5	77	409	841	1848	3664	5870	6838	4952	2505	588	58
(13)	CDH80	10359	0	15	160	327	608	1216	2397	2988	1848	675	121	4
(14)	Wind	WSAvg	6.0	6.4	6.3	6.3	6.2	6.1	6.2	6.0	5.8	5.5	5.1	6.0
(15) Precipitation	PrecAvg	21.7	5.9	3.5	2.6	0.7	0.1	0.0	0.0	0.0	0.0	1.1	2.7	5.4
	PrecMax	40.6	18.7	10.7	5.4	3.9	0.9	0.0	0.0	0.0	0.1	4.6	12.9	15.2
	PrecMin	13.0	2.6	0.7	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	6.7	3.4	2.3	1.4	0.7	0.2	0.0	0.0	0.0	0.0	1.1	2.8	3.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.2	81.9	92.3	96.2	99.4	96.7	93.7	94.2	92.2	93.4	88.8	79.9
		MCWB	57.8	60.4	62.0	61.5	65.6	68.4	75.2	77.0	75.5	70.0	62.8	57.6
	2%	DB	69.8	75.4	84.4	88.4	91.4	90.4	90.9	91.5	89.8	88.5	83.3	74.8
		MCWB	56.5	57.7	61.3	61.8	65.0	70.6	76.7	77.5	75.7	70.0	64.1	58.4
	5%	DB	67.2	70.8	77.7	82.5	86.3	87.7	89.6	90.3	88.5	85.4	79.9	71.1
		MCWB	56.1	57.0	59.6	61.3	65.5	72.8	76.1	76.8	74.9	70.7	63.8	58.1
	10%	DB	65.0	67.4	73.0	78.1	82.4	86.0	88.4	89.4	87.3	83.6	77.0	68.5
		MCWB	55.2	56.7	59.6	61.4	66.2	72.3	75.5	76.3	74.2	70.5	63.2	57.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.3	64.1	67.4	67.2	71.9	76.7	79.6	80.4	80.0	76.7	71.4	64.7
		MCDB	68.6	72.3	81.8	79.5	83.4	86.9	89.3	89.9	88.0	84.2	79.1	71.9
	2%	WB	59.1	61.0	64.1	65.7	70.4	75.5	78.2	79.1	77.9	74.6	69.1	62.0
		MCDB	66.7	69.9	74.2	76.6	80.9	85.4	88.0	89.0	87.0	83.5	77.3	69.9
	5%	WB	57.6	59.4	62.3	64.6	69.2	74.5	77.2	78.1	76.7	73.1	67.0	60.2
		MCDB	64.7	67.6	71.7	75.0	79.3	84.1	87.3	88.1	86.1	82.5	75.4	67.6
	10%	WB	56.2	57.9	60.8	63.4	68.1	73.5	76.4	77.3	75.6	71.8	65.0	58.8
		MCDB	62.9	65.9	70.7	74.1	78.2	83.0	86.5	87.3	85.2	81.3	73.8	66.0
(35) Mean Daily Temperature Range	5% DB	MDBR	16.9	18.3	18.6	19.3	17.7	15.9	14.5	14.3	15.3	17.8	19.3	17.8
		MCDBR	21.9	25.2	28.7	29.2	26.4	19.3	15.7	15.1	16.0	20.5	23.4	22.4
		MCWBR	11.4	11.4	11.2	10.2	9.3	7.5	6.5	5.8	6.8	9.7	10.9	10.8
	5% WB	MCDBR	18.5	20.1	21.4	20.8	17.6	15.3	15.0	14.2	15.0	17.6	18.9	17.2
		MCWBR	11.1	11.0	10.5	9.7	8.7	6.6	6.5	5.6	7.1	9.3	11.5	10.2
(40) Clear-Sky Solar Irradiance	taub		0.387	0.421	0.464	0.498	0.494	0.426	0.439	0.446	0.437	0.449	0.401	0.383
	taud		2.256	2.144	2.020	1.951	1.998	2.236	2.210	2.194	2.221	2.165	2.274	2.296
	Ebn at Noon		259	261	258	255	256	273	269	266	264	249	252	253
	Edh at Noon		36	43	53	59	57	45	46	46	43	42	35	33
(44) All-Sky Solar Radiation	RadAvg		944	1212	1659	2028	2348	2570	2496	2281	1946	1473	1097	878
	RadStd		58	89	94	87	92	38	28	35	48	62	56	53

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.83	N/A	-4.45	N/A	N/A	N/A	N/A	-139	+274	+185

Nomenclature: See separate page