

BET DAGAN, IsraelWMO: **401790**Lat: **32.0073N**Lon: **34.8138E**Elev: **31**StdP: **100.95**Time Zone: **2.00 (ISR)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.3	6.8	-5.1	2.5	19.8	-1.3	3.4	17.5	11.4	13.4	10.2	14.0	1.7	110	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	34.2	21.3	32.8	23.2	32.1	23.7	26.0	31.4	25.5	30.9	25.0	30.5	4.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	19.3	29.8	23.7	18.6	29.5	23.2	18.0	29.1	80.7	31.4	78.4	30.9	76.6	30.6	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.2	6.6	5.8	2.8	39.0	1.8	1.8	1.4	40.3	0.4	41.3	-0.7	42.4	-2.0	43.7
			1.5	26.5	2.2	0.9	-0.1	27.1	-1.4	27.6	-2.6	28.1	-4.2	28.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	13.2	14.4	16.8	19.3	22.4	25.3	27.4	28.2	26.6	23.6	19.4	15.2
	DBStd	5.53	2.19	2.53	2.85	2.78	2.53	1.54	1.12	0.84	1.31	2.01	2.55	2.41
	HDD10.0	6	4	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	473	159	113	66	18	1	0	0	0	0	0	17	100
	CDD10.0	4024	103	123	212	278	383	459	538	563	498	422	281	162
	CDD18.3	1452	0	3	19	46	126	209	280	305	248	164	48	3
	CDH23.3	15364	3	43	227	467	1027	2036	3261	3799	2751	1392	327	32
(13)	CDH26.7	5755	0	8	89	182	338	676	1332	1660	1027	375	67	2
(14) Wind	WSAvg	2.7	2.9	2.8	2.8	2.8	2.8	2.7	2.8	2.7	2.6	2.4	2.3	2.7
(15) Precipitation	PrecAvg	552	149	90	66	17	2	0	0	0	0	29	69	138
	PrecMax	1031	475	273	137	100	22	0	0	1	2	116	328	385
	PrecMin	329	65	18	9	0	0	0	0	0	0	0	0	10
	PrecStd	170	86	58	36	19	4	0	0	0	1	29	71	95
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.4	27.7	33.5	35.6	37.5	36.0	34.3	34.6	33.4	34.1	31.6	26.6
		MCWB	14.3	15.8	16.7	16.4	18.7	20.2	24.0	25.0	24.2	21.1	17.1	14.2
	2%	DB	21.0	24.1	29.1	31.3	33.0	32.4	32.7	33.1	32.1	31.4	28.5	23.8
		MCWB	13.6	14.3	16.3	16.5	18.4	21.4	24.8	25.3	24.3	21.1	17.8	14.7
	5%	DB	19.6	21.5	25.4	28.1	30.2	31.0	32.0	32.4	31.4	29.6	26.6	21.7
		MCWB	13.4	13.9	15.3	16.3	18.6	22.7	24.5	24.9	23.9	21.5	17.7	14.5
	10%	DB	18.3	19.7	22.8	25.6	28.0	30.0	31.3	31.9	30.7	28.6	25.0	20.3
		MCWB	12.9	13.7	15.3	16.4	19.0	22.4	24.2	24.6	23.4	21.4	17.3	14.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	17.8	19.7	19.5	22.2	24.8	26.4	26.9	26.7	24.9	21.9	18.2
		MCDB	20.4	22.4	27.7	26.4	28.6	30.5	31.8	32.2	31.1	29.0	26.2	22.2
	2%	WB	15.1	16.1	17.8	18.7	21.3	24.2	25.7	26.1	25.5	23.6	20.6	16.7
		MCDB	19.3	21.0	23.4	24.8	27.2	29.6	31.1	31.7	30.6	28.6	25.2	21.1
	5%	WB	14.2	15.2	16.8	18.1	20.7	23.6	25.1	25.6	24.8	22.9	19.4	15.7
		MCDB	18.2	19.8	22.1	23.9	26.3	29.0	30.7	31.2	30.0	28.1	24.1	19.8
	10%	WB	13.5	14.4	16.0	17.4	20.1	23.1	24.7	25.2	24.2	22.1	18.3	14.9
		MCDB	17.2	18.8	21.5	23.4	25.7	28.3	30.3	30.7	29.5	27.4	23.2	18.9
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.2	10.3	10.7	9.9	8.9	8.1	7.9	8.5	9.9	10.7	9.9
		MCDBR	12.1	14.0	15.9	16.2	14.7	10.7	8.7	8.4	8.9	11.4	13.0	12.4
		MCWBR	6.3	6.4	6.2	5.7	5.2	4.2	3.6	3.2	3.8	5.4	6.1	6.0
	5% WB	MCDBR	10.3	11.2	11.9	11.6	9.8	8.5	8.3	7.9	8.3	9.8	10.5	9.6
		MCWBR	6.2	6.1	5.9	5.4	4.8	3.6	3.6	3.1	4.0	5.2	6.4	5.7
(40) Clear-Sky Solar Irradiance	taub		0.387	0.421	0.464	0.498	0.494	0.426	0.439	0.446	0.437	0.449	0.401	0.383
	taud		2.256	2.144	2.020	1.951	1.998	2.236	2.210	2.194	2.221	2.165	2.274	2.296
	Ebn at Noon		816	822	814	803	808	861	848	838	831	784	795	798
	Edh at Noon		112	137	167	186	179	141	144	144	135	133	109	103
(44) All-Sky Solar Radiation	RadAvg		2.98	3.82	5.23	6.39	7.40	8.10	7.87	7.19	6.13	4.64	3.46	2.77
	RadStd		0.18	0.28	0.30	0.27	0.29	0.12	0.09	0.11	0.15	0.19	0.17	0.17

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.46	N/A	-2.47	N/A	N/A	N/A	N/A	N/A	-77	+152	+103

Nomenclature: See separate page