

JERUSALEM CENTER, Israel

WMO: 401830

Lat: 31.7806N

Lon: 35.2217E

Elev: 2657

StdP: 13.34

Time Zone: 2.00 (ISR)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.1	39.8	9.8	10.0	62.6	14.6	12.7	60.9	22.8	44.4	20.5	43.4	9.9	260	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.7	92.5	64.4	90.1	64.5	87.9	64.3	71.5	83.8	70.2	82.0	69.1	80.4	7.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	113.6	75.2	66.9	109.2	74.3	65.8	105.2	73.5	37.1	83.9	35.9	82.3	34.9	80.4	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.5	15.1	13.7	DB	34.4	97.7	2.8	3.1	32.4	99.9	30.7	101.8	29.1	103.5	27.1	105.8	
			WB	31.3	73.7	2.5	1.7	29.5	74.9	28.0	75.9	26.6	76.9	24.8	78.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	50.0	52.2	57.9	64.0	69.8	74.4	77.3	77.9	75.1	70.5	62.1	53.9
	DBStd	11.39	5.83	6.84	8.06	7.81	7.14	5.16	3.76	3.52	4.05	5.76	6.31	5.47
	HDD50	150	68	47	13	1	0	0	0	0	0	0	1	20
	HDD65	1713	465	362	252	115	31	0	0	0	13	129	346	
	CDD50	5806	68	108	259	420	615	731	847	864	754	635	363	142
	CDD65	1895	1	4	33	83	181	282	382	399	304	182	41	3
	CDH74	14419	0	6	198	572	1530	2376	3269	3279	2049	1017	121	2
	CDH80	4789	0	0	40	140	506	827	1181	1192	624	268	11	0
Wind	WSAvg	7.1	6.8	7.0	7.1	7.0	7.4	8.1	8.4	7.9	7.4	6.3	5.8	6.3
Precipitation	PrecAvg	23.2	5.2	4.6	3.7	1.2	0.2	0.0	0.0	0.0	0.0	0.7	2.7	5.3
	PrecMax	45.4	16.6	13.9	9.5	8.7	1.2	1.1	0.0	0.0	0.1	3.2	10.1	18.7
	PrecMin	11.0	0.6	0.7	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
	PrecStd	7.6	3.2	3.1	1.9	1.6	0.3	0.2	0.0	0.0	0.0	0.8	2.3	4.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.8	74.2	84.9	88.5	94.2	94.4	95.0	96.1	92.4	91.1	81.8	72.6
		MCWB	50.9	53.3	57.1	56.2	61.2	62.2	68.0	67.5	65.4	60.4	57.3	50.8
	2%	DB	64.0	70.4	79.4	83.9	89.6	90.9	91.1	90.9	89.0	86.3	77.5	68.1
		MCWB	48.5	50.4	55.0	55.2	59.4	63.2	66.1	68.1	66.1	61.5	55.7	50.4
	5%	DB	60.4	66.5	74.7	80.2	85.7	87.5	88.4	88.2	86.2	82.9	74.0	64.6
		MCWB	47.3	48.9	52.6	54.5	58.6	62.2	65.9	67.1	65.8	60.7	54.5	48.0
	10%	DB	58.0	62.7	70.8	76.7	82.3	84.7	86.0	86.1	83.6	79.8	71.0	61.5
		MCWB	46.4	47.5	51.5	54.1	57.8	62.2	65.6	67.0	65.0	60.2	54.1	48.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	56.2	60.1	61.0	65.6	69.9	73.1	73.8	72.7	68.9	62.6	56.6
		MCDB	61.7	70.1	78.4	75.0	83.5	85.7	86.4	88.4	84.2	78.2	74.0	65.4
	2%	WB	51.3	52.8	57.1	58.6	63.0	67.8	70.8	71.7	70.5	66.6	59.6	54.4
		MCDB	58.4	63.4	72.0	73.0	79.7	82.5	83.7	84.3	81.2	76.6	69.3	61.4
	5%	WB	49.8	51.1	54.8	57.0	61.6	66.2	69.3	70.5	69.0	64.9	58.0	52.7
		MCDB	56.2	61.0	68.9	73.4	78.1	79.9	81.8	82.3	79.2	74.1	67.0	58.4
	10%	WB	48.6	49.6	53.1	55.7	60.1	64.8	68.2	69.4	67.7	63.5	56.7	51.2
		MCDB	54.7	59.1	66.8	72.3	76.5	78.1	80.2	80.4	77.5	72.3	65.3	56.5
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.9	13.4	15.7	16.5	16.9	17.0	16.7	16.2	13.9	11.2	9.5
		MCDBR	13.4	15.3	17.6	18.9	19.3	19.3	18.5	17.8	18.4	16.5	14.3	12.9
		MCWBR	7.6	8.1	8.8	9.4	9.5	11.1	11.7	10.5	10.9	8.5	7.3	6.9
	5% WB	MCDBR	11.4	13.5	15.9	17.5	17.6	17.8	18.2	17.9	17.5	15.4	12.5	10.3
MCWBR		7.1	8.0	9.4	10.4	10.8	10.6	10.6	9.4	9.7	8.4	7.0	6.8	
Clear-Sky Solar Irradiance	taub		0.345	0.374	0.415	0.452	0.449	0.385	0.394	0.401	0.395	0.409	0.362	0.344
	taud		2.303	2.201	2.069	1.977	2.014	2.241	2.224	2.205	2.225	2.169	2.289	2.321
	Ebn at Noon		275	277	273	267	268	285	281	279	276	261	266	268
	Edh at Noon		34	41	50	57	56	44	45	45	43	42	34	31
All-Sky Solar Radiation	RadAvg		968	1226	1669	2043	2368	2613	2547	2338	1990	1512	1131	907
	RadStd		61	88	100	89	93	37	26	29	48	59	56	54

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (18 neighbors)	+0.83	N/A	-3.58	N/A	N/A	N/A	-112	+272	+178

Nomenclature: See separate page