

BEER SHEVA, Israel

WMO: 401900

Lat: 31.2515N

Lon: 34.7995E

Elev: 915

StdP: 14.22

Time Zone: 2.00 (ISR)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 40.6	(c) 42.4	(d) 17.4	(e) 13.7	(f) 67.6	(g) 22.8	(h) 17.8	(i) 67.7	(j) 16.5	(k) 52.4	(l) 15.2	(m) 54.4	(n) 3.5	(o) 110	(p) 0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 21.4	(c) 99.6	(d) 68.0	(e) 96.8	(f) 69.1	(g) 94.6	(h) 69.8	(i) 77.1	(j) 87.8	(k) 75.8	(l) 86.3	(m) 74.7	(n) 85.1	(o) 6.6	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.6	134.0	80.9	73.3	127.9	79.7	72.1	122.7	79.1	41.3	87.8	40.0	86.6	39.0	85.0	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.3	(b) 12.2	(c) 10.7	(e) 37.4	(f) 106.4	(g) 2.5	(h) 2.0	(i) 35.7	(j) 107.8	(k) 34.2	(l) 109.0	(m) 32.8	(n) 110.1	(o) 31.0	(p) 111.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	54.8	57.3	63.0	68.6	74.5	79.7	83.0	83.5	80.2	74.7	66.4	58.3
	DBStd	11.03	4.83	5.79	6.64	6.06	5.29	3.48	2.55	2.56	3.14	4.94	5.19	5.08
	HDD50	21	13	5	0	0	0	0	0	0	0	0	0	3
	HDD65	952	318	227	120	26	1	0	0	0	0	0	41	219
	CDD50	7466	162	209	402	557	760	892	1022	1039	906	764	493	260
	CDD65	2922	2	11	58	132	296	442	557	574	456	300	84	10
	CDH74	29752	25	116	647	1547	3075	4627	6042	6313	4310	2384	586	80
	CDH80	14110	3	23	264	699	1451	2364	3115	3174	1927	931	148	11
Wind	WSAvg	4.1	3.9	4.1	4.1	4.1	4.2	4.1	3.9	4.1	4.1	3.8	4.1	4.2
Precipitation	PrecAvg	7.6	1.9	1.5	1.2	0.4	0.0	0.0	0.0	0.0	0.0	0.2	0.7	1.6
	PrecMax	12.5	7.3	4.5	4.8	2.8	0.4	0.0	0.0	0.0	0.4	1.2	3.2	6.4
	PrecMin	2.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.0	1.6	1.1	0.9	0.6	0.1	0.0	0.0	0.0	0.1	0.4	0.7	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	83.2	95.5	98.9	103.4	102.9	101.2	101.5	97.9	99.8	88.8	81.2
		MCWB	56.8	58.1	61.1	61.6	65.5	66.2	70.3	72.1	70.2	65.6	61.6	55.6
	2%	DB	71.3	77.4	87.2	93.6	97.2	97.4	97.2	97.0	94.2	92.4	84.2	75.7
		MCWB	53.2	56.1	60.3	60.3	64.6	67.7	71.4	73.5	72.0	66.8	62.2	54.6
	5%	DB	67.4	72.1	80.9	87.9	92.4	94.1	95.0	94.6	91.7	88.2	80.6	71.0
		MCWB	52.6	54.7	57.8	60.3	63.8	68.0	72.0	73.1	71.8	68.0	61.1	55.0
	10%	DB	64.3	67.9	75.6	82.9	88.0	91.4	92.8	92.6	89.4	85.0	76.9	67.6
		MCWB	52.1	53.8	56.9	59.0	63.6	68.1	71.6	72.6	71.5	67.3	59.8	54.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	62.0	66.1	65.7	70.4	74.7	77.9	79.6	78.0	75.2	69.3	61.4
		MCDB	67.5	71.5	82.7	80.3	87.4	88.8	89.2	92.0	88.3	84.4	78.1	68.8
	2%	WB	56.8	58.7	62.3	63.8	68.4	73.3	76.0	77.7	76.0	72.8	66.7	59.4
		MCDB	64.8	69.9	76.6	77.8	82.5	85.2	87.8	88.2	86.5	82.9	75.4	67.6
	5%	WB	55.3	57.0	60.3	62.5	67.2	72.1	74.9	76.3	74.7	71.1	64.5	57.7
		MCDB	62.8	67.1	73.3	78.1	80.4	83.7	86.2	86.4	84.1	81.3	73.4	65.2
	10%	WB	53.9	55.6	58.7	61.3	66.0	71.0	73.9	75.2	73.6	69.7	62.6	56.2
		MCDB	61.9	64.3	70.6	76.3	78.8	82.4	84.5	85.4	83.2	79.4	72.2	64.1
Mean Daily Temperature Range	5% DB	MDBR	18.1	19.2	21.6	24.5	24.3	23.6	22.0	21.4	21.4	22.1	20.7	19.2
		MCDBR	24.1	26.6	30.2	33.6	31.7	28.6	24.6	23.2	23.8	25.6	25.2	24.1
		MCWBR	11.0	11.3	11.8	11.5	10.8	8.3	6.8	5.9	7.5	9.1	10.9	11.0
	5% WB	MCDBR	19.2	21.0	24.1	26.1	24.3	23.5	22.0	21.1	20.8	21.3	21.4	18.1
		MCWBR	10.4	10.3	10.9	10.4	8.6	6.7	6.2	5.2	6.7	8.1	10.5	10.1
Clear-Sky Solar Irradiance	taub		0.359	0.392	0.434	0.472	0.470	0.403	0.410	0.416	0.415	0.427	0.375	0.357
	taud		2.248	2.137	2.010	1.920	1.955	2.182	2.178	2.166	2.170	2.123	2.248	2.271
	Ebn at Noon		270	271	268	262	263	280	277	275	270	256	262	264
	Edh at Noon		36	44	54	61	59	47	47	47	45	44	36	33
All-Sky Solar Radiation	RadAvg		1009	1277	1707	2072	2368	2590	2513	2312	1976	1519	1149	942
	RadStd		54	75	90	71	90	32	31	31	48	55	54	47

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		+0.81	N/A	-3.82	N/A	N/A	N/A	N/A	-108	+272	+193

Nomenclature: See separate page