

OVDA, Israel

WMO: 401980

Lat: 29.940N

Lon: 34.936E

Elev: 1492

StdP: 13.92

Time Zone: 2.00 (ISR)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 37.2	(c) 39.2	(d) 12.4	(e) 10.9	(f) 60.2	(g) 17.2	(h) 13.9	(i) 66.7	(j) 24.3	(k) 54.1	(l) 21.0	(m) 55.0	(n) 5.7	(o) 220	(p) 0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 25.8	(c) 101.7	(d) 65.6	(e) 99.6	(f) 65.1	(g) 97.2	(h) 64.7	(i) 71.5	(j) 87.5	(k) 70.2	(l) 86.0	(m) 69.2	(n) 85.1	(o) 10.0	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	103.6	77.1	65.8	100.7	76.4	64.3	95.3	75.9	36.2	87.7	35.0	86.4	34.1	85.2	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.9	(b) 18.0	(c) 15.6	(e) 32.5	(f) 105.9	(g) 3.4	(h) 1.9	(i) 30.1	(j) 107.3	(k) 28.1	(l) 108.4	(m) 26.2	(n) 109.5	(o) 23.7	(p) 110.9		
(4) 20.9	(5) 18.0	(6) 15.6	(7) 32.5	(8) 105.9	(9) 3.4	(10) 1.9	(11) 30.1	(12) 107.3	(13) 28.1	(14) 108.4	(15) 26.2	(16) 109.5	(17) 23.7	(18) 110.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	52.0	54.7	60.7	68.7	76.2	80.9	84.8	84.1	79.7	73.2	62.9	54.2
	DBStd	12.60	4.37	5.40	6.55	6.93	5.63	3.91	2.99	2.88	3.28	4.91	5.24	4.44
	HDD50	48	25	11	1	0	0	0	0	0	0	0	0	11
	HDD65	1344	404	295	172	34	1	0	0	0	0	3	100	335
	CDD50	7136	87	142	331	561	813	926	1078	1057	891	719	388	143
	CDD65	2955	0	6	37	145	349	476	613	592	441	257	38	1
	CDH74	36816	10	79	524	1822	4274	6136	8477	7920	4927	2281	338	28
	CDH80	19605	0	20	169	792	2156	3442	5089	4583	2422	855	73	4
(14) Wind	WSAvg	7.3	6.7	7.2	7.7	8.1	7.9	8.1	7.7	7.5	7.2	6.3	6.6	6.5
(15) Precipitation	PrecAvg	0.8	0.2	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.2
	PrecMax	2.1	0.7	0.9	1.1	0.5	0.6	0.0	0.0	0.0	0.1	0.6	0.5	1.4
	PrecMin	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.5	0.2	0.2	0.3	0.1	0.2	0.0	0.0	0.0	0.0	0.2	0.1	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	82.3	91.1	98.6	101.4	103.7	104.2	103.8	100.0	97.2	86.4	77.3
		MCWB	52.9	57.2	57.7	61.8	63.6	65.5	66.1	69.5	64.3	62.3	59.8	53.4
	2%	DB	69.7	75.2	84.4	93.2	97.3	100.2	101.6	100.4	96.5	91.7	81.4	71.9
		MCWB	51.7	53.7	57.2	60.2	62.4	64.1	65.7	66.8	65.8	62.7	58.5	52.8
	5%	DB	65.8	70.2	80.2	89.2	94.5	97.0	99.2	98.4	93.5	88.1	77.4	68.1
		MCWB	50.7	51.8	55.5	58.7	61.6	63.4	65.4	66.2	65.9	63.5	57.5	52.3
	10%	DB	62.6	66.3	75.1	84.2	91.1	94.6	97.1	96.4	91.2	84.4	74.1	64.7
		MCWB	49.3	50.1	53.8	57.3	60.9	63.0	65.0	66.0	65.4	63.2	56.6	50.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	62.3	61.7	66.4	67.5	69.0	73.5	73.7	72.9	69.3	63.3	59.4
		MCDB	66.3	78.0	78.2	87.2	92.6	89.3	92.1	91.7	88.6	82.5	77.6	67.0
	2%	WB	53.7	55.4	58.9	62.1	64.8	67.3	70.7	71.5	70.8	67.6	61.4	55.4
		MCDB	65.8	71.1	80.0	84.7	89.8	87.5	88.6	87.6	85.0	79.7	74.7	66.8
	5%	WB	51.9	53.1	56.6	60.0	63.4	66.0	69.2	70.3	69.5	66.6	60.0	53.7
		MCDB	62.9	66.8	76.6	83.5	87.9	87.2	87.5	86.0	83.2	79.1	72.3	64.4
	10%	WB	50.3	51.1	54.7	58.3	62.1	65.0	68.0	69.4	68.1	65.4	58.5	52.1
		MCDB	60.4	63.0	71.5	80.6	85.5	86.5	86.6	85.1	82.6	78.3	70.4	62.5
(35) Mean Daily Temperature Range	5% DB	MDBR	20.8	21.5	23.1	24.8	26.0	26.4	25.8	24.8	23.1	21.8	21.8	21.7
		MCDBR	26.5	27.9	29.3	30.5	29.7	29.4	27.6	26.6	25.9	26.4	25.6	26.4
		MCWBR	13.7	13.3	12.5	12.2	10.6	9.1	8.7	7.9	8.4	9.8	11.4	14.2
	5% WB	MCDWR	22.0	23.8	26.1	26.6	26.8	26.5	25.6	24.4	23.2	21.9	21.7	21.7
		MCWBR	12.5	12.1	11.7	11.6	10.0	8.4	8.4	7.5	7.9	8.2	9.9	12.7
(40) Clear-Sky Solar Irradiance	taub		0.342	0.379	0.432	0.459	0.463	0.391	0.395	0.402	0.402	0.408	0.352	0.328
	taud		2.267	2.137	1.959	1.912	1.934	2.176	2.189	2.176	2.172	2.134	2.286	2.338
	Ebn at Noon		279	278	269	266	265	283	282	279	276	264	273	279
	Edh at Noon		36	44	57	62	61	48	47	47	45	44	35	32
(44) All-Sky Solar Radiation	RadAvg		1172	1469	1896	2226	2469	2683	2590	2397	2089	1664	1307	1104
	RadStd		48	56	69	54	83	28	40	34	48	52	41	38

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.76	N/A	-3.13	N/A	N/A	N/A	N/A	N/A	N/A	+243	+263

Nomenclature: See separate page