

KING HUSSEIN AB, Jordan

WMO: 402650

Lat: 32.356N

Lon: 36.259E

Elev: 683

StdP: 93.39

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.2	1.5	-11.7	1.5	11.4	-8.5	2.0	13.1	12.5	9.0	10.3	9.1	0.9	280	0.421

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.7	36.8	19.1	35.2	18.8	33.8	18.5	22.6	29.4	21.8	28.8	21.1	27.9	3.9	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	17.1	24.3	20.1	16.1	23.6	19.2	15.2	23.2	70.5	29.0	67.3	28.8	64.5	27.9	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	8.2	7.1	-2.5	40.2	1.9	1.5	-3.9	41.3	-5.0	42.2	-6.0	43.1	-7.4	44.2		
			-3.9	24.0	2.2	1.4	-5.5	25.0	-6.8	25.8	-8.0	26.6	-9.7	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	8.0	9.7	13.0	16.8	21.4	23.9	25.6	25.9	24.0	20.4	14.2	9.6
	DBStd	7.04	2.49	2.82	3.63	4.19	3.77	2.54	1.98	1.98	2.33	3.15	3.20	2.70
	HDD10.0	162	71	35	10	2	0	0	0	0	0	5	38	
	HDD18.3	1237	322	242	170	79	12	0	0	0	14	128	270	
	CDD10.0	2993	8	27	104	205	353	417	484	493	421	322	132	27
	CDD18.3	1027	0	0	6	33	107	167	226	235	171	78	4	0
	CDH23.3	11499	0	1	73	439	1393	1993	2568	2569	1689	736	37	0
CDH26.7	5392	0	0	16	150	631	966	1314	1326	739	248	3	0	
Wind	WSAvg	2.5	2.3	2.5	2.7	2.8	2.8	2.9	3.1	2.9	2.4	1.9	1.8	1.9
Precipitation	PrecAvg	155	34	30	28	9	3	0	0	0	0	7	16	29
	PrecMax	289	99	76	68	53	21	0	0	3	29	98	97	
	PrecMin	58	6	3	1	0	0	0	0	0	0	0	2	
	PrecStd	52	23	21	18	10	5	0	0	1	9	20	24	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	22.5	28.9	33.3	37.7	37.7	39.0	39.1	37.2	33.9	26.9	20.9
		MCWB	9.5	10.6	13.1	16.2	18.0	17.8	19.9	21.4	18.6	16.4	14.0	11.3
	2%	DB	16.2	19.5	25.3	30.3	34.6	35.8	36.0	36.0	34.5	31.6	24.3	18.5
		MCWB	8.9	9.6	12.3	14.6	17.0	18.3	19.9	20.1	18.3	16.4	13.7	10.5
	5%	DB	14.7	17.3	22.8	28.1	32.4	33.7	34.2	34.4	32.5	29.5	22.3	16.4
		MCWB	8.5	9.0	11.1	13.7	16.3	17.9	19.3	19.6	18.0	16.3	12.8	10.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	12.4	15.3	17.4	19.8	21.6	23.2	24.3	23.1	20.3	17.0	13.7
		MCDB	14.9	19.1	23.2	28.7	32.4	30.5	30.7	31.4	28.9	26.0	20.8	17.5
	2%	WB	10.2	11.1	13.7	15.9	18.3	20.4	22.1	23.0	21.6	19.1	15.6	12.1
		MCDB	13.6	15.8	21.4	25.7	30.6	29.2	30.4	29.2	27.3	25.2	20.0	15.8
	5%	WB	9.5	10.1	12.6	14.8	17.4	19.6	21.3	22.2	20.7	18.2	14.6	11.1
		MCDB	12.9	14.9	20.0	24.6	28.9	28.4	29.3	28.7	26.6	24.3	19.5	14.7
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.1	11.7	13.8	15.2	15.5	15.0	14.7	14.1	13.3	11.5	9.9
		MCDBR	11.6	13.3	15.3	16.9	17.3	17.8	16.7	16.5	16.1	15.5	13.8	12.0
		MCWBR	6.1	6.0	6.4	6.9	6.7	6.5	5.6	5.2	5.3	5.9	6.7	6.7
	5% WB	MCDBR	9.9	11.0	13.1	15.2	15.6	15.5	15.2	14.8	14.0	13.1	11.1	9.9
		MCWBR	6.1	6.0	6.6	6.9	6.7	6.5	5.7	5.1	5.3	6.1	6.5	6.3
		Clear-Sky Solar Irradiance	taub	0.342	0.371	0.413	0.457	0.458	0.387	0.393	0.399	0.392	0.412	0.364
taud	2.309		2.212	2.071	1.955	1.983	2.219	2.209	2.194	2.217	2.145	2.268	2.313	
Ebn at Noon	867		875	861	837	838	896	888	879	872	817	831	841	
Edh at Noon	104		127	158	185	181	143	144	144	135	134	108	99	
All-Sky Solar Radiation	RadAvg	3.00	3.79	5.22	6.36	7.48	8.33	8.06	7.38	6.30	4.76	3.54	2.81	
	RadStd	0.20	0.33	0.31	0.33	0.33	0.11	0.09	0.10	0.16	0.19	0.20	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.44	N/A	-1.73	N/A	N/A	N/A	N/A	-64	+158	+103

Nomenclature: See separate page