

JERUSALEM ATAROT, Palestinian Territory, Occupied

WMO: 402900

Lat: 31.867N

Lon: 35.217E

Elev: 2490

StdP: 13.42

Time Zone: 2.00 (JOR)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.6	38.2	17.9	14.9	56.5	21.7	17.9	56.8	26.2	43.6	23.0	44.4	4.8	240	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	92.0	65.0	89.6	65.0	87.4	64.8	71.2	84.3	69.7	81.6	68.4	80.1	8.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.7	111.7	76.0	66.2	106.0	73.5	64.8	100.9	71.8	36.7	83.7	35.3	82.1	34.2	80.6	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	18.5	16.8	30.8	98.9	4.4	3.3	27.6	101.3	25.0	103.2	22.6	105.1	19.4	107.4
			30.1	75.5	2.0	4.7	28.6	78.9	27.4	81.7	26.3	84.3	24.8	87.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	48.5	49.1	53.4	60.4	67.6	72.3	76.1	75.8	73.8	68.8	59.8	51.3
	DBStd	11.64	5.04	5.81	7.64	8.18	6.68	4.68	3.71	3.12	4.26	5.56	6.22	4.92
	HDD50	260	87	77	41	7	0	0	0	0	0	0	7	41
	HDD65	2195	511	447	374	191	47	1	0	0	0	21	177	426
	CDD50	5053	41	51	146	317	545	668	808	800	713	583	301	80
	CDD65	1514	0	1	15	51	128	218	343	335	263	139	20	1
	CDH74	11917	0	2	61	427	1245	1768	2931	2627	1889	893	72	2
	CDH80	3962	0	0	6	122	421	564	1053	932	612	246	6	0
Wind	WSAvg	7.7	6.8	7.3	7.9	8.0	8.1	9.2	9.7	9.0	7.9	6.3	6.3	6.0
Precipitation	PrecAvg	23.2	5.2	4.6	3.7	1.2	0.2	0.0	0.0	0.0	0.0	0.7	2.7	5.3
	PrecMax	45.4	16.6	13.9	9.5	8.7	1.2	1.1	0.0	0.0	0.1	3.2	10.1	18.7
	PrecMin	11.0	0.6	0.7	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
	PrecStd	7.6	3.2	3.1	1.9	1.6	0.3	0.2	0.0	0.0	0.0	0.8	2.3	4.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.3	71.9	79.9	89.6	93.4	93.8	95.4	93.6	95.1	90.9	80.1	70.2
		MCWB	51.2	54.5	55.3	62.3	63.3	62.9	66.8	69.0	64.0	62.0	59.5	54.2
	2%	DB	62.6	65.5	74.8	83.2	88.2	89.4	90.8	89.8	90.0	85.9	75.6	65.5
		MCWB	49.1	50.1	53.9	58.5	61.5	62.6	65.8	68.3	64.0	61.7	57.2	51.6
	5%	DB	58.8	61.7	70.1	78.9	84.5	85.8	88.0	87.5	86.1	82.3	72.2	61.8
		MCWB	48.2	48.0	52.3	56.9	60.9	63.3	65.2	67.9	64.1	61.2	56.2	50.2
	10%	DB	56.0	58.6	66.2	74.8	81.0	82.7	85.8	85.3	83.0	78.9	69.3	58.9
		MCWB	47.2	47.1	50.9	55.4	60.2	63.0	65.2	67.2	64.3	61.5	54.9	49.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.6	57.0	59.2	64.2	68.2	69.3	72.5	73.9	71.9	68.7	63.4	57.8
		MCDB	59.9	69.3	72.2	83.6	84.8	83.9	87.6	87.6	83.0	79.3	73.1	66.0
	2%	WB	51.7	52.2	56.3	60.9	65.6	67.5	70.1	71.7	69.3	66.3	59.8	53.7
		MCDB	58.5	61.8	69.6	78.2	82.2	81.7	84.0	84.8	79.3	76.6	68.3	61.1
	5%	WB	50.0	50.2	54.1	58.6	63.5	66.2	68.6	70.3	68.0	64.7	58.4	52.1
		MCDB	56.1	58.2	66.4	75.5	80.2	79.6	81.5	82.2	78.4	74.4	66.7	58.5
	10%	WB	48.7	48.7	52.2	56.6	61.4	64.9	67.5	69.0	66.7	63.3	57.3	50.6
		MCDB	54.3	55.7	63.2	72.0	77.1	78.1	79.5	80.2	76.6	73.0	65.8	56.6
Mean Daily Temperature Range	5% DB	MDBR	11.6	12.8	14.3	17.9	19.8	19.3	18.4	18.9	18.8	17.5	13.8	12.0
		MCDBR	16.3	18.1	18.2	22.2	24.2	22.7	21.0	21.9	22.3	22.2	17.9	17.4
		MCWBR	10.2	11.3	11.0	10.9	13.1	12.5	12.4	12.3	13.0	11.2	9.4	10.3
	5% WB	MCDBR	14.3	17.0	18.6	22.4	22.7	21.0	20.0	21.2	20.6	19.9	15.8	15.7
		MCWBR	9.7	11.4	12.3	12.8	14.1	11.9	11.7	11.6	11.3	11.1	9.5	10.4
Clear-Sky Solar Irradiance	taub	0.349	0.379	0.420	0.457	0.454	0.390	0.400	0.407	0.400	0.413	0.366	0.349	
	taud	2.296	2.193	2.063	1.969	2.009	2.237	2.218	2.199	2.221	2.164	2.282	2.313	
	Ebn at Noon	273	275	272	266	267	283	280	277	275	260	264	266	
	Edh at Noon	34	41	51	58	56	44	45	45	43	42	34	32	
All-Sky Solar Radiation	RadAvg	961	1219	1663	2037	2364	2609	2541	2330	1983	1505	1125	899	
	RadStd	61	89	100	92	93	39	26	30	48	60	56	55	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (17 neighbors)		+0.83	N/A	-4.45	N/A	N/A	N/A	N/A	-139	+274	+185

Nomenclature: See separate page