

JERUSALEM ATAROT, Palestinian Territory, Occupied

WMO: 402900

Lat: 31.867N

Lon: 35.217E

Elev: 759

StdP: 92.53

Time Zone: 2.00 (JOR)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.0	(c) 3.5	(d) -7.8	(e) 2.1	(f) 13.6	(g) -5.7	(h) 2.6	(i) 13.8	(j) 11.7	(k) 6.4	(l) 10.3	(m) 6.9	(n) 2.1	(o) 240	(p) 0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.2	(c) 33.3	(d) 18.3	(e) 32.0	(f) 18.3	(g) 30.8	(h) 18.2	(i) 21.8	(j) 29.0	(k) 20.9	(l) 27.5	(m) 20.2	(n) 26.7	(o) 3.9	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	16.0	24.4	19.0	15.1	23.0	18.2	14.4	22.1	67.5	28.7	64.2	27.8	61.7	27.0	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	8.3	7.5	-0.7	37.2	2.4	1.8	-2.4	38.5	-3.9	39.6	-5.2	40.6	-7.0	41.9
			-1.1	24.2	1.1	2.6	-1.9	26.1	-2.5	27.6	-3.2	29.1	-4.0	31.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	9.2	9.5	11.9	15.8	19.8	22.4	24.5	24.3	23.2	20.5	15.4	10.7		
	DBStd	6.47	2.80	3.23	4.25	4.54	3.71	2.60	2.06	1.73	2.37	3.09	3.46	2.73		
	HDD10.0	144	48	43	23	4	0	0	0	0	0	0	4	23		
	HDD18.3	1219	284	248	208	106	26	1	0	0	0	12	98	237		
	CDD10.0	2807	23	28	81	176	303	371	449	444	396	324	167	44		
	CDD18.3	841	0	1	8	28	71	121	191	186	146	77	11	1		
	CDH23.3	6621	0	1	34	237	692	982	1628	1459	1049	496	40	1		
(13)	CDH26.7	2201	0	0	3	68	234	313	585	518	340	137	3	0		
(14)	Wind	WSAvg	3.5	3.0	3.3	3.6	3.6	4.1	4.3	4.0	3.5	2.8	2.8	2.7		
(15) Precipitation	PrecAvg	590	133	118	93	30	4	1	0	0	0	19	68	135		
	PrecMax	1153	422	353	242	220	30	28	0	0	3	81	257	476		
	PrecMin	280	14	19	2	0	0	0	0	0	0	0	0	7		
	PrecStd	194	82	79	47	41	7	5	0	0	1	20	59	106		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.6	22.2	26.6	32.0	34.1	34.3	35.2	34.2	35.0	32.7	26.7	21.2		
		MCWB	10.6	12.5	13.0	16.9	17.4	17.2	19.4	20.5	17.8	16.6	15.3	12.3		
	2%	DB	17.0	18.6	23.8	28.4	31.2	31.9	32.7	32.1	32.2	29.9	24.2	18.6		
		MCWB	9.5	10.1	12.2	14.7	16.4	17.0	18.8	20.2	17.8	16.5	14.0	10.9		
	5%	DB	14.9	16.5	21.2	26.0	29.2	29.9	31.1	30.8	30.1	27.9	22.3	16.5		
		MCWB	9.0	8.9	11.3	13.8	16.1	17.4	18.4	20.0	17.8	16.2	13.5	10.1		
	10%	DB	13.3	14.8	19.0	23.8	27.2	28.2	29.9	29.6	28.3	26.0	20.7	15.0		
		MCWB	8.5	8.4	10.5	13.0	15.6	17.2	18.4	19.5	17.9	16.4	12.7	9.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	13.9	15.1	17.9	20.1	20.7	22.5	23.3	22.2	20.4	17.4	14.3		
		MCDB	15.5	20.7	22.3	28.7	29.3	28.9	30.9	30.9	28.4	26.3	22.8	18.9		
	2%	WB	10.9	11.2	13.5	16.1	18.6	19.7	21.2	22.1	20.7	19.1	15.4	12.0		
		MCDB	14.7	16.6	20.9	25.6	27.9	27.6	28.9	29.3	26.3	24.8	20.2	16.2		
	5%	WB	10.0	10.1	12.3	14.8	17.5	19.0	20.3	21.3	20.0	18.2	14.7	11.2		
		MCDB	13.4	14.6	19.1	24.2	26.8	26.4	27.5	27.9	25.8	23.6	19.3	14.7		
	10%	WB	9.3	9.3	11.2	13.7	16.3	18.3	19.7	20.6	19.3	17.4	14.0	10.4		
		MCDB	12.4	13.2	17.3	22.2	25.1	25.6	26.4	26.8	24.8	22.8	18.8	13.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	7.1	7.9	9.9	11.0	10.7	10.2	10.5	10.5	9.7	7.6	6.7		
		MCDBR	9.1	10.0	10.1	12.3	13.4	12.6	11.6	12.2	12.4	12.3	10.0	9.7		
		MCWBR	5.7	6.3	6.1	6.0	7.3	7.0	6.9	6.8	7.2	6.2	5.2	5.7		
	5% WB	MCDBR	8.0	9.4	10.4	12.4	12.6	11.6	11.1	11.8	11.5	11.1	8.8	8.7		
		MCWBR	5.4	6.3	6.8	7.1	7.8	6.6	6.5	6.5	6.3	6.2	5.3	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.349	0.379	0.420	0.457	0.454	0.390	0.400	0.407	0.400	0.413	0.366	0.349		
	taud		2.296	2.193	2.063	1.969	2.009	2.237	2.218	2.199	2.221	2.164	2.282	2.313		
	Ebn at Noon		861	868	856	838	841	893	883	873	866	819	833	839		
	Edh at Noon		107	130	160	183	177	140	143	143	135	132	107	100		
(44) All-Sky Solar Radiation	RadAvg		3.03	3.84	5.24	6.42	7.45	8.22	8.01	7.35	6.25	4.75	3.54	2.83		
	RadStd		0.19	0.28	0.32	0.29	0.29	0.12	0.08	0.10	0.15	0.19	0.18	0.17		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (17 neighbors)	+0.46	N/A	-2.47	N/A	N/A	N/A	N/A	-77	+152	+103

Nomenclature: See separate page