

GAWR AL-SAFI, Jordan

WMO: 402960

Lat: 31.033N

Lon: 35.467E

Elev: -350

StdP: 105.60

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.9	10.2	0.8	3.8	15.3	2.5	4.3	15.5	6.8	18.2	5.8	18.4	0.1	N/A	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	41.9	25.4	40.8	25.1	39.7	25.0	27.9	38.0	27.1	37.0	26.5	36.4	0.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	19.3	34.5	24.1	18.2	34.2	23.4	17.4	33.8	86.7	38.2	83.2	37.2	80.4	36.3	33.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.1	4.5	3.4	4.2	44.9	3.1	1.5	2.0	46.0	0.2	46.8	-1.5	47.6	-3.7	48.7
			2.5	29.8	2.8	1.4	0.5	30.9	-1.1	31.7	-2.7	32.5	-4.7	33.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	16.1	17.8	21.2	24.9	29.2	32.3	34.5	34.5	32.3	28.5	22.1	17.4	(6)
(7)		DBStd	6.96	1.97	2.16	2.75	3.18	2.58	1.91	1.42	1.48	1.72	2.44	2.73	2.57	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	162	73	31	7	1	0	0	0	0	0	0	4	47	(9)
(10)		CDD10.0	5824	189	220	346	448	595	670	758	758	670	574	364	231	(10)
(11)		CDD18.3	2943	3	17	94	199	337	420	500	499	420	316	118	20	(11)
(12)		CDH23.3	40659	6	62	610	1937	4464	6450	8157	8117	6311	3796	700	50	(12)
(13)		CDH26.7	24798	0	5	172	823	2446	4113	5685	5644	3936	1816	156	4	(13)
(14)	Wind	WSAvg	0.5	0.4	0.6	0.8	0.7	0.7	0.6	0.4	0.4	0.4	0.3	0.3	(14)	
(15)	Precipitation	PrecAvg	187	47	42	29	9	4	0	0	0	6	17	33	(15)	
(16)		PrecMax	333	76	108	132	53	48	1	0	4	50	98	85	(16)	
(17)		PrecMin	83	0	14	4	0	0	0	0	0	0	1	0	(17)	
(18)		PrecStd	59	20	17	24	11	10	0	0	1	10	20	21	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	27.3	33.7	38.2	41.2	42.1	43.6	42.7	41.3	37.8	31.6	26.7	(19)
(20)		0.4%	MCWB	15.8	17.0	20.2	21.9	24.4	25.2	25.6	27.0	25.1	24.8	20.5	17.5	(20)
(21)		2%	DB	22.7	25.2	30.4	35.3	38.3	40.6	42.2	41.2	39.1	35.7	29.8	24.6	(21)
(22)		2%	MCWB	15.2	15.9	18.8	21.0	23.6	24.6	25.3	25.6	25.3	23.5	20.1	16.6	(22)
(23)		5%	DB	21.6	23.7	28.2	33.2	36.6	39.3	41.0	40.2	37.8	34.3	28.5	23.4	(23)
(24)		5%	MCWB	14.6	15.3	17.7	20.6	22.8	24.2	25.0	25.5	25.1	23.3	19.6	16.2	(24)
(25)		10%	DB	20.6	22.5	26.4	31.1	35.1	37.9	39.9	39.2	36.7	33.1	27.1	22.1	(25)
(26)		10%	MCWB	14.2	15.0	17.0	19.7	22.5	24.0	25.0	25.4	24.8	23.1	19.1	15.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	18.3	21.1	24.0	26.6	27.3	28.2	28.9	28.4	28.4	23.0	19.1	(27)
(28)		0.4%	MCDWB	22.2	24.9	31.5	35.5	36.0	38.4	40.0	39.0	36.6	33.9	28.8	24.1	(28)
(29)		2%	WB	16.1	17.0	19.6	22.2	25.2	26.2	27.2	28.1	27.0	25.7	21.6	17.8	(29)
(30)		2%	MCDWB	21.2	23.2	29.2	33.1	35.6	37.5	38.8	38.4	35.8	33.0	27.6	23.0	(30)
(31)		5%	WB	15.4	16.1	18.5	21.1	24.2	25.5	26.5	27.4	26.3	24.6	20.6	17.0	(31)
(32)		5%	MCDWB	20.5	22.2	26.6	31.5	34.2	36.5	38.1	37.1	35.3	32.0	26.7	22.1	(32)
(33)		10%	WB	14.7	15.5	17.6	20.0	23.4	24.8	25.9	26.7	25.7	23.9	19.8	16.1	(33)
(34)		10%	MCDWB	19.7	21.4	25.2	30.0	33.0	35.4	37.4	36.1	34.7	31.4	25.9	21.2	(34)
(35)	Mean Daily Temperature Range		MDBR	9.3	8.9	9.6	10.5	11.2	11.5	11.5	10.3	9.2	8.9	9.4	9.2	(35)
(36)		5% DB	MCDBR	10.3	10.2	12.0	12.6	13.1	13.0	13.1	11.3	10.3	9.6	10.4	10.0	(36)
(37)		5% DB	MCWBR	5.4	4.8	5.0	5.2	5.1	4.7	4.6	3.8	3.9	4.1	4.9	5.5	(37)
(38)		5% WB	MCDWR	9.4	9.1	11.2	11.7	12.0	11.8	11.7	10.2	9.3	8.9	9.5	9.1	(38)
(39)		5% WB	MCWBR	5.4	4.9	5.1	5.2	5.4	5.0	4.9	4.0	4.2	4.6	5.1	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.408	0.453	0.515	0.574	0.572	0.478	0.484	0.495	0.493	0.512	0.436	0.407	(40)	
(41)		taud	2.112	1.977	1.819	1.708	1.734	1.983	1.989	1.969	1.966	1.918	2.073	2.128	(41)	
(42)		Ebn at Noon	793	791	770	743	747	818	811	797	780	724	754	770	(42)	
(43)		Edh at Noon	130	164	205	238	234	181	179	181	175	171	135	123	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.32	4.18	5.55	6.68	7.64	8.40	8.16	7.52	6.47	5.01	3.81	3.12	(44)	
(45)		RadStd	0.18	0.23	0.28	0.21	0.28	0.10	0.11	0.09	0.16	0.18	0.16	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	-1.93	N/A	N/A	N/A	N/A	-54	+151	+103

Nomenclature: See separate page