

AQABA KING HUSSEIN INTL, Jordan

WMO: 403400

Lat: 29.612N

Lon: 35.018E

Elev: 53

StdP: 100.69

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.8	8.9	-5.1	2.5	19.2	-3.1	2.9	18.5	10.5	17.9	9.7	18.0	1.9	0	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	42.0	23.7	40.9	23.1	39.9	22.8	27.8	35.9	26.8	34.8	25.9	34.7	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.5	31.8	24.8	20.0	31.8	23.4	18.4	31.4	89.5	36.1	84.9	35.2	80.7	34.7	34.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	10.0	9.0	DB	5.6	44.5	1.8	1.1	4.4	45.3	3.3	46.0	2.3	46.6	1.0	47.5	(4)
			WB	2.8	28.5	1.7	2.3	1.6	30.1	0.6	31.5	-0.3	32.7	-1.5	34.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.1	15.3	17.0	20.4	24.5	28.9	31.8	33.5	33.4	30.9	27.0	21.5	16.7	(6)
(7)		DBStd	6.97	2.18	2.81	3.31	3.46	3.00	2.23	1.62	1.62	1.82	2.73	2.83	2.38	(7)
(8)		HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	235	98	54	14	1	0	0	0	0	0	0	6	62	(9)
(10)		CDD10.0	5517	163	197	324	433	586	653	729	726	627	526	345	208	(10)
(11)		CDD18.3	2710	3	17	79	184	327	403	471	468	377	268	101	12	(11)
(12)		CDH23.3	37112	23	144	689	1949	4359	6115	7568	7384	5277	2856	680	68	(12)
(13)	CDH26.7	22306	1	31	234	914	2524	3927	5123	4933	3090	1336	183	9	(13)	
(14)	Wind	WSAvg	4.3	2.9	3.5	4.1	4.5	4.8	5.1	4.7	5.2	5.5	4.5	3.6	3.1	(14)
(15)	Precipitation	PrecAvg	24	3	4	3	3	1	0	0	0	0	3	3	5	(15)
(16)		PrecMax	62	23	67	22	28	13	0	0	0	0	35	27	43	(16)
(17)		PrecMin	0	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	16	5	10	5	6	3	0	0	0	0	8	6	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	25.9	30.0	34.8	38.2	41.9	43.2	43.2	43.0	40.9	38.7	32.9	27.9	(19)	
(20)		MCWB	15.0	16.9	19.3	19.3	21.8	22.8	24.2	25.5	23.0	21.6	19.6	15.6	(20)	
(21)		DB	23.8	27.1	31.5	36.0	39.6	41.2	41.9	41.2	39.0	36.1	30.3	25.2	(21)	
(22)		MCWB	13.7	15.1	17.9	18.5	21.3	22.5	23.9	24.0	22.7	21.8	18.3	15.3	(22)	
(23)		DB	22.0	24.9	29.1	33.9	37.8	40.0	40.8	40.1	37.8	34.2	28.9	23.2	(23)	
(24)		MCWB	13.2	14.5	16.6	18.3	21.0	22.1	23.4	23.4	22.5	21.4	17.7	14.4	(24)	
(25)		DB	20.4	23.0	27.0	31.9	36.0	38.8	39.8	39.1	36.4	32.8	27.1	22.0	(25)	
(26)		MCWB	12.5	13.8	15.9	17.9	20.2	21.9	23.1	23.2	22.3	21.0	17.1	13.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	17.4	19.3	23.1	23.3	25.8	27.1	29.1	29.7	28.1	26.3	22.1	19.4	(27)	
(28)		MCDWB	21.5	25.9	29.2	29.5	33.6	37.5	38.5	36.8	33.8	31.6	28.1	23.3	(28)	
(29)		WB	15.3	16.9	20.6	21.7	24.0	25.6	27.4	28.1	26.7	24.6	20.6	17.0	(29)	
(30)		MCDWB	20.8	24.5	27.0	30.1	33.9	36.1	37.0	36.2	32.1	30.6	26.6	22.2	(30)	
(31)		WB	14.2	15.5	18.6	20.1	22.9	24.5	26.3	27.1	25.5	23.4	19.3	15.5	(31)	
(32)		MCDWB	19.8	22.5	26.1	29.6	33.4	34.7	36.2	34.8	32.1	30.0	25.8	21.4	(32)	
(33)		WB	13.2	14.4	17.0	18.9	21.8	23.6	25.3	26.1	24.4	22.4	18.3	14.5	(33)	
(34)		MCDWB	19.1	21.3	24.7	28.8	32.5	34.3	35.6	34.7	32.1	29.6	25.0	20.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.4	11.1	11.8	12.6	13.1	13.5	12.9	12.2	11.7	11.2	10.9	10.6	(35)	
(36)		5% DB	12.3	13.4	14.1	14.6	14.8	14.7	13.7	12.8	12.6	12.6	12.1	12.0	(36)	
(37)		MCWBR	6.1	6.3	6.4	6.0	5.8	5.3	5.0	4.5	4.6	5.0	5.5	6.0	(37)	
(38)		5% WB	10.9	11.9	12.0	12.6	13.3	13.8	13.0	12.0	11.7	11.2	11.1	10.8	(38)	
(39)		MCWBR	6.3	6.4	7.4	6.2	6.4	6.1	5.7	5.4	5.4	5.6	6.0	6.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.366	0.408	0.472	0.499	0.504	0.422	0.427	0.436	0.433	0.439	0.376	0.348	(40)	
(41)		taud	2.238	2.092	1.896	1.859	1.876	2.137	2.155	2.138	2.133	2.093	2.258	2.328	(41)	
(42)		Ebn at Noon	854	846	813	806	802	866	860	851	840	803	837	858	(42)	
(43)		Edh at Noon	117	147	191	206	203	156	152	153	149	145	113	102	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.82	4.77	6.13	7.14	7.86	8.51	8.22	7.63	6.67	5.34	4.23	3.60	(44)	
(45)		RadStd	0.16	0.18	0.20	0.16	0.26	0.09	0.14	0.11	0.15	0.16	0.13	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+0.48	N/A	-2.22	N/A	-1.54	-2.33	N/A	N/A	N/A	N/A	
(47)	Regional (11 neighbors)		+0.43	N/A	-1.58	N/A	N/A	N/A	N/A	+135	+146	(47)

Nomenclature: See separate page