

BAGHDAD INTL, IraqWMO: **406500**Lat: **33.267N**Lon: **44.233E**Elev: **114**StdP: **14.64**Time Zone: **3.00 (E03)**Period: **03-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.3	37.6	16.6	12.8	51.2	20.0	15.0	53.2	23.8	59.3	21.3	58.9	4.1	300	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.7	116.8	71.4	114.7	70.9	112.7	70.1	74.1	108.6	72.9	107.9	71.8	106.8	10.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	86.6	81.0	61.2	81.1	80.1	59.4	76.0	81.2	37.7	108.8	36.5	108.2	35.6	106.4	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.7	17.9	15.5	DB	30.1	120.1	1.9	2.0	28.7	121.5	27.6	122.7	26.5	123.8	25.1	125.3
(5)				WB	27.3	77.3	2.5	2.5	25.6	79.1	24.1	80.5	22.8	81.9	21.0	83.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.9	51.5	56.6	64.8	74.5	85.6	93.9	97.9	97.6	90.2	79.4	63.2	54.6
	DBStd	17.43	5.22	6.00	6.01	6.13	5.77	4.01	3.55	3.54	4.65	6.32	6.25	5.61
	HDD50	84	45	15	1	0	0	0	0	0	0	0	1	22
	HDD65	1171	419	240	77	5	0	0	0	0	0	1	107	322
	CDD50	9546	91	199	459	736	1105	1316	1486	1477	1205	910	396	166
	CDD65	5157	0	5	70	290	640	866	1021	1012	755	446	51	1
	CDH74	83043	1	38	747	3352	9642	14930	18332	18071	12028	5419	470	13
	CDH80	57312	0	1	209	1545	6079	10733	13882	13647	8168	2943	105	0
Wind	WSAvg	6.8	5.9	6.4	7.0	6.8	7.2	8.4	8.7	7.4	6.5	5.9	5.2	5.7
Precipitation	PrecAvg	8.1	1.2	1.1	1.2	1.1	0.6	0.0	0.0	0.0	0.0	0.6	1.1	1.1
	PrecMax	12.2	2.3	3.1	3.4	2.8	2.1	0.2	0.1	0.1	0.4	1.8	4.0	2.6
	PrecMin	4.6	0.2	0.1	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1
	PrecStd	2.1	0.6	0.7	0.8	0.7	0.5	0.0	0.0	0.0	0.1	0.5	1.1	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.1	78.7	92.9	100.7	109.6	116.6	120.2	118.8	114.8	103.8	86.6	75.6
		MCWB	54.6	56.2	62.6	64.8	67.9	70.0	72.1	71.8	70.2	68.8	62.5	57.0
	2%	DB	66.6	74.8	84.6	96.4	106.1	113.2	117.0	116.8	111.2	100.2	82.7	71.4
		MCWB	53.5	55.7	58.8	63.8	67.1	69.4	71.4	71.7	70.1	66.5	60.8	56.1
	5%	DB	64.4	71.4	80.9	92.8	103.7	111.0	114.8	114.8	107.7	96.9	79.4	68.0
		MCWB	52.5	54.8	57.7	62.5	66.5	68.6	70.7	71.4	69.0	65.2	59.3	54.6
	10%	DB	62.3	68.1	78.4	88.4	100.5	108.0	112.6	112.6	105.4	93.6	75.5	64.8
		MCWB	51.4	53.6	56.6	61.5	65.5	67.8	70.1	70.6	68.1	64.7	57.8	53.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.4	61.3	64.6	68.8	71.5	73.4	75.5	76.0	73.5	71.3	67.2	60.7
		MCDB	65.2	69.7	80.8	90.7	98.3	108.4	109.5	108.5	105.0	95.9	76.4	66.1
	2%	WB	56.6	58.4	61.8	66.6	69.4	71.6	73.8	74.5	71.6	69.1	63.8	58.6
		MCDB	62.8	67.7	79.5	86.1	96.7	107.3	109.0	108.9	105.4	92.2	74.6	67.1
	5%	WB	54.3	56.6	59.8	65.1	68.1	70.2	72.6	73.3	70.4	67.4	61.8	56.6
		MCDB	62.0	67.0	75.8	84.0	95.7	105.3	108.4	108.5	103.5	89.0	73.8	64.9
	10%	WB	52.2	55.1	58.1	63.6	67.0	69.0	71.5	72.1	69.2	66.0	60.3	55.0
		MCDB	60.1	66.0	73.8	82.6	94.3	104.0	107.6	107.3	101.6	87.9	72.4	63.2
Mean Daily Temperature Range	5% DB	MDBR	18.8	19.9	22.2	23.4	24.9	27.3	27.7	29.3	28.6	24.8	22.2	19.5
		MCDBR	21.0	23.2	26.1	27.9	29.0	30.6	30.8	31.7	31.5	28.3	25.9	21.6
		MCWBR	11.3	10.8	10.4	9.7	9.5	10.4	10.5	10.5	10.2	10.2	11.3	10.9
	5% WB	MCDBR	17.3	18.7	21.8	23.0	25.6	28.4	28.6	30.1	29.2	23.0	19.5	17.3
MCWBR		10.3	9.9	10.0	9.0	9.3	10.6	11.0	11.4	10.5	9.5	9.9	9.7	
Clear-Sky Solar Irradiance	taub	0.455	0.486	0.540	0.633	0.639	0.587	0.617	0.578	0.530	0.559	0.485	0.466	
	taud	1.937	1.873	1.753	1.606	1.607	1.690	1.643	1.721	1.814	1.774	1.904	1.930	
	Ebn at Noon	227	236	234	220	220	232	224	230	234	211	215	214	
	Edh at Noon	48	56	69	83	84	77	80	73	64	62	49	46	
All-Sky Solar Radiation	RadAvg	968	1259	1656	1905	2222	2531	2401	2229	1905	1406	1065	880	
	RadStd	47	88	72	97	104	72	74	51	78	91	92	63	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page