

BAGHDAD INTL, IraqWMO: **406500**Lat: **33.267N**Lon: **44.233E**Elev: **35**StdP: **100.91**Time Zone: **3.00 (E03)**Period: **03-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	3.1	-8.5	1.8	10.6	-6.7	2.1	11.8	10.6	15.2	9.5	15.0	1.8	300	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	47.1	21.9	46.0	21.6	44.8	21.1	23.4	42.6	22.7	42.1	22.1	41.6	4.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.4	27.2	16.2	11.6	26.7	15.2	10.9	27.3	69.8	42.7	67.1	42.3	64.8	41.3	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.2	8.0	6.9	DB	-1.1	48.9	1.1	1.1	-1.8	49.7	-2.5	50.4	-3.1	51.0	-3.8	51.8
(5)				WB	-2.6	25.2	1.4	1.4	-3.6	26.2	-4.4	27.0	-5.1	27.7	-6.1	28.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	10.8	13.7	18.2	23.6	29.8	34.4	36.6	36.5	32.3	26.3	17.3	12.6
	DBStd	9.69	2.90	3.33	3.34	3.41	3.20	2.23	1.97	1.97	2.58	3.51	3.47	3.12
	HDD10.0	47	25	8	1	0	0	0	0	0	0	0	1	12
	HDD18.3	651	233	133	43	3	0	0	0	0	1	59	179	
	CDD10.0	5303	51	111	255	409	614	731	826	821	669	506	220	92
	CDD18.3	2865	0	3	39	161	356	481	567	562	419	248	28	1
	CDH23.3	46135	1	21	415	1862	5357	8294	10184	10039	6682	3011	261	7
	CDH26.7	31840	0	1	116	858	3377	5963	7712	7582	4538	1635	58	0
Wind	WSAvg	3.0	2.6	2.8	3.1	3.0	3.2	3.7	3.9	3.3	2.9	2.6	2.3	2.6
Precipitation	PrecAvg	207	30	29	30	29	14	1	1	1	1	14	29	28
	PrecMax	310	58	78	86	72	53	5	3	3	9	46	101	66
	PrecMin	117	5	3	4	1	3	0	0	0	0	2	3	
	PrecStd	54	15	17	20	19	12	1	1	1	2	12	28	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	25.9	33.8	38.2	43.1	47.0	49.0	48.2	46.0	39.9	30.3	24.2
		MCWB	12.5	13.5	17.0	18.2	20.0	21.1	22.3	22.1	21.2	20.4	16.9	13.9
	2%	DB	19.2	23.8	29.2	35.8	41.2	45.1	47.2	47.1	44.0	37.9	28.2	21.9
		MCWB	12.0	13.1	14.9	17.7	19.5	20.8	21.9	22.1	21.1	19.2	16.0	13.4
	5%	DB	18.0	21.9	27.2	33.8	39.8	43.9	46.0	46.0	42.1	36.1	26.3	20.0
		MCWB	11.4	12.7	14.3	17.0	19.2	20.4	21.5	21.9	20.5	18.5	15.2	12.6
	10%	DB	16.8	20.1	25.8	31.4	38.0	42.2	44.8	44.8	40.8	34.2	24.2	18.2
		MCWB	10.8	12.0	13.7	16.4	18.6	19.9	21.2	21.4	20.1	18.2	14.3	12.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	16.3	18.1	20.4	21.9	23.0	24.2	24.4	23.1	21.9	19.6	16.0
		MCDB	18.4	21.0	27.1	32.6	36.8	42.4	43.1	42.5	40.6	35.5	24.7	18.9
	2%	WB	13.7	14.7	16.6	19.2	20.8	22.0	23.2	23.6	22.0	20.6	17.6	14.8
		MCDB	17.1	19.8	26.4	30.1	35.9	41.9	42.8	42.7	40.8	33.4	23.7	19.5
	5%	WB	12.4	13.7	15.4	18.4	20.1	21.2	22.5	22.9	21.3	19.7	16.6	13.7
		MCDB	16.6	19.5	24.3	28.9	35.4	40.7	42.4	42.5	39.7	31.7	23.2	18.3
	10%	WB	11.2	12.8	14.5	17.6	19.4	20.6	21.9	22.3	20.7	18.9	15.7	12.8
		MCDB	15.6	18.9	23.2	28.1	34.6	40.0	42.0	41.8	38.7	31.1	22.4	17.4
Mean Daily Temperature Range	5% DB	MDBR	10.5	11.1	12.3	13.0	13.8	15.2	15.4	16.3	15.9	13.8	12.3	10.9
		MCDBR	11.7	12.9	14.5	15.5	16.1	17.0	17.1	17.6	17.5	15.7	14.4	12.0
		MCWBR	6.3	6.0	5.8	5.4	5.3	5.8	5.8	5.8	5.7	5.6	6.3	6.1
	5% WB	MCDBR	9.6	10.4	12.1	12.8	14.2	15.8	15.9	16.7	16.2	12.8	10.8	9.6
		MCWBR	5.7	5.5	5.6	5.0	5.2	5.9	6.1	6.3	5.8	5.3	5.5	5.4
Clear-Sky Solar Irradiance	taub	0.455	0.486	0.540	0.633	0.639	0.587	0.617	0.578	0.530	0.559	0.485	0.466	
	taud	1.937	1.873	1.753	1.606	1.607	1.690	1.643	1.721	1.814	1.774	1.904	1.930	
	Ebn at Noon	717	744	738	693	695	731	705	725	738	665	679	675	
	Edh at Noon	151	178	216	262	264	242	253	230	201	194	155	145	
All-Sky Solar Radiation	RadAvg	3.05	3.97	5.22	6.00	7.00	7.98	7.57	7.03	6.01	4.43	3.36	2.77	
	RadStd	0.15	0.28	0.23	0.31	0.33	0.23	0.23	0.16	0.25	0.29	0.29	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page