

PARSABAD MOGHAN, Iran, Islamic Republic of

WMO: 407000

Lat: 39.6064N

Lon: 47.8822E

Elev: 32

StdP: 100.94

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.5	(c) -2.8	(d) -7.5	(e) 2.0	(f) -0.5	(g) -5.9	(h) 2.3	(i) -0.2	(j) 11.3	(k) 7.0	(l) 10.0	(m) 5.5	(n) 2.8	(o) 240	(p) 0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.6	(c) 35.9	(d) 23.2	(e) 34.8	(f) 22.9	(g) 33.6	(h) 22.5	(i) 25.2	(j) 32.7	(k) 24.4	(l) 31.8	(m) 23.7	(n) 30.9	(o) 3.8	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 23.1	(b) 17.9	(c) 28.4	(d) 22.2	(e) 16.9	(f) 28.2	(g) 21.4	(h) 16.1	(i) 27.7	(j) 77.2	(k) 32.7	(l) 74.2	(m) 32.0	(n) 71.3	(o) 30.9	(p) 28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.0	(b) 8.3	(c) 7.0	(e) -7.1	(f) 37.9	(g) 2.8	(h) 1.2	(i) -9.1	(j) 38.8	(k) -10.8	(l) 39.4	(m) -12.4	(n) 40.1	(o) -14.4	(p) 40.9		
(a) 10.0	(b) 8.3	(c) 7.0	(e) -7.8	(f) 26.6	(g) 2.8	(h) 1.1	(i) -9.8	(j) 27.4	(k) -11.5	(l) 28.1	(m) -13.0	(n) 28.7	(o) -15.1	(p) 29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	3.9	5.4	9.3	13.8	20.4	25.1	27.3	26.9	22.5	16.3	9.8	5.6		
	DBStd	8.94	3.45	3.25	3.13	3.84	2.83	2.44	2.16	2.23	2.96	3.51	3.46	3.11		
	HDD10.0	571	191	132	51	11	0	0	0	0	0	3	43	140		
	HDD18.3	1983	448	363	281	143	13	0	0	0	4	81	256	394		
	CDD10.0	2608	2	2	28	123	324	453	536	525	376	197	38	4		
	CDD18.3	979	0	0	0	6	78	203	278	267	131	17	0	0		
	CDH23.3	10083	0	0	6	75	637	2120	3171	2972	997	104	2	0		
	CDH26.7	4668	0	0	0	11	176	1025	1613	1507	321	17	0	0		
(14) Wind	WSAvg	2.7	2.7	2.8	3.0	2.7	2.9	3.1	3.3	3.0	2.6	2.3	2.1	2.4		
(15) Precipitation	PrecAvg	271	19	21	31	29	31	25	6	6	28	37	28	19		
	PrecMax	414	61	70	83	92	82	70	25	23	141	90	92	57		
	PrecMin	170	3	6	7	0	3	2	0	0	0	4	0	0		
	PrecStd	54	13	13	19	22	19	19	7	6	38	23	25	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	18.8	23.9	28.1	32.5	37.1	37.9	37.2	33.2	28.9	21.8	18.0		
		MCWB	9.3	10.7	15.3	19.0	21.9	22.3	23.7	24.2	23.2	19.9	14.5	11.2		
	2%	DB	13.5	15.0	20.3	25.5	30.2	35.0	35.9	35.9	31.6	26.0	18.9	14.5		
		MCWB	7.8	9.5	12.9	17.9	20.9	21.8	23.7	23.3	22.4	19.0	13.9	9.8		
	5%	DB	10.8	12.3	17.8	23.2	28.7	33.6	34.7	34.8	30.0	24.0	16.7	12.2		
		MCWB	6.3	8.1	11.8	16.6	20.1	21.3	23.3	23.0	21.7	18.0	12.9	8.7		
	10%	DB	8.7	10.2	15.3	21.1	27.0	32.1	33.4	33.4	28.5	22.2	15.0	10.2		
		MCWB	5.3	7.1	10.5	15.6	19.5	20.9	22.8	22.8	21.1	17.2	12.0	7.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	11.5	15.8	20.3	23.6	24.6	26.3	26.3	25.1	20.7	16.1	12.0		
		MCDB	17.1	16.3	21.3	26.4	30.4	32.2	33.4	33.8	30.9	26.4	19.9	15.9		
	2%	WB	8.0	9.6	13.5	18.5	21.9	23.4	25.1	25.3	23.7	19.8	14.7	10.3		
		MCDB	12.5	14.1	19.1	24.6	28.1	31.3	33.2	32.9	29.2	24.8	17.4	13.8		
	5%	WB	6.8	8.4	12.1	17.1	21.0	22.6	24.4	24.5	22.7	18.8	13.4	9.1		
		MCDB	9.5	11.7	17.0	22.3	27.2	30.8	32.3	31.9	28.2	22.9	15.9	11.5		
	10%	WB	5.8	7.4	10.8	15.9	20.0	21.8	23.6	23.8	21.7	17.8	12.4	8.0		
		MCDB	8.0	9.7	14.8	20.6	25.8	29.9	31.4	30.8	26.8	21.3	14.8	9.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	8.2	9.9	10.7	11.4	12.5	11.6	12.3	10.2	9.0	8.4	8.4		
		MCDBR	12.5	12.9	15.0	14.3	14.1	15.3	13.9	14.8	12.7	12.3	11.4	11.7		
	5% WB	MCWBR	7.8	7.8	8.4	7.6	6.3	5.6	5.3	5.7	5.6	6.1	6.9	7.7		
		MCWBR	10.7	11.0	13.5	13.3	12.5	13.5	12.9	13.0	11.4	11.1	10.2	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.385	0.426	0.476	0.555	0.531	0.525	0.575	0.552	0.523	0.472	0.414	0.385		
	taud		2.174	2.063	1.961	1.814	1.926	1.965	1.863	1.916	1.968	2.057	2.155	2.186		
	Ebn at Noon		747	767	771	735	767	770	727	730	719	710	706	711		
	Edh at Noon		106	136	168	207	189	182	200	185	165	136	108	98		
(44) All-Sky Solar Radiation	RadAvg		1.94	2.55	3.64	4.67	6.07	7.02	6.76	6.02	4.50	2.98	2.15	1.76		
	RadStd		0.22	0.36	0.38	0.64	0.34	0.40	0.40	0.49	0.39	0.39	0.23	0.21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page