

BARZARGAN, Iran, Islamic Republic of

WMO: 407010

Lat: 39.3795N

Lon: 44.3923E

Elev: 1411

StdP: 85.48

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-12.6	-18.8	0.8	-11.4	-16.8	1.0	-9.9	13.4	1.4	10.3	0.8	0.2	240	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	33.1	16.5	31.7	16.5	30.2	16.1	18.4	29.3	17.7	28.6	17.0	27.8	4.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.8	12.5	22.4	13.7	11.6	22.4	12.9	11.0	22.1	58.2	29.4	55.5	28.6	53.4	27.9	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
12.0	9.8	7.7		-16.4	35.6	4.5	1.5	-19.6	36.7	-22.2	37.6	-24.7	38.5	-28.0		
				-16.9	20.1	4.2	1.8	-19.9	21.4	-22.4	22.5	-24.7	23.5	-27.8	39.6	24.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-3.7	-0.2	5.6	10.6	15.3	20.4	24.0	24.3	19.3	12.6	5.4	-0.5
	DBStd	10.12	4.83	4.55	4.24	3.84	2.99	2.84	2.61	2.41	3.43	3.65	3.75	4.94
	HDD10.0	1381	424	285	148	37	2	0	0	0	17	143	326	
	HDD18.3	3127	683	518	396	233	102	13	1	29	179	388	584	
	CDD10.0	1799	0	0	10	55	166	312	433	442	281	98	4	0
	CDD18.3	504	0	0	0	2	7	74	175	184	59	2	0	0
	CDH23.3	4795	0	0	0	12	56	638	1701	1876	499	14	0	0
	CDH26.7	1669	0	0	0	1	4	165	639	739	120	1	0	0
Wind	WSAvg	2.3	1.3	1.8	3.3	3.2	2.7	2.7	2.6	2.5	2.3	1.8	1.7	1.3
Precipitation	PrecAvg	311	17	17	30	45	59	39	18	11	16	27	22	15
	PrecMax	511	39	53	82	101	130	81	60	52	57	82	73	39
	PrecMin	191	2	1	9	10	31	6	2	0	0	5	0	0
	PrecStd	73	10	12	18	23	23	17	14	11	16	20	17	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	11.2	19.3	25.1	26.9	32.2	35.1	35.1	32.1	25.0	16.2	12.1
		MCWB	2.5	4.7	8.5	11.3	13.6	15.8	17.4	16.7	15.7	12.6	8.3	5.8
	2%	DB	5.5	9.1	15.9	21.5	24.9	30.2	33.2	33.2	29.7	22.8	14.2	9.3
		MCWB	1.5	3.6	7.0	10.2	12.9	15.3	16.9	16.5	15.3	11.9	7.4	4.2
	5%	DB	4.1	7.8	13.9	19.1	23.0	28.4	31.7	31.9	27.9	20.7	12.6	7.3
		MCWB	0.9	2.7	6.2	9.4	12.6	15.0	16.8	16.5	14.5	11.2	6.8	3.2
	10%	DB	2.8	6.1	12.0	17.1	21.2	27.0	30.0	30.5	26.2	18.9	11.1	5.8
		MCWB	0.2	1.8	5.6	8.9	11.9	14.7	16.4	16.3	13.9	10.7	6.1	2.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	6.0	9.2	12.2	15.7	18.1	19.7	21.8	17.9	14.2	9.8	6.4
		MCDB	6.0	9.3	16.8	20.5	24.2	28.9	31.6	29.6	28.5	20.9	14.1	10.3
	2%	WB	2.3	4.2	7.7	11.1	14.4	16.9	18.4	18.6	16.5	12.9	8.5	4.9
		MCDB	4.6	8.0	14.4	18.4	21.6	27.4	29.6	28.9	26.7	19.7	12.1	7.9
	5%	WB	1.3	3.2	6.8	10.3	13.5	16.1	17.8	17.6	15.6	12.1	7.5	3.8
		MCDB	3.6	6.9	12.7	17.2	20.5	26.0	28.6	28.7	25.5	18.7	11.3	6.6
	10%	WB	0.2	2.1	5.9	9.5	12.7	15.5	17.1	17.0	14.9	11.3	6.6	2.8
		MCDB	2.6	5.7	11.4	16.0	19.5	24.8	27.7	28.0	24.5	17.5	10.5	5.2
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.8	8.0	8.7	9.3	10.9	10.8	11.3	10.8	9.2	8.2	6.8
		MCDBR	7.3	8.6	10.3	11.5	12.0	13.0	12.3	13.0	13.0	11.8	9.9	8.6
		MCWBR	4.8	5.1	5.0	5.0	4.9	4.8	4.1	4.5	5.0	5.3	5.6	5.2
	5% WB	MCDBR	6.5	7.8	8.9	9.6	10.3	11.7	11.2	11.6	11.9	10.0	8.4	7.3
		MCWBR	4.5	5.0	4.7	4.8	5.0	4.6	4.0	4.4	5.0	4.9	4.9	4.7
Clear-Sky Solar Irradiance	taub		0.296	0.331	0.391	0.460	0.436	0.415	0.461	0.442	0.378	0.376	0.318	0.293
	taud		2.355	2.253	2.095	1.941	2.078	2.191	2.067	2.110	2.278	2.219	2.371	2.389
	Ebn at Noon		872	880	856	817	847	864	819	825	862	815	837	847
	Edh at Noon		87	112	146	182	162	145	163	152	120	114	86	79
All-Sky Solar Radiation	RadAvg		2.42	3.45	4.16	4.91	6.00	7.43	7.45	6.79	5.52	3.64	2.46	1.86
	RadStd		0.20	0.31	0.32	0.51	0.35	0.45	0.24	0.22	0.29	0.25	0.30	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	+0.84	-0.54	-0.82	N/A	N/A	N/A	N/A

Nomenclature: See separate page