

URMIA INTL, Iran, Islamic Republic of

WMO: 407120

Lat: 37.6581N

Lon: 45.0560E

Elev: 1324

StdP: 86.40

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-9.2	-16.2	1.1	-10.3	-14.1	1.3	-7.5	8.6	3.5	7.4	3.2	2.5	270	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	34.1	17.6	32.8	17.5	31.2	17.3	19.7	30.0	19.1	29.4	18.4	28.8	3.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.2	13.5	25.0	15.1	12.6	24.7	14.2	11.9	24.2	62.5	30.0	60.0	29.6	57.6	28.9	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	6.8	5.5	-13.3	36.2	2.8	1.8	-15.3	37.5	-17.0	38.6	-18.6	39.6	-20.7	40.9		
(5)			-14.0	21.8	2.7	1.1	-16.0	22.6	-17.6	23.2	-19.2	23.9	-21.2	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	-1.1	1.4	6.3	11.2	16.1	21.0	24.1	23.7	19.2	13.3	6.3	0.9	(6)	
(7)		DBStd	9.24	3.65	3.77	3.75	3.32	2.80	2.47	2.08	1.96	2.61	3.07	3.35	3.95	(7)	
(8)		HDD10.0	1137	344	240	124	23	0	0	0	0	8	116	282		(8)	
(9)		HDD18.3	2825	602	473	372	214	78	7	0	0	21	158	361	539	(9)	
(10)		CDD10.0	1844	0	0	11	60	190	331	438	426	274	109	4	0	(10)	
(11)		CDD18.3	493	0	0	0	1	10	88	180	168	46	1	0	0	(11)	
(12)		CDH23.3	6004	0	0	1	18	164	1063	2038	1969	705	46	0	0	(12)	
(13)		CDH26.7	2408	0	0	0	2	18	351	929	904	202	2	0	0	(13)	
(14)	Wind	WSAvg	2.5	2.1	2.4	3.0	3.0	2.9	2.8	2.6	2.5	2.5	2.4	2.2	2.0	(14)	
(15)	Precipitation	PrecAvg	271	27	20	38	52	34	6	7	2	4	21	36	23	(15)	
(16)		PrecMax	484	80	58	82	116	115	25	40	24	29	132	129	80	(16)	
(17)		PrecMin	168	0	0	5	4	0	0	0	0	0	0	0	0	(17)	
(18)		PrecStd	76	18	14	22	32	28	8	9	5	7	34	28	19	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	14.1	21.9	25.8	28.9	33.1	36.2	36.0	33.0	26.8	18.4	14.0	(19)	
(20)			MCWB	4.5	6.9	10.0	13.2	14.8	16.6	18.1	17.4	16.2	13.6	9.4	6.9	(20)	
(21)		2%	DB	8.2	11.8	18.1	22.5	26.8	31.8	34.8	34.1	30.8	24.7	16.2	10.9	(21)	
(22)			MCWB	3.6	5.4	8.8	11.6	14.3	16.6	18.1	17.4	15.6	12.9	8.4	5.5	(22)	
(23)		5%	DB	6.6	9.9	15.8	20.2	25.1	30.1	32.9	32.8	29.0	22.9	14.6	8.9	(23)	
(24)			MCWB	2.7	4.5	7.6	10.8	14.0	16.4	18.0	17.6	15.3	12.4	7.9	4.4	(24)	
(25)		10%	DB	4.8	8.0	13.8	18.2	23.7	28.8	31.2	31.2	27.2	21.0	12.9	7.0	(25)	
(26)			MCWB	1.7	3.5	6.6	10.0	13.5	16.2	17.8	17.4	14.9	11.8	7.3	3.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.7	7.5	10.7	14.2	17.2	19.6	21.6	20.3	18.2	14.7	11.1	7.5	(27)	
(28)			MCDWB	9.0	13.2	19.8	22.9	24.8	29.1	30.8	30.5	28.6	23.2	14.8	12.6	(28)	
(29)		2%	WB	4.1	5.9	9.2	12.6	15.8	18.3	20.1	19.5	17.1	13.7	9.7	5.9	(29)	
(30)			MCDWB	7.1	10.3	16.9	20.1	23.8	28.7	30.5	29.9	27.7	22.4	13.9	9.6	(30)	
(31)		5%	WB	2.9	4.8	8.1	11.7	14.9	17.5	19.3	18.8	16.3	13.0	8.7	4.7	(31)	
(32)			MCDWB	5.8	8.7	14.8	18.3	23.0	27.9	29.7	29.4	26.6	21.2	13.0	7.9	(32)	
(33)		10%	WB	1.9	3.7	6.9	10.7	14.1	16.8	18.7	18.2	15.5	12.2	7.7	3.7	(33)	
(34)			MCDWB	4.5	7.3	12.7	16.9	21.7	27.0	29.0	29.0	25.6	19.8	12.0	6.4	(34)	
(35)	Mean Daily Temperature Range			MDBR	9.1	10.2	11.1	11.8	13.1	14.2	14.0	15.1	15.4	13.5	10.9	9.3	(35)
(36)		5% DB	MCDBR	11.5	12.7	14.0	14.5	15.1	16.1	16.7	17.4	17.6	16.2	13.5	12.1	(36)	
(37)			MCWBR	7.7	7.7	7.4	7.2	6.7	6.8	7.3	7.3	7.6	7.5	7.5	7.7	(37)	
(38)		5% WB	MCDWB	10.3	11.6	13.4	12.7	13.9	14.8	14.5	15.3	16.0	14.7	11.7	10.8	(38)	
(39)			MCWBR	7.2	7.4	7.4	6.7	6.6	6.9	6.7	6.8	7.4	7.3	7.0	7.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.302	0.335	0.385	0.452	0.443	0.411	0.442	0.414	0.370	0.382	0.326	0.301	(40)	
(41)		taud		2.366	2.290	2.156	1.988	2.068	2.203	2.125	2.204	2.318	2.224	2.372	2.406	(41)	
(42)		Ebn at Noon		879	889	871	830	844	869	838	855	877	821	842	855	(42)	
(43)		Edh at Noon		90	110	139	175	164	144	154	139	117	117	89	81	(43)	
(44)	All-Sky Solar Radiation	RadAvg		2.50	3.52	4.33	5.40	6.63	8.06	7.82	7.10	5.83	3.90	2.69	2.11	(44)	
(45)		RadStd		0.21	0.33	0.34	0.45	0.39	0.40	0.24	0.28	0.33	0.31	0.33	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page