

RASHT, Iran, Islamic Republic of

WMO: 407190

Lat: 37.325N

Lon: 49.606E

Elev: -40

StdP: 14.72

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.2	32.4	24.5	18.5	45.7	28.4	22.3	43.0	21.8	55.1	18.1	52.9	3.0	270	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.9	92.6	76.4	90.0	76.0	88.1	75.5	79.9	87.7	78.7	86.2	77.5	84.8	6.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	142.7	84.1	76.7	138.8	83.4	75.3	132.4	82.1	43.6	87.9	42.2	86.6	41.0	84.7	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.7	12.2	10.0	DB	25.3	97.3	6.7	2.2	20.4	98.8	16.5	100.1	12.7	101.3	7.8	102.9
			WB	24.8	83.3	6.6	1.6	20.1	84.4	16.2	85.4	12.5	86.3	7.8	87.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.1	46.0	45.7	51.0	57.7	68.7	75.4	78.5	79.5	73.1	64.7	54.8	48.9	(6)
	DBStd	13.47	6.44	6.08	6.61	6.55	4.94	4.10	3.76	3.83	4.78	5.44	5.87	6.21	(7)
	HDD50	476	153	141	61	10	0	0	0	0	0	0	21	90	(8)
	HDD65	2716	591	540	440	233	22	1	0	3	72	310	504		(9)
	CDD50	4890	28	21	91	242	580	761	884	915	693	455	164	56	(10)
	CDD65	1654	1	0	5	15	137	312	419	450	246	62	3	4	(11)
	CDH74	13602	10	18	107	157	712	2401	3934	4428	1533	261	23	18	(12)
	CDH80	4782	0	2	40	53	131	725	1487	1867	411	62	3	1	(13)
(14) Wind	WSAvg	3.7	4.3	3.9	4.1	4.0	3.7	3.8	3.4	3.4	3.4	3.1	3.2	3.8	(14)
(15) Precipitation	PrecAvg	49.8	4.5	4.1	3.7	2.6	1.7	1.6	2.1	2.5	5.7	7.2	7.4	5.7	(15)
	PrecMax	68.5	9.3	8.2	7.2	7.1	4.6	6.6	5.7	11.3	14.6	14.6	19.5	11.3	(16)
	PrecMin	38.5	1.5	0.5	0.2	0.3	0.4	0.0	0.2	0.0	1.3	0.1	0.8	0.5	(17)
	PrecStd	7.2	2.0	2.1	1.8	1.9	0.9	1.5	1.5	2.1	3.1	3.5	3.5	2.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.0	76.8	85.4	86.1	86.4	91.1	93.8	95.2	90.6	87.8	78.0	76.9	(19)
		MCWB	53.3	55.1	61.1	64.2	70.4	75.6	77.5	75.5	76.7	64.4	59.8	56.7	(20)
	2%	DB	68.2	64.6	73.7	77.4	82.8	88.1	91.4	93.2	87.3	79.4	71.8	71.3	(21)
		MCWB	50.5	50.3	56.6	63.4	70.2	74.0	77.4	76.8	75.4	70.2	61.0	53.4	(22)
	5%	DB	61.2	57.3	66.0	71.8	80.6	86.2	89.3	91.3	84.4	76.6	67.1	64.1	(23)
		MCWB	48.9	49.7	55.5	62.0	69.3	73.3	76.5	76.7	74.3	69.0	60.6	52.4	(24)
	10%	DB	55.1	53.4	59.3	67.7	78.0	84.3	87.4	89.4	82.1	73.6	64.1	57.4	(25)
		MCWB	49.1	48.4	52.8	60.0	68.5	72.4	75.8	76.4	73.6	67.5	59.5	52.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	56.1	62.6	69.0	74.8	79.0	81.7	81.7	79.2	74.1	66.0	59.7	(27)
		MCDB	69.4	70.2	74.2	80.0	82.5	86.1	89.3	90.5	86.6	80.1	71.1	69.0	(28)
	2%	WB	52.6	52.7	58.4	65.2	72.5	76.8	79.7	80.1	77.2	71.5	63.4	56.3	(29)
		MCDB	62.6	62.4	71.1	73.7	79.6	85.0	87.1	88.3	84.1	76.5	67.8	64.0	(30)
	5%	WB	50.9	50.7	55.6	62.6	70.9	75.4	78.4	79.1	75.8	69.9	61.4	54.4	(31)
		MCDB	57.8	55.8	64.4	70.1	77.7	82.9	85.7	86.8	81.8	74.7	65.2	60.0	(32)
	10%	WB	49.5	49.2	53.2	60.3	69.4	74.1	77.1	78.0	74.4	68.4	59.6	52.7	(33)
		MCDB	53.7	52.0	59.4	66.2	75.6	81.0	84.3	85.4	79.8	72.6	63.1	57.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	12.8	14.4	14.5	14.4	14.6	14.8	15.9	13.5	13.3	13.6	13.5	(35)
		MCDBR	26.2	23.0	27.8	23.1	18.9	17.6	18.3	20.1	18.2	18.8	20.4	22.2	(36)
	5% WB	MCWBR	12.6	13.0	13.5	11.6	8.4	7.6	7.7	7.9	8.4	10.4	11.9	11.2	(37)
		MCWBR	19.8	18.2	24.7	20.4	16.8	15.8	16.3	17.2	16.3	16.4	17.2	17.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.392	0.436	0.489	0.574	0.559	0.558	0.603	0.575	0.548	0.501	0.430	0.394	(40)
		taud	2.188	2.072	1.971	1.823	1.904	1.930	1.852	1.912	1.952	2.028	2.154	2.205	(41)
	Ebn at Noon		242	246	244	231	238	237	225	228	225	221	226	232	(42)
		Edh at Noon	35	44	54	66	62	60	64	59	54	46	36	32	(43)
(44) All-Sky Solar Radiation	RadAvg		633	815	1095	1416	1845	2073	2007	1805	1381	961	679	553	(44)
	RadStd		68	111	120	168	121	121	139	183	101	120	86	69	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.72	N/A	N/A	+1.76	+0.77	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page