

RASHT, Iran, Islamic Republic of

WMO: 407190

Lat: 37.325N

Lon: 49.606E

Elev: -12

StdP: 101.47

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.0	0.2	-4.2	2.6	7.6	-2.0	3.2	6.1	9.7	12.8	8.1	11.6	1.3	270	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.8	33.7	24.7	32.2	24.5	31.2	24.2	26.6	30.9	26.0	30.1	25.3	29.3	2.9	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.3	20.4	29.0	24.8	19.8	28.5	24.1	18.9	27.8	83.5	31.1	80.3	30.4	77.5	29.3	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	5.4	4.5	-3.7	36.3	3.7	1.2	-6.4	37.1	-8.6	37.8	-10.7	38.5	-13.4	39.4		
(5)			-4.0	28.5	3.6	0.9	-6.6	29.1	-8.8	29.6	-10.8	30.1	-13.5	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	7.8	7.6	10.5	14.3	20.4	24.1	25.8	26.4	22.8	18.1	12.6	9.4		
	DBStd	7.48	3.58	3.38	3.67	3.64	2.75	2.28	2.09	2.13	2.65	3.02	3.26	3.45		
	HDD10.0	264	85	78	34	6	0	0	0	0	0	0	12	50		
	HDD18.3	1509	328	300	244	129	12	1	0	0	2	40	172	280		
	CDD10.0	2717	16	12	51	134	322	423	491	508	385	253	91	31		
	CDD18.3	919	1	0	3	8	76	173	233	250	137	34	2	2		
	CDH23.3	7557	6	10	59	87	396	1334	2186	2460	852	145	13	10		
	CDH26.7	2657	0	1	22	29	73	403	826	1037	228	34	2	1		
(14) Wind	WSAvg	1.6	1.9	1.8	1.9	1.8	1.7	1.7	1.5	1.5	1.5	1.4	1.4	1.7		
(15) Precipitation	PrecAvg	1265	115	105	95	67	42	40	54	63	145	183	187	144		
	PrecMax	1740	237	209	184	181	118	168	144	287	370	372	496	288		
	PrecMin	978	39	12	6	8	11	0	6	0	33	2	21	12		
	PrecStd	184	50	53	46	47	24	38	39	54	79	88	90	72		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.9	24.9	29.7	30.1	30.2	32.9	34.3	35.1	32.6	31.0	25.5	24.9		
		MCWB	11.9	12.9	16.1	17.9	21.4	24.2	25.3	24.1	24.9	18.0	15.5	13.7		
	2%	DB	20.1	18.1	23.1	25.2	28.2	31.2	33.0	34.0	30.7	26.3	22.1	21.8		
		MCWB	10.3	10.2	13.7	17.4	21.2	23.4	25.2	24.9	24.1	21.2	16.1	11.9		
	5%	DB	16.2	14.1	18.9	22.1	27.0	30.1	31.8	33.0	29.1	24.8	19.5	17.8		
		MCWB	9.4	9.8	13.0	16.7	20.7	23.0	24.7	24.8	23.5	20.6	15.9	11.4		
	10%	DB	12.8	11.9	15.2	19.9	25.6	29.1	30.8	31.9	27.9	23.1	17.8	14.1		
		MCWB	9.5	9.1	11.6	15.6	20.3	22.4	24.3	24.7	23.1	19.7	15.3	11.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	13.4	17.0	20.6	23.8	26.1	27.6	27.6	26.2	23.4	18.9	15.4		
		MCDB	20.8	21.2	23.4	26.6	28.0	30.0	31.8	32.5	30.3	26.7	21.7	20.6		
	2%	WB	11.5	11.5	14.7	18.4	22.5	24.9	26.5	26.7	25.1	22.0	17.5	13.5		
		MCDB	17.0	16.9	21.7	23.2	26.4	29.4	30.6	31.3	28.9	24.7	19.9	17.8		
	5%	WB	10.5	10.4	13.1	17.0	21.6	24.1	25.8	26.2	24.3	21.0	16.3	12.4		
		MCDB	14.3	13.2	18.0	21.2	25.4	28.3	29.8	30.5	27.7	23.7	18.4	15.6		
	10%	WB	9.7	9.6	11.8	15.7	20.8	23.4	25.1	25.6	23.6	20.2	15.3	11.5		
		MCDB	12.0	11.1	15.2	19.0	24.2	27.2	29.0	29.6	26.6	22.6	17.3	14.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	7.1	8.0	8.1	8.0	8.1	8.2	8.8	7.5	7.4	7.6	7.5		
		MCDBR	14.6	12.8	15.5	12.8	10.5	9.8	10.2	11.2	10.1	10.5	11.3	12.3		
	5% WB	MCWBR	7.0	7.2	7.5	6.5	4.6	4.2	4.3	4.4	4.7	5.8	6.6	6.2		
		MCWBR	11.0	10.1	13.7	11.3	9.3	8.8	9.1	9.6	9.1	9.1	9.5	9.8		
(40) Clear-Sky Solar Irradiance	taub		0.392	0.436	0.489	0.574	0.559	0.558	0.603	0.575	0.548	0.501	0.430	0.394		
		taud	2.188	2.072	1.971	1.823	1.904	1.930	1.852	1.912	1.952	2.028	2.154	2.205		
	Ebn at Noon		763	774	770	728	749	748	710	719	709	698	712	730		
		Edh at Noon	110	139	169	207	194	189	203	187	171	144	113	102		
(44) All-Sky Solar Radiation	RadAvg		1.99	2.57	3.45	4.46	5.82	6.53	6.33	5.69	4.35	3.03	2.14	1.74		
	RadStd		0.21	0.35	0.38	0.53	0.38	0.38	0.44	0.58	0.32	0.38	0.27	0.22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.40	N/A	N/A	+0.98	+0.43	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page