

SAQQEZ, Iran, Islamic Republic of

WMO: 407270

Lat: 36.250N

Lon: 46.267E

Elev: 4898

StdP: 12.27

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.1	(c) 4.4	(d) -9.2	(e) 4.0	(f) -2.8	(g) -1.1	(h) 6.2	(i) 7.4	(j) 23.4	(k) 31.6	(l) 20.4	(m) 39.0	(n) 1.5	(o) 140	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.3	97.4	62.2	95.0	61.6	92.5	60.7	64.7	90.9	63.5	90.0	62.3	88.7	11.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.6	76.2	76.6	53.0	71.7	74.7	51.4	67.6	72.6	32.4	90.9	31.4	90.0	30.5	89.2	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	21.0	17.9	-8.1	101.2	10.3	1.0	-15.6	101.9	-21.6	102.5	-27.4	103.0	-35.0	103.7
			-9.6	66.8	10.1	1.1	-16.8	67.6	-22.7	68.2	-28.4	68.9	-35.7	69.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.8	27.8	33.6	42.8	50.9	59.2	68.5	75.9	75.6	66.8	56.1	42.6	32.7
	DBStd	17.58	10.72	9.31	6.95	5.82	4.67	4.34	4.07	3.81	4.73	5.78	7.05	9.73
	HDD50	2240	689	458	242	58	1	0	0	0	0	16	237	539
	HDD65	5333	1154	878	689	424	188	16	0	0	31	279	672	1002
	CDD50	3262	0	0	19	83	286	556	802	792	503	205	15	1
	CDD65	880	0	0	0	0	7	122	337	327	84	3	0	0
	CDH74	15175	0	0	1	34	313	2458	5084	5114	2000	171	0	0
	CDH80	7497	0	0	0	4	36	1008	2808	2853	777	11	0	0
Wind	WSAvg	6.4	4.7	5.8	7.9	7.5	7.5	7.2	7.1	6.8	6.1	6.1	4.9	4.6
Precipitation	PrecAvg	19.8	2.6	2.5	2.9	2.9	1.4	0.2	0.3	0.1	0.1	1.3	2.7	2.6
	PrecMax	33.2	6.0	7.4	5.9	6.0	4.9	1.6	1.1	0.5	0.7	5.3	10.4	8.6
	PrecMin	12.0	1.3	1.0	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
	PrecStd	5.4	1.1	1.2	1.1	1.5	1.2	0.4	0.3	0.1	0.2	1.3	2.6	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	57.1	71.8	78.2	84.2	95.4	100.3	99.5	93.7	81.7	67.4	59.5
		MCWB	39.7	42.7	48.9	53.6	57.7	61.9	63.7	62.0	59.3	55.4	48.6	43.7
	2%	DB	47.5	53.4	65.8	72.3	80.3	91.5	98.1	97.3	90.5	78.6	62.9	54.1
		MCWB	39.2	41.5	47.2	52.6	56.9	60.5	62.8	61.7	58.2	53.8	46.8	42.1
	5%	DB	44.3	49.8	60.5	68.7	77.6	88.5	95.6	95.2	87.8	75.6	59.3	49.7
		MCWB	37.6	40.1	45.3	51.4	56.0	59.5	62.1	61.3	57.3	53.1	45.6	40.9
	10%	DB	41.0	46.4	56.5	65.2	74.8	86.1	92.7	92.9	84.7	72.1	55.4	45.8
		MCWB	35.8	38.8	43.6	49.9	55.1	59.0	61.4	60.5	56.2	51.8	44.8	39.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.4	45.5	50.3	56.6	60.9	64.5	66.6	65.7	61.9	57.5	51.9	46.4
		MCDB	48.8	53.2	63.9	71.7	78.1	88.7	92.7	90.8	88.2	75.6	60.6	54.9
	2%	WB	40.2	42.9	48.4	54.5	58.9	62.7	65.2	64.4	60.0	55.4	49.7	43.6
		MCDB	45.6	50.4	63.0	67.9	76.1	87.3	91.7	90.5	85.0	73.3	57.9	51.0
	5%	WB	38.2	41.1	46.6	52.6	57.4	61.3	64.0	63.1	58.6	54.0	47.7	41.5
		MCDB	43.5	48.2	59.0	65.8	74.1	85.0	90.8	90.3	83.4	70.6	55.8	47.8
	10%	WB	36.1	39.4	44.5	51.0	56.0	60.0	62.8	62.0	57.3	52.8	45.7	39.7
		MCDB	40.6	45.6	55.0	63.1	72.1	83.1	89.3	89.6	82.0	68.4	53.8	45.1
Mean Daily Temperature Range	5% DB	MDBR	18.0	19.3	21.5	24.1	27.5	33.8	33.3	34.8	35.3	28.3	22.3	19.3
		MCDBR	20.5	25.0	30.1	31.8	32.3	37.4	36.1	37.7	38.6	34.8	30.3	26.0
		MCWBR	13.4	14.7	15.5	15.2	14.1	15.0	14.5	15.5	18.0	17.8	17.2	16.2
	5% WB	MCDBR	17.7	20.3	25.0	27.0	28.8	34.3	33.2	33.0	34.7	29.0	22.6	21.5
		MCWBR	11.8	12.6	13.6	13.8	13.4	14.6	14.3	14.7	16.9	15.1	13.2	14.0
Clear-Sky Solar Irradiance	taub		0.300	0.334	0.384	0.452	0.449	0.403	0.433	0.403	0.357	0.375	0.321	0.298
	taud		2.364	2.259	2.126	1.962	2.001	2.157	2.074	2.157	2.280	2.194	2.364	2.400
	Ebn at Noon		283	284	278	264	266	278	269	275	284	265	272	277
	Edh at Noon		29	37	46	57	56	48	52	47	39	39	29	27
All-Sky Solar Radiation	RadAvg		832	1121	1413	1744	2172	2622	2507	2317	1938	1341	908	719
	RadStd		80	126	130	158	142	120	65	68	97	100	119	93

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	-3.22	N/A	+2.25	N/A	-0.68	N/A	N/A	N/A	N/A

Nomenclature: See separate page