

SAQQEZ, Iran, Islamic Republic of

WMO: 407270

Lat: 36.250N

Lon: 46.267E

Elev: 1493

StdP: 84.63

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.1	-15.3	-22.9	0.6	-19.3	-18.4	0.9	-13.7	10.5	-0.2	9.1	3.9	0.7	140	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	36.4	16.8	35.0	16.4	33.6	15.9	18.2	32.7	17.5	32.2	16.9	31.5	4.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.6	10.9	24.8	11.6	10.2	23.7	10.8	9.7	22.6	57.6	32.7	55.2	32.2	53.0	31.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.4	8.0	DB	-22.3	38.4	5.7	0.6	-26.4	38.8	-29.8	39.1	-33.0	39.4	-37.2	39.8	(4)
(5)			WB	-23.1	19.4	5.6	0.6	-27.1	19.8	-30.4	20.1	-33.6	20.5	-37.6	20.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	-2.3	0.9	6.0	10.5	15.1	20.3	24.4	24.2	19.3	13.4	5.9	0.4	(6)	
	DBStd	9.77	5.95	5.17	3.86	3.24	2.59	2.41	2.26	2.12	2.63	3.21	3.92	5.41	(7)	
	HDD10.0	1244	383	254	134	32	1	0	0	0	0	9	132	299	(8)	
	HDD18.3	2963	641	488	383	236	104	9	0	0	17	155	373	557	(9)	
	CDD10.0	1812	0	0	11	46	159	309	446	440	279	114	8	1	(10)	
	CDD18.3	489	0	0	0	0	4	68	187	182	47	2	0	0	(11)	
	CDH23.3	8431	0	0	1	19	174	1366	2824	2841	1111	95	0	0	(12)	
	CDH26.7	4165	0	0	0	2	20	560	1560	1585	432	6	0	0	(13)	
(14) Wind	WSAvg	2.8	2.1	2.6	3.5	3.3	3.4	3.2	3.2	3.0	2.7	2.7	2.2	2.1	(14)	
(15) Precipitation	PrecAvg	502	65	63	73	74	35	6	7	2	3	32	69	66	(15)	
	PrecMax	843	153	189	149	152	125	40	29	13	17	134	265	219	(16)	
	PrecMin	306	33	26	31	1	0	0	0	0	0	0	1	7	(17)	
	PrecStd	138	28	31	28	37	31	9	7	3	5	33	66	47	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	13.9	22.1	25.7	29.0	35.2	38.0	37.5	34.3	27.6	19.7	15.3	(19)	
		MCWB	4.3	6.0	9.4	12.0	14.3	16.6	17.6	16.7	15.2	13.0	9.2	6.5	(20)	
	2%	DB	8.6	11.9	18.8	22.4	26.8	33.1	36.7	36.3	32.5	25.9	17.2	12.3	(21)	
		MCWB	4.0	5.3	8.4	11.5	13.8	15.8	17.1	16.5	14.6	12.1	8.2	5.6	(22)	
	5%	DB	6.8	9.9	15.8	20.4	25.3	31.4	35.3	35.1	31.0	24.2	15.2	9.8	(23)	
		MCWB	3.1	4.5	7.4	10.8	13.3	15.3	16.7	16.3	14.0	11.7	7.5	4.9	(24)	
	10%	DB	5.0	8.0	13.6	18.5	23.8	30.0	33.7	33.8	29.3	22.3	13.0	7.7	(25)	
		MCWB	2.1	3.8	6.4	10.0	12.8	15.0	16.3	15.8	13.5	11.0	7.1	4.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.3	7.5	10.2	13.7	16.1	18.1	19.2	18.7	16.6	14.2	11.1	8.0	(27)	
		MCDB	9.4	11.8	17.7	22.1	25.6	31.5	33.7	32.7	31.2	24.2	15.9	12.7	(28)	
	2%	WB	4.5	6.1	9.1	12.5	14.9	17.1	18.5	18.0	15.6	13.0	9.8	6.4	(29)	
		MCDB	7.6	10.2	17.2	19.9	24.5	30.7	33.2	32.5	29.5	23.0	14.4	10.5	(30)	
	5%	WB	3.4	5.1	8.1	11.5	14.1	16.3	17.8	17.3	14.8	12.2	8.7	5.3	(31)	
		MCDB	6.4	9.0	15.0	18.8	23.4	29.5	32.6	32.4	28.6	21.4	13.2	8.8	(32)	
	10%	WB	2.3	4.1	6.9	10.6	13.3	15.6	17.1	16.7	14.1	11.6	7.6	4.3	(33)	
		MCDB	4.8	7.6	12.8	17.3	22.3	28.4	31.8	32.0	27.8	20.2	12.1	7.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	10.7	11.9	13.4	15.3	18.8	18.5	19.3	19.6	15.7	12.4	10.7	(35)	
		MCDBR	11.4	13.9	16.7	17.6	18.0	20.8	20.0	21.0	21.5	19.4	16.8	14.5	(36)	
	5% WB	MCWBR	7.4	8.2	8.6	8.4	7.8	8.3	8.1	8.6	10.0	9.9	9.6	9.0	(37)	
		MCWBR	9.8	11.3	13.9	15.0	16.0	19.1	18.4	18.4	19.3	16.1	12.6	12.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.300	0.334	0.384	0.452	0.449	0.403	0.433	0.403	0.357	0.375	0.321	0.298	(40)	
		taud	2.364	2.259	2.126	1.962	2.001	2.157	2.074	2.157	2.280	2.194	2.364	2.400	(41)	
	Ebn at Noon		893	896	877	833	840	877	848	868	894	835	859	872	(42)	
		Edh at Noon	92	116	145	181	177	151	163	147	123	122	92	84	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.62	3.54	4.45	5.50	6.85	8.27	7.90	7.30	6.11	4.23	2.86	2.27	(44)	
	RadStd		0.25	0.40	0.41	0.50	0.45	0.38	0.20	0.21	0.31	0.32	0.38	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	-1.79	N/A	+1.25	N/A	-0.38	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page