

NOSHAHR, Iran, Islamic Republic of

WMO: 407340

Lat: 36.6614N

Lon: 51.4663E

Elev: -21

StdP: 101.58

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.9	2.2	-2.8	3.0	4.2	-1.0	3.5	4.2	10.4	8.1	8.6	7.4	1.6	180	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	31.8	26.2	31.0	25.9	30.1	25.3	27.0	30.7	26.4	30.0	25.9	29.4	3.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.3	30.1	25.2	20.2	29.3	24.8	19.8	28.9	85.6	30.6	82.6	30.2	79.8	29.6	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	6.7	5.5		-0.2	32.7	1.7	1.0	-1.5	33.4	-2.5	34.0	-3.4	34.5	-4.6	35.2
			DB	-1.3	28.1	1.5	1.2	-2.4	29.0	-3.3	29.7	-4.1	30.3	-5.2	31.2
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	8.3	8.0	10.5	13.7	19.6	24.1	26.0	26.2	23.4	18.9	13.5	10.1		
	DBStd	7.12	2.44	2.43	2.85	2.93	2.52	1.93	1.82	1.86	2.08	2.57	2.97	2.28		
	HDD10.0	186	63	63	24	3	0	0	0	0	0	0	7	27		
	HDD18.3	1431	312	290	246	142	16	0	0	0	0	23	148	256		
	CDD10.0	2706	9	6	38	116	297	423	496	503	403	276	110	29		
	CDD18.3	911	0	0	2	3	54	173	237	244	154	41	1	0		
	CDH23.3	7159	0	0	16	18	166	1249	2232	2405	953	118	3	0		
	CDH26.7	1984	0	0	5	4	13	246	683	847	172	14	0	0		
(14) Wind	WSAvg	2.2	2.0	2.3	2.6	2.4	2.3	2.2	2.2	2.1	2.0	2.0	2.0	1.9		
(15) Precipitation	PrecAvg	1116	84	80	82	58	42	43	52	46	136	201	166	111		
	PrecMax	1529	162	156	147	124	96	167	207	173	297	490	325	291		
	PrecMin	643	25	23	10	4	18	2	8	0	19	20	0	4		
	PrecStd	188	32	33	35	32	19	36	48	38	73	109	76	64		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	18.0	25.0	26.1	28.1	30.8	32.2	32.9	31.0	28.4	23.2	20.0		
		MCWB	12.0	11.0	14.8	17.0	21.7	25.3	26.5	26.5	26.1	21.8	18.2	14.4		
	2%	DB	15.0	14.3	19.2	21.9	26.2	29.9	31.7	31.9	29.6	25.9	21.0	17.2		
		MCWB	11.3	10.2	13.1	16.9	21.3	24.6	26.2	26.2	25.1	22.1	17.8	13.4		
	5%	DB	13.2	12.6	16.2	19.7	25.1	29.0	30.9	31.1	28.7	24.3	19.2	15.2		
		MCWB	10.3	9.7	12.6	16.0	21.1	23.9	25.7	26.1	24.4	20.8	16.2	12.6		
	10%	DB	12.1	11.5	14.0	18.0	24.0	28.1	30.0	30.6	27.6	23.2	18.2	14.1		
		MCWB	9.7	9.4	11.5	15.2	20.5	23.5	25.2	25.9	23.6	20.0	15.5	11.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.8	12.2	15.6	18.6	23.5	26.2	27.9	28.0	26.7	23.7	19.6	15.6		
		MCDB	15.8	15.2	22.4	23.6	26.4	29.5	31.4	31.1	30.1	26.4	22.0	18.4		
	2%	WB	11.7	11.0	13.8	17.3	22.4	25.5	26.9	27.2	25.6	22.4	18.1	14.0		
		MCDB	14.1	13.1	18.4	20.9	25.3	28.9	30.4	30.8	28.9	24.9	20.2	16.3		
	5%	WB	10.9	10.3	12.6	16.2	21.6	24.8	26.3	26.6	24.7	21.5	17.1	13.0		
		MCDB	12.8	11.8	15.6	18.8	24.2	28.1	29.7	30.3	27.8	23.8	19.1	15.0		
	10%	WB	10.3	9.8	11.7	15.4	20.7	24.0	25.7	26.1	24.0	20.6	15.9	12.2		
		MCDB	11.8	11.0	13.9	17.6	23.3	27.5	29.1	29.8	26.8	22.9	17.8	14.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	5.5	5.6	5.4	5.7	6.0	5.9	6.5	6.1	6.8	7.0	6.9		
		MCDBR	8.8	8.2	10.8	8.8	7.6	7.0	7.0	7.7	7.3	8.1	8.4	9.0		
	5% WB	MCWBR	6.6	5.7	5.8	5.3	5.0	4.6	4.7	5.5	5.2	5.7	6.1	7.0		
		MCWBR	7.9	6.2	9.1	7.6	7.0	6.6	6.6	7.4	6.8	7.7	7.5	8.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.399	0.449	0.512	0.596	0.598	0.607	0.660	0.625	0.583	0.534	0.454	0.404		
		taud	2.130	2.011	1.899	1.775	1.817	1.833	1.754	1.820	1.883	1.953	2.073	2.137		
	Ebn at Noon	Ebn at Noon	758	763	750	712	720	712	671	683	683	671	689	720		
		Edh at Noon	117	149	183	218	212	209	225	206	184	157	124	110		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.19	2.76	3.74	4.80	5.94	6.61	6.29	5.88	4.71	3.45	2.36	1.92		
	RadStd	RadStd	0.19	0.31	0.38	0.58	0.32	0.40	0.44	0.58	0.28	0.30	0.26	0.25		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	+0.46	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page