

GORGAN, Iran, Islamic Republic ofWMO: **407380**Lat: **36.9049N**Lon: **54.4131E**Elev: **43**StdP: **14.67**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.6	31.8	24.9	19.0	35.0	28.3	22.3	36.3	24.2	51.0	21.7	47.1	1.4	350	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.8	98.7	75.2	96.5	75.4	93.9	75.0	80.4	91.4	79.1	89.9	78.0	88.6	8.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.3	142.2	86.6	76.1	136.4	85.4	75.0	131.6	84.4	44.0	91.9	42.7	89.8	41.5	88.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	22.5	18.7	16.1	25.4	106.1	3.5	3.8	22.9	108.8	20.8	111.1	18.9	113.3	16.3	116.1	
(5)				24.7	83.3	3.4	1.6	22.2	84.5	20.2	85.4	18.3	86.3	15.8	87.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.5	45.6	46.9	53.3	59.5	71.9	79.9	83.4	83.7	77.5	67.4	55.7	48.4
	DBStd	14.98	5.44	5.59	6.27	5.64	5.74	4.29	3.68	3.43	4.58	6.16	6.99	5.24
	HDD50	416	155	111	29	3	0	0	0	0	0	24	94	
	HDD65	2517	601	507	367	181	11	0	0	0	45	289	516	
	CDD50	5723	19	24	133	289	679	896	1035	1045	826	541	193	43
	CDD65	2351	0	0	6	17	226	446	570	580	376	121	9	0
	CDH74	24995	1	5	138	262	2066	4679	6630	6828	3380	922	80	4
	CDH80	11533	0	0	38	80	907	2237	3165	3418	1381	288	19	0
Wind	WSAvg	6.0	4.9	5.8	6.7	6.4	7.2	7.7	7.5	6.9	6.1	4.6	4.1	4.3
Precipitation	PrecAvg	18.1	1.7	1.7	2.2	1.6	1.1	0.8	0.6	0.5	1.6	1.7	2.7	1.7
	PrecMax	24.0	3.9	4.4	4.1	3.7	2.9	2.5	3.5	1.9	5.5	4.4	5.2	4.4
	PrecMin	10.5	0.3	0.2	1.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.4	0.6
	PrecStd	3.4	1.0	0.9	0.8	0.9	0.8	0.7	0.8	0.6	1.1	1.1	1.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.2	73.2	85.6	89.4	98.9	100.5	103.0	101.3	96.8	94.6	82.4	73.0
		MCWB	56.7	59.1	65.9	69.2	70.2	74.3	77.5	76.9	74.2	67.2	62.2	58.3
	2%	DB	64.1	65.4	77.4	80.6	93.5	96.7	98.4	98.3	93.1	86.3	75.0	66.0
		MCWB	52.7	53.8	61.5	65.8	69.3	73.7	77.0	77.0	74.2	67.6	61.2	55.1
	5%	DB	58.5	60.7	71.4	75.5	89.2	93.5	95.1	95.4	90.1	82.5	70.8	60.9
		MCWB	51.1	52.1	59.8	63.4	69.5	72.8	76.8	76.9	73.6	67.7	60.3	53.9
	10%	DB	55.2	56.8	64.7	71.0	84.4	91.1	92.3	93.4	87.8	78.9	67.3	57.5
		MCWB	49.6	50.1	56.1	61.7	68.6	72.9	76.0	76.7	73.1	66.8	59.1	52.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.2	59.8	69.0	71.4	74.9	79.0	82.3	82.2	79.1	72.6	66.4	59.6
		MCDB	67.9	67.8	80.5	83.5	90.1	92.0	94.2	93.8	90.2	82.6	76.9	68.6
	2%	WB	54.3	55.2	63.5	67.2	72.5	77.2	80.4	80.7	77.2	70.8	63.8	56.7
		MCDB	61.1	62.9	75.0	78.9	86.1	89.7	91.3	91.8	87.5	79.9	71.9	63.4
	5%	WB	51.9	52.7	59.8	64.5	70.9	75.7	78.9	79.5	75.8	69.6	61.8	54.7
		MCDB	57.1	59.1	69.4	73.7	83.2	87.6	89.5	90.3	86.1	78.2	68.7	60.3
	10%	WB	50.1	50.9	56.6	62.1	69.5	74.4	77.8	78.4	74.6	68.2	59.7	52.9
		MCDB	54.3	55.2	63.9	69.3	81.1	86.0	88.1	88.9	84.4	76.8	65.5	57.4
Mean Daily Temperature Range	5% DB	MDBR	18.4	17.4	18.9	18.5	22.0	20.7	17.3	18.8	18.8	20.3	18.8	18.0
		MCDBR	26.1	27.3	32.9	30.1	32.1	26.4	22.7	23.5	23.4	26.8	26.0	25.0
		MCWBR	17.5	17.6	19.6	16.9	12.2	9.0	7.9	9.6	9.6	11.9	13.7	16.7
	5% WB	MCDBR	23.3	24.0	30.0	26.7	26.2	22.3	19.2	20.3	19.8	21.5	19.9	21.9
		MCWBR	16.5	16.4	18.7	15.9	11.3	8.3	7.6	9.1	9.1	10.9	11.3	15.1
Clear-Sky Solar Irradiance	taub	0.406	0.458	0.533	0.606	0.619	0.620	0.657	0.602	0.569	0.541	0.459	0.408	
	taud	2.106	1.969	1.806	1.708	1.719	1.742	1.692	1.795	1.837	1.870	2.023	2.113	
	Ebn at Noon	237	238	231	223	223	223	213	221	219	209	215	226	
	Edh at Noon	38	49	63	74	74	73	76	67	61	54	41	36	
All-Sky Solar Radiation	RadAvg	775	1003	1339	1662	2056	2363	2262	2127	1752	1294	892	689	
	RadStd	49	100	96	96	167	91	102	114	142	69	60	54	59