

GORGAN, Iran, Islamic Republic ofWMO: **407380**Lat: **36.9049N**Lon: **54.4131E**Elev: **13**StdP: **101.17**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.9	-0.1	-4.0	2.7	1.6	-2.1	3.2	2.4	10.8	10.5	9.7	8.4	0.6	350	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	37.1	24.0	35.8	24.1	34.4	23.9	26.9	33.0	26.2	32.2	25.6	31.4	3.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.3	30.3	24.5	19.5	29.7	23.9	18.8	29.1	84.5	33.3	81.3	32.1	78.7	31.3	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.1	8.4	7.2	-3.7	41.2	1.9	2.1	-5.1	42.7	-6.2	43.9	-7.3	45.1	-8.7	46.7		
			-4.0	28.5	1.9	0.9	-5.4	29.2	-6.5	29.7	-7.6	30.2	-9.0	30.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	7.6	8.3	11.9	15.3	22.2	26.6	28.6	28.7	25.3	19.7	13.1	9.1
	DBStd	8.32	3.02	3.10	3.49	3.14	3.19	2.38	2.04	1.90	2.55	3.42	3.88	2.91
	HDD10.0	231	86	62	16	2	0	0	0	0	0	13	52	
	HDD18.3	1398	334	282	204	101	6	0	0	0	25	161	287	
	CDD10.0	3179	11	13	74	161	377	498	575	581	459	301	107	24
	CDD18.3	1306	0	0	3	9	126	248	317	322	209	67	5	0
	CDH23.3	13886	1	3	77	146	1148	2599	3683	3793	1878	512	44	2
	CDH26.7	6407	0	0	21	44	504	1243	1758	1899	767	160	11	0
Wind	WSAvg	2.7	2.2	2.6	3.0	2.8	3.2	3.4	3.1	2.7	2.1	1.8	1.9	
Precipitation	PrecAvg	460	44	44	57	40	29	21	14	13	40	43	69	42
	PrecMax	609	99	113	104	94	73	63	90	48	140	112	131	113
	PrecMin	267	7	4	25	1	0	0	0	5	1	10	15	
	PrecStd	87	26	24	21	24	20	18	20	14	28	28	31	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	22.9	29.8	31.9	37.2	38.1	39.4	38.5	36.0	34.8	28.0	22.8
		MCWB	13.7	15.0	18.8	20.6	21.2	23.5	25.3	24.9	23.5	19.6	16.8	14.6
	2%	DB	17.8	18.5	25.2	27.0	34.1	36.0	36.9	36.8	34.0	30.1	23.9	18.9
		MCWB	11.5	12.1	16.4	18.8	20.7	23.2	25.0	25.0	23.4	19.8	16.2	12.8
	5%	DB	14.7	15.9	21.9	24.2	31.8	34.2	35.1	35.2	32.3	28.0	21.5	16.1
		MCWB	10.6	11.2	15.4	17.4	20.8	22.7	24.9	24.9	23.1	19.9	15.7	12.2
	10%	DB	12.9	13.8	18.1	21.7	29.1	32.8	33.5	34.1	31.0	26.1	19.6	14.2
		MCWB	9.8	10.0	13.4	16.5	20.4	22.7	24.4	24.8	22.8	19.4	15.1	11.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	15.4	20.6	21.9	23.9	26.1	28.0	27.9	26.2	22.5	19.1	15.3
		MCDB	20.0	19.9	27.0	28.6	32.3	33.4	34.6	34.3	32.4	28.1	24.9	20.3
	2%	WB	12.4	12.9	17.5	19.5	22.5	25.1	26.9	27.0	25.1	21.6	17.7	13.7
		MCDB	16.1	17.2	23.9	26.1	30.1	32.0	32.9	33.2	30.8	26.6	22.1	17.4
	5%	WB	11.1	11.5	15.4	18.0	21.6	24.3	26.1	26.4	24.3	20.9	16.5	12.6
		MCDB	14.0	15.1	20.8	23.2	28.5	30.9	32.0	32.4	30.0	25.7	20.4	15.7
	10%	WB	10.1	10.5	13.7	16.7	20.8	23.6	25.4	25.8	23.7	20.1	15.4	11.6
		MCDB	12.4	12.9	17.7	20.7	27.3	30.0	31.2	31.6	29.1	24.9	18.6	14.1
Mean Daily Temperature Range	5% DB	MDBR	10.2	9.7	10.5	10.3	12.2	11.5	9.6	10.4	10.4	11.3	10.5	10.0
		MCDBR	14.5	15.1	18.3	16.7	17.8	14.7	12.6	13.0	13.0	14.9	14.5	13.9
		MCWBR	9.7	9.8	10.9	9.4	6.8	5.0	4.4	5.3	5.3	6.6	7.6	9.3
	5% WB	MCDBR	12.9	13.4	16.6	14.8	14.6	12.4	10.7	11.3	11.0	11.9	11.1	12.2
		MCWBR	9.2	9.1	10.4	8.8	6.3	4.6	4.2	5.1	5.0	6.1	6.3	8.4
Clear-Sky Solar Irradiance	taub	0.406	0.458	0.533	0.606	0.619	0.620	0.657	0.602	0.569	0.541	0.459	0.408	
	taud	2.106	1.969	1.806	1.708	1.719	1.742	1.692	1.795	1.837	1.870	2.023	2.113	
	Ebn at Noon	746	750	729	703	704	703	672	698	691	659	678	711	
	Edh at Noon	120	155	200	233	234	229	239	211	192	170	130	112	
All-Sky Solar Radiation	RadAvg	2.44	3.16	4.22	5.24	6.48	7.45	7.13	6.71	5.52	4.08	2.81	2.17	
	RadStd	0.15	0.32	0.30	0.53	0.29	0.32	0.36	0.45	0.22	0.19	0.17	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.31	N/A	N/A	+0.57	+0.31	+0.32	N/A	N/A	N/A	N/A

Nomenclature: See separate page