

SARAKHS, Iran, Islamic Republic of

WMO: 407410

Lat: **36.5368N**Lon: **61.1490E**Elev: **771**StdP: **14.29**Time Zone: **3.50 (IRN)**Period: **00-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.3	24.8	7.0	8.1	23.4	14.0	11.5	40.0	33.9	53.0	28.1	55.9	4.2	300	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.9	107.8	69.1	105.6	68.1	102.8	67.2	73.2	99.2	71.3	98.2	69.8	96.1	11.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	92.7	85.0	62.0	85.4	83.2	59.9	79.1	81.5	37.3	99.1	35.6	98.2	34.2	96.0	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	28.4	22.5	18.3	DB	16.3	112.7	8.3	3.3	10.3	115.1	5.4	117.1	0.8	118.9	-5.2	121.4
(5)				WB	13.5	76.3	10.0	3.0	6.3	78.5	0.4	80.2	-5.2	81.9	-12.5	84.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	42.7	46.0	56.3	65.7	78.3	86.3	89.0	85.1	76.8	65.3	52.8	45.1
	DBStd	18.14	10.67	9.75	9.21	8.78	5.57	4.20	4.26	4.60	5.62	8.58	9.40	8.84
	HDD50	770	268	172	42	5	0	0	0	0	0	4	75	204
	HDD65	2721	691	533	297	96	1	0	0	0	2	105	378	618
	CDD50	6573	43	60	237	475	876	1090	1210	1089	803	478	159	53
	CDD65	3050	1	2	27	116	412	640	745	624	355	114	12	2
	CDH74	44666	11	32	396	1488	5444	9906	11924	9247	4611	1431	155	21
	CDH80	27326	0	6	134	658	3038	6406	8000	5912	2511	615	45	1
Wind	WSAvg	6.5	5.8	6.2	7.0	6.3	7.7	8.7	9.1	7.2	5.3	4.8	4.3	5.3
Precipitation	PrecAvg	8.0	1.2	1.3	1.8	1.5	0.5	0.0	0.0	0.0	0.0	0.2	0.5	0.9
	PrecMax	12.3	3.6	3.1	4.0	4.3	1.9	0.4	0.0	0.2	0.7	1.6	2.1	2.4
	PrecMin	5.0	0.2	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.8	0.8	0.8	0.9	1.0	0.6	0.1	0.0	0.0	0.1	0.3	0.5	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	78.5	89.8	98.3	105.5	109.7	112.1	109.4	104.1	98.3	85.8	76.8
		MCWB	53.5	56.8	61.9	64.1	66.7	68.3	70.0	69.8	65.4	63.5	60.0	54.3
	2%	DB	69.6	71.5	83.8	91.8	100.8	106.1	109.1	105.6	100.0	91.5	78.1	69.7
		MCWB	51.1	53.6	59.1	63.9	65.9	67.5	70.0	67.9	65.2	62.4	56.9	51.6
	5%	DB	63.0	66.1	77.8	87.8	97.1	103.8	106.0	102.9	95.8	86.4	73.0	64.1
		MCWB	48.6	51.5	57.8	62.1	65.1	66.7	69.1	67.0	63.8	60.4	54.7	49.6
	10%	DB	57.5	61.1	72.8	82.6	93.6	101.2	103.7	100.4	92.8	82.3	68.0	58.9
		MCWB	46.3	49.4	56.0	60.6	64.3	66.5	68.4	66.3	63.0	59.2	53.3	47.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.6	57.6	63.9	69.4	70.7	72.1	76.7	75.3	70.0	66.1	61.8	55.7
		MCDB	70.6	73.4	81.4	88.1	94.8	100.5	101.2	99.5	92.7	89.9	80.4	72.3
	2%	WB	51.6	54.9	60.7	66.3	68.6	70.6	74.1	72.3	67.6	63.9	58.6	52.9
		MCDB	66.5	69.5	78.0	83.9	91.4	98.9	99.9	98.6	92.4	86.3	73.1	66.6
	5%	WB	49.5	52.5	59.0	64.2	67.6	69.4	72.2	69.8	66.0	62.3	55.9	50.5
		MCDB	61.5	62.9	74.7	82.9	90.2	97.1	98.7	95.5	91.4	83.5	69.1	62.0
	10%	WB	47.1	50.3	57.1	62.3	66.3	68.2	70.5	68.0	64.4	60.4	54.2	48.3
		MCDB	56.7	59.5	70.8	78.9	88.1	95.6	97.3	95.8	89.0	78.9	66.1	57.4
Mean Daily Temperature Range	5% DB	MDBR	17.8	18.6	20.9	23.7	27.0	27.2	26.9	28.5	29.3	26.5	20.9	18.0
		MCDBR	27.3	27.9	31.0	32.8	32.8	31.7	30.4	31.6	33.6	33.0	29.2	26.9
		MCWBR	13.8	13.7	12.5	12.0	10.5	10.3	10.5	11.4	12.9	14.2	13.9	13.6
	5% WB	MCDBR	24.7	24.2	27.1	27.3	27.3	25.5	25.1	26.7	28.5	28.0	24.7	24.0
		MCWBR	13.1	12.9	12.0	11.1	9.5	9.4	9.9	11.6	11.6	12.6	12.3	12.8
Clear-Sky Solar Irradiance	taub	0.391	0.440	0.512	0.547	0.555	0.553	0.540	0.494	0.462	0.483	0.447	0.395	
	taud	2.088	1.965	1.816	1.784	1.785	1.779	1.811	1.896	1.944	1.884	1.958	2.078	
	Ebn at Noon	242	244	238	238	239	239	241	249	249	226	218	230	
	Edh at Noon	39	49	63	69	69	70	67	61	55	53	44	37	
All-Sky Solar Radiation	RadAvg	732	1006	1364	1793	2263	2577	2533	2353	1955	1381	898	685	
	RadStd	65	120	116	178	84	71	44	56	46	74	82	70	

Historical Trends

	DBAvg	Heating		Cooling		
--	-------	---------	--	---------	--	--