

SARAKHS, Iran, Islamic Republic of

WMO: 407410

Lat: 36.5368N

Lon: 61.1490E

Elev: 235

StdP: 98.53

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.2	-4.0	-13.9	1.2	-4.8	-10.0	1.6	4.4	15.2	11.7	12.5	13.3	1.9	300	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	42.1	20.6	40.9	20.0	39.3	19.5	22.9	37.3	21.8	36.8	21.0	35.6	5.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	13.2	29.4	16.7	12.2	28.4	15.5	11.3	27.5	68.9	37.3	64.8	36.8	61.6	35.5	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.7	10.1	8.2	-8.7	44.8	4.6	1.9	-12.1	46.2	-14.8	47.3	-17.3	48.3	-20.7	49.6		
			-10.3	24.6	5.6	1.7	-14.3	25.8	-17.6	26.8	-20.7	27.7	-24.7	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	6.0	7.8	13.5	18.7	25.7	30.2	31.7	29.5	24.9	18.5	11.6	7.3
	DBStd	10.08	5.93	5.42	5.12	4.88	3.09	2.33	2.36	2.56	3.12	4.77	5.22	4.91
	HDD10.0	428	149	96	23	3	0	0	0	0	0	2	42	113
	HDD18.3	1512	384	296	165	53	1	0	0	0	1	58	210	343
	CDD10.0	3652	24	33	132	264	487	606	672	605	446	266	88	29
	CDD18.3	1694	1	1	15	64	229	356	414	347	197	63	7	1
	CDH23.3	24814	6	18	220	827	3024	5503	6624	5137	2562	795	86	12
	CDH26.7	15181	0	3	74	366	1688	3559	4444	3284	1395	342	25	1
Wind	WSAvg	2.9	2.6	2.8	3.1	2.8	3.4	3.9	4.1	3.2	2.4	2.1	1.9	2.4
Precipitation	PrecAvg	203	31	33	45	38	13	0	0	1	4	12	24	
	PrecMax	312	92	80	102	108	49	10	1	5	19	40	54	61
	PrecMin	127	4	4	8	1	0	0	0	0	0	0	0	0
	PrecStd	45	21	20	23	26	15	2	0	1	3	8	13	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.8	32.1	36.8	40.8	43.1	44.5	43.0	40.1	36.8	29.9	24.9
		MCWB	11.9	13.8	16.6	17.9	19.3	20.2	21.1	21.0	18.6	17.5	15.5	12.4
	2%	DB	20.9	22.0	28.8	33.2	38.2	41.2	42.8	40.9	37.8	33.1	25.6	20.9
		MCWB	10.6	12.0	15.1	17.7	18.8	19.7	21.1	20.0	18.5	16.9	13.9	10.9
	5%	DB	17.2	18.9	25.4	31.0	36.2	39.9	41.1	39.4	35.5	30.2	22.8	17.8
		MCWB	9.2	10.8	14.3	16.7	18.4	19.3	20.6	19.5	17.6	15.8	12.6	9.8
	10%	DB	14.2	16.2	22.6	28.1	34.2	38.4	39.8	38.0	33.8	28.0	20.0	15.0
		MCWB	7.9	9.7	13.3	15.9	17.9	19.1	20.2	19.1	17.2	15.1	11.8	8.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	14.2	17.7	20.8	21.5	22.3	24.8	24.1	21.1	18.9	16.6	13.2
		MCDB	21.4	23.0	27.4	31.2	34.9	38.1	38.5	37.5	33.7	32.2	26.9	22.4
	2%	WB	10.9	12.7	16.0	19.0	20.4	21.5	23.4	22.4	19.8	17.7	14.8	11.6
		MCDB	19.2	20.9	25.5	28.8	33.0	37.2	37.7	37.0	33.6	30.2	22.8	19.2
	5%	WB	9.7	11.4	15.0	17.9	19.8	20.8	22.3	21.0	18.9	16.9	13.3	10.3
		MCDB	16.4	17.2	23.7	28.3	32.4	36.2	37.1	35.3	33.0	28.6	20.6	16.7
	10%	WB	8.4	10.2	13.9	16.8	19.0	20.1	21.4	20.0	18.0	15.8	12.3	9.1
		MCDB	13.7	15.3	21.5	26.1	31.2	35.4	36.3	35.4	31.7	26.0	18.9	14.1
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.3	11.6	13.2	15.0	15.1	14.9	15.8	16.3	14.7	11.6	10.0
		MCDBR	15.2	15.5	17.2	18.2	18.2	17.6	16.9	17.6	18.7	18.3	16.2	14.9
		MCWBR	7.7	7.6	6.9	6.6	5.8	5.7	5.8	6.3	7.2	7.9	7.7	7.5
	5% WB	MCDBR	13.7	13.5	15.0	15.2	15.1	14.2	13.9	14.8	15.8	15.5	13.7	13.3
MCWBR		7.3	7.2	6.6	6.2	5.3	5.2	5.5	6.4	6.5	7.0	6.8	7.1	
Clear-Sky Solar Irradiance	taub	0.391	0.440	0.512	0.547	0.555	0.553	0.540	0.494	0.462	0.483	0.447	0.395	
	taud	2.088	1.965	1.816	1.784	1.785	1.779	1.811	1.896	1.944	1.884	1.958	2.078	
	Ebn at Noon	764	769	749	751	752	753	759	785	785	713	688	726	
	Edh at Noon	122	156	198	216	219	220	212	191	172	167	139	116	
All-Sky Solar Radiation	RadAvg	2.31	3.17	4.30	5.65	7.13	8.12	7.99	7.42	6.16	4.36	2.83	2.16	
	RadStd	0.20	0.38	0.37	0.56	0.26	0.22	0.14	0.18	0.15	0.23	0.26	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.43	-0.39	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page