

SABZEVAR, Iran, Islamic Republic of

WMO: 407430

Lat: 36.217N

Lon: 57.667E

Elev: 3209

StdP: 13.07

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.2	26.5	2.1	6.9	35.8	7.3	9.0	42.6	23.2	42.7	20.0	38.5	9.9	70	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	104.1	64.5	101.8	64.0	99.4	63.3	68.5	96.5	67.0	94.9	65.6	93.4	10.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.2	81.5	82.4	55.9	75.0	80.6	53.9	69.7	79.3	34.7	96.3	33.3	94.5	32.1	93.5	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	21.4	18.7	DB	18.0	108.8	6.6	1.4	13.2	109.8	9.4	110.6	5.6	111.4	0.9	112.4	(4)
(5)			WB	15.7	71.3	5.9	3.1	11.4	73.5	7.9	75.3	4.6	77.0	0.3	79.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.3	40.7	45.0	54.3	65.1	75.9	85.0	88.8	85.7	78.2	66.7	52.9	43.8		
	DBStd	18.07	7.44	8.11	8.25	7.84	6.32	5.07	4.25	4.25	5.61	6.85	7.46	6.13		
	HDD50	782	296	171	51	5	0	0	0	0	0	0	53	206		
	HDD65	2840	754	561	340	91	4	0	0	0	1	64	368	657		
	CDD50	6362	7	30	186	457	803	1049	1204	1108	847	518	139	14		
	CDD65	2943	0	0	9	93	342	599	739	643	398	116	4	0		
	CDH74	37992	0	4	103	916	3686	8150	10853	8801	4396	1046	37	0		
	CDH80	21373	0	0	19	297	1728	4787	6791	5195	2218	335	3	0		
(14) Wind	WSAvg	8.6	6.3	7.6	8.4	9.0	10.0	11.0	11.6	9.9	9.3	8.0	6.6	5.7		
(15) Precipitation	PrecAvg	7.0	1.0	1.1	1.6	0.9	0.5	0.2	0.0	0.0	0.0	0.2	0.6	0.9		
	PrecMax	11.3	2.5	2.9	4.8	2.8	2.0	1.1	0.2	0.1	0.5	0.5	3.1	2.3		
	PrecMin	2.4	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.1	0.7	0.8	1.1	0.7	0.5	0.3	0.0	0.0	0.1	0.2	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.4	70.0	82.5	92.5	98.7	105.6	107.8	105.4	100.5	92.1	78.9	65.4		
		MCWB	46.4	49.2	55.4	59.9	61.6	64.6	65.2	64.0	61.8	58.9	54.6	47.3		
	2%	DB	58.6	64.2	76.5	87.5	95.2	102.4	105.0	102.2	97.0	87.3	73.4	60.6		
		MCWB	44.9	47.0	52.7	58.7	61.2	63.6	65.1	64.2	60.9	57.9	52.2	46.0		
	5%	DB	54.7	60.8	72.3	83.1	92.4	100.0	102.5	99.7	94.2	83.7	69.0	56.9		
		MCWB	42.9	46.2	51.4	57.5	60.4	62.9	64.5	63.7	60.5	56.5	50.4	44.6		
	10%	DB	51.4	57.4	68.3	79.1	89.3	97.2	100.1	97.1	91.4	80.0	65.0	53.6		
		MCWB	41.3	45.2	50.0	55.9	59.5	62.2	64.0	62.5	59.7	55.6	48.9	43.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	53.1	58.2	62.6	68.7	70.5	71.0	69.7	66.6	61.2	56.3	49.8		
		MCDB	56.3	61.5	71.5	84.2	89.8	98.2	100.1	97.5	92.9	85.7	70.7	59.1		
	2%	WB	46.5	50.2	55.2	60.4	64.2	67.5	68.8	67.5	64.2	59.3	54.1	47.8		
		MCDB	55.3	59.7	69.8	81.9	87.2	95.5	97.6	95.4	89.8	83.0	68.2	56.7		
	5%	WB	44.4	48.1	53.2	59.0	62.2	65.5	67.2	65.9	62.5	57.7	52.2	46.1		
		MCDB	52.7	58.3	69.0	78.1	85.1	93.4	95.7	93.9	88.9	80.0	65.7	55.0		
	10%	WB	42.3	46.0	51.4	57.4	60.7	64.0	65.8	64.3	61.0	56.3	50.3	44.4		
		MCDB	50.2	56.3	65.5	75.1	83.6	91.5	94.3	92.6	87.3	77.4	62.8	52.1		
(35) Mean Daily Temperature Range	MDBR		17.1	18.5	20.6	22.1	22.6	22.7	21.8	23.3	24.7	23.7	19.8	17.0		
	5% DB	MCDBR	20.3	22.5	25.0	26.2	24.9	24.9	23.9	24.6	26.7	26.5	23.5	20.6		
		MCWBR	11.3	11.5	10.9	10.0	8.2	8.4	8.6	9.1	10.6	11.1	11.4	11.3		
	5% WB	MCDBR	17.8	19.0	22.1	23.2	23.5	23.6	22.5	22.6	25.7	24.8	20.7	17.4		
		MCWBR	10.7	10.6	10.7	9.8	9.0	9.0	8.9	9.2	11.2	10.8	10.5	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.361	0.430	0.472	0.491	0.472	0.477	0.429	0.391	0.402	0.361	0.323		
	taud		2.334	2.212	2.006	1.941	1.918	1.975	1.973	2.103	2.189	2.136	2.240	2.354		
	Ebn at Noon		272	274	263	259	255	259	257	268	272	255	255	266		
	Edh at Noon		30	39	52	59	61	57	57	49	43	41	33	28		
(44) All-Sky Solar Radiation	RadAvg		846	1140	1501	1904	2241	2577	2515	2349	1960	1443	1002	789		
	RadStd		68	88	86	127	99	75	46	81	58	57	70	67		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-1.89	-1.91	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.72	N/A	-3.22	+0.81	-2.12	-2.07	N/A	N/A	N/A	+160

Nomenclature: See separate page