

SABZEVAR, Iran, Islamic Republic of

WMO: 407430

Lat: 36.217N

Lon: 57.667E

Elev: 978

StdP: 90.11

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-3.0	-16.6	1.0	2.1	-13.7	1.3	5.9	10.4	5.9	8.9	3.6	4.4	70	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	40.0	18.1	38.8	17.8	37.4	17.4	20.3	35.8	19.4	34.9	18.7	34.1	4.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	11.6	28.0	13.3	10.7	27.0	12.2	10.0	26.3	62.9	35.7	59.7	34.7	56.9	34.2	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.6	8.4	DB	-7.8	42.7	3.7	0.8	-10.4	43.2	-12.6	43.7	-14.6	44.1	-17.3	44.7	(4)
(5)			WB	-9.1	21.8	3.3	1.7	-11.4	23.0	-13.4	24.0	-15.2	25.0	-17.6	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	4.8	7.2	12.4	18.4	24.4	29.4	31.6	29.8	25.7	19.3	11.6	6.6	(6)	
	DBStd	10.04	4.14	4.51	4.58	4.36	3.51	2.82	2.36	2.36	3.12	3.81	4.15	3.41	(7)	
	HDD10.0	434	164	95	28	3	0	0	0	0	0	0	29	114	(8)	
	HDD18.3	1578	419	312	189	51	2	0	0	0	1	36	204	365	(9)	
	CDD10.0	3534	4	17	103	254	446	583	669	616	471	288	77	8	(10)	
	CDD18.3	1635	0	0	5	52	190	333	411	357	221	64	2	0	(11)	
	CDH23.3	21107	0	2	57	509	2048	4528	6029	4889	2442	581	21	0	(12)	
	CDH26.7	11874	0	0	11	165	960	2659	3773	2886	1232	186	2	0	(13)	
(14) Wind	WSAvg	3.9	2.8	3.4	3.8	4.0	4.5	4.9	5.2	4.4	4.2	3.6	3.0	2.5	(14)	
(15) Precipitation	PrecAvg	179	25	29	41	24	13	4	1	0	1	4	15	22	(15)	
	PrecMax	287	64	74	122	72	52	29	6	3	12	13	79	58	(16)	
	PrecMin	62	3	3	3	0	0	0	0	0	0	0	0	1	(17)	
	PrecStd	54	18	21	28	17	12	7	1	1	2	4	17	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	21.1	28.1	33.6	37.0	40.9	42.1	40.8	38.0	33.4	26.0	18.6	(19)	
		MCWB	8.0	9.6	13.0	15.5	16.4	18.1	18.4	17.8	16.6	15.0	12.5	8.5	(20)	
	2%	DB	14.8	17.9	24.7	30.8	35.1	39.1	40.5	39.0	36.1	30.7	23.0	15.9	(21)	
		MCWB	7.2	8.3	11.5	14.8	16.2	17.5	18.4	17.9	16.0	14.4	11.2	7.8	(22)	
	5%	DB	12.6	16.0	22.4	28.4	33.6	37.8	39.2	37.6	34.6	28.7	20.6	13.9	(23)	
		MCWB	6.0	7.9	10.8	14.2	15.8	17.2	18.1	17.6	15.8	13.6	10.2	7.0	(24)	
	10%	DB	10.8	14.1	20.2	26.2	31.9	36.2	37.8	36.2	33.0	26.7	18.3	12.0	(25)	
		MCWB	5.2	7.4	10.0	13.3	15.3	16.8	17.8	16.9	15.4	13.1	9.4	6.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.7	14.6	17.0	20.4	21.4	21.7	20.9	19.2	16.2	13.5	9.9	(27)	
		MCDB	13.5	16.4	21.9	29.0	32.1	36.8	37.8	36.4	33.8	29.8	21.5	15.1	(28)	
	2%	WB	8.1	10.1	12.9	15.8	17.9	19.7	20.4	19.7	17.9	15.2	12.3	8.8	(29)	
		MCDB	13.0	15.4	21.0	27.7	30.6	35.3	36.5	35.2	32.1	28.4	20.1	13.7	(30)	
	5%	WB	6.9	8.9	11.8	15.0	16.8	18.6	19.6	18.8	17.0	14.3	11.2	7.9	(31)	
		MCDB	11.5	14.6	20.5	25.6	29.5	34.1	35.4	34.4	31.6	26.7	18.7	12.8	(32)	
	10%	WB	5.7	7.8	10.8	14.1	16.0	17.8	18.8	18.0	16.1	13.5	10.2	6.9	(33)	
		MCDB	10.1	13.5	18.6	24.0	28.6	33.0	34.6	33.7	30.7	25.2	17.1	11.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	10.3	11.4	12.3	12.5	12.6	12.1	12.9	13.7	13.2	11.0	9.4	(35)	
		MCDBR	11.3	12.5	13.9	14.6	13.8	13.8	13.3	13.7	14.9	14.7	13.1	11.5	(36)	
	5% WB	MCWBR	6.3	6.4	6.1	5.6	4.6	4.7	4.8	5.0	5.9	6.2	6.3	6.3	(37)	
		MCWBR	9.9	10.5	12.3	12.9	13.1	13.1	12.5	12.6	14.3	13.8	11.5	9.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.327	0.361	0.430	0.472	0.491	0.472	0.477	0.429	0.391	0.402	0.361	0.323	(40)	
		taud	2.334	2.212	2.006	1.941	1.918	1.975	1.973	2.103	2.189	2.136	2.240	2.354	(41)	
	Ebn at Noon	Ebn at Noon	858	864	829	815	805	818	811	844	859	805	803	837	(42)	
		Edh at Noon	96	122	164	185	192	181	180	155	135	130	104	88	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.67	3.59	4.73	6.00	7.07	8.12	7.93	7.41	6.18	4.55	3.16	2.49	(44)	
	RadStd	RadStd	0.21	0.28	0.27	0.40	0.31	0.24	0.14	0.25	0.18	0.18	0.22	0.21	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-1.05	-1.06	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.40	N/A	-1.79	+0.45	-1.18	-1.15	N/A	N/A	N/A	+89	

Nomenclature: See separate page