

KASHMAR, Iran, Islamic Republic of

WMO: 407630

Lat: 35.2705N

Lon: 58.4732E

Elev: 3642

StdP: 12.86

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 21.2	(c) 26.5	(d) 4.4	(e) 7.9	(f) 41.0	(g) 8.4	(h) 9.7	(i) 45.1	(j) 18.8	(k) 43.5	(l) 16.4	(m) 45.8	(n) 0.9	(o) 90	(p) 0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	102.5	63.6	100.5	63.3	98.5	62.8	68.0	95.9	66.6	94.4	65.3	93.1	9.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.9	79.1	81.2	54.9	73.3	81.3	53.1	68.8	80.5	34.6	95.9	33.3	94.6	32.2	92.8	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	DB	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.2	15.6	13.5 <td>19.0</td> <td>106.8</td> <td>5.8</td> <td>1.3</td> <td>14.8</td> <td>107.8</td> <td>11.5</td> <td>108.6</td> <td>8.2</td> <td>109.3</td> <td>4.0</td> <td>110.3</td>		19.0	106.8	5.8	1.3	14.8	107.8	11.5	108.6	8.2	109.3	4.0	110.3	
			WB	16.1	69.2	5.2	2.2	12.3	70.8	9.3	72.1	6.4	73.3	2.6	74.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.2	40.4	45.2	55.8	65.2	76.8	85.3	87.7	83.8	77.2	66.6	52.9	44.0	(6)
	DBStd	17.70	7.89	7.82	8.27	7.89	5.77	4.54	4.07	4.34	5.44	7.16	7.73	6.04	(7)
	HDD50	774	307	167	40	4	0	0	0	0	0	0	56	200	(8)
	HDD65	2801	763	555	300	90	2	0	0	0	1	70	369	651	(9)
	CDD50	6317	9	33	221	461	832	1059	1167	1048	817	515	141	14	(10)
	CDD65	2866	0	0	15	97	368	609	702	583	368	119	5	0	(11)
	CDH74	38146	0	3	102	806	4099	8863	10717	8208	4295	1027	26	0	(12)
	CDH80	21111	0	0	20	219	1813	5264	6706	4765	2031	292	1	0	(13)
(14) Wind	WSAvg	5.2	3.7	4.5	5.3	6.1	6.7	7.0	6.9	5.6	4.7	4.4	3.8	3.5	(14)
(15) Precipitation	PrecAvg	8.3	1.4	1.4	1.9	1.1	0.7	0.1	0.0	0.0	0.0	0.2	0.6	1.0	(15)
	PrecMax	14.3	3.3	4.1	3.9	3.2	2.8	0.7	0.4	0.2	0.6	1.3	1.3	3.0	(16)
	PrecMin	3.7	0.2	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	2.2	0.7	1.0	1.1	0.8	0.6	0.2	0.1	0.0	0.1	0.3	0.4	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	70.0	82.5	90.8	97.7	104.4	105.8	103.9	97.6	91.0	77.3	65.9	(19)
		MCWB	46.0	49.9	54.3	58.1	60.8	64.0	64.2	64.3	59.7	58.1	54.5	46.9	(20)
	2%	DB	59.3	64.2	75.8	86.0	94.8	101.8	103.6	100.6	95.1	86.3	72.3	60.5	(21)
		MCWB	44.8	47.9	52.6	57.6	60.9	62.4	64.3	63.7	59.3	57.3	52.2	44.9	(22)
	5%	DB	55.5	60.5	72.3	82.1	91.8	99.0	101.4	98.3	92.9	83.1	68.4	57.2	(23)
		MCWB	43.0	46.4	51.9	56.8	60.4	62.2	63.9	62.9	59.3	56.1	50.3	43.8	(24)
	10%	DB	51.9	57.2	69.3	78.7	89.3	97.0	99.0	95.6	90.0	80.0	64.8	54.1	(25)
		MCWB	41.6	44.8	50.7	55.4	59.9	61.9	63.6	61.6	59.1	55.2	48.8	42.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	52.8	57.8	61.5	65.9	68.3	71.1	69.4	65.2	60.1	56.4	49.9	(27)
		MCDB	53.8	63.1	67.7	79.0	90.4	96.5	98.6	98.4	90.4	83.8	71.1	57.9	(28)
	2%	WB	47.2	50.3	55.6	59.5	64.0	66.6	68.7	67.1	62.7	58.4	53.8	47.5	(29)
		MCDB	54.9	59.9	69.6	79.1	88.1	95.2	96.3	95.1	89.1	82.1	68.9	55.2	(30)
	5%	WB	44.9	48.2	53.8	58.4	62.5	65.2	67.1	65.5	61.0	57.1	52.1	46.0	(31)
		MCDB	53.7	58.1	69.3	77.5	86.1	94.1	95.0	93.0	88.1	80.1	65.2	53.9	(32)
	10%	WB	42.6	46.2	52.1	56.9	61.1	63.8	65.7	63.8	59.7	55.8	50.4	44.4	(33)
		MCDB	50.6	55.0	66.9	74.5	84.7	92.8	93.8	91.7	86.9	77.8	62.2	52.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.8	16.3	18.2	19.0	20.3	22.0	22.2	23.7	23.6	21.2	18.0	16.5	(35)
		MCDBR	19.2	19.6	20.4	21.5	22.4	23.0	23.6	24.4	24.9	22.4	19.8	19.5	(36)
	5% WB	MCWBR	10.8	10.2	9.0	7.9	8.1	8.1	8.4	9.1	10.0	9.3	9.9	10.7	(37)
		MCWBR	15.2	16.7	18.3	18.9	20.2	20.5	21.0	21.7	22.6	21.2	17.6	16.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.320	0.357	0.424	0.466	0.482	0.461	0.457	0.416	0.376	0.391	0.354	0.316	(40)
		taud	2.351	2.226	2.015	1.944	1.922	1.983	2.002	2.117	2.208	2.141	2.251	2.377	(41)
	Ebn at Noon	Ebn at Noon	277	278	266	261	258	263	263	272	278	261	260	272	(42)
		Edh at Noon	30	38	52	59	61	57	56	49	42	41	33	28	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	888	1174	1543	1921	2256	2568	2521	2352	1982	1486	1053	841	(44)
	RadStd	RadStd	83	107	89	113	116	75	41	72	50	54	74	75	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+0.72	N/A	-3.22	+0.81	-2.12	-2.07	N/A	N/A	N/A	+160