

KASHMAR, Iran, Islamic Republic ofWMO: **407630**Lat: **35.2705N**Lon: **58.4732E**Elev: **1110**StdP: **88.68**Time Zone: **3.50 (IRN)**Period: **00-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	-3.1	-15.3	1.1	5.0	-13.1	1.4	7.3	8.4	6.4	7.3	7.7	0.4	90	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	39.2	17.6	38.1	17.4	36.9	17.1	20.0	35.5	19.2	34.6	18.5	34.0	4.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.8	11.3	27.3	12.7	10.5	27.4	11.7	9.8	27.0	62.5	35.5	59.5	34.8	57.0	33.8	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.0	6.0	-7.2	41.6	3.2	0.7	-9.5	42.1	-11.4	42.5	-13.2	43.0	-15.5	43.5		
(5)			-8.8	20.7	2.9	1.2	-10.9	21.6	-12.6	22.3	-14.2	23.0	-16.3	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	4.7	7.3	13.2	18.5	24.9	29.6	30.9	28.8	25.1	19.2	11.6	6.7	(6)
(7)		DBStd	9.83	4.38	4.35	4.59	4.38	3.21	2.52	2.26	2.41	3.02	3.98	4.30	3.36	(7)
(8)		HDD10.0	430	171	93	22	2	0	0	0	0	0	0	31	111	(8)
(9)		HDD18.3	1556	424	308	167	50	1	0	0	1	39	205	362	(9)	
(10)		CDD10.0	3509	5	18	123	256	462	588	648	582	454	286	78	8	(10)
(11)		CDD18.3	1592	0	0	8	54	204	338	390	324	204	66	3	0	(11)
(12)		CDH23.3	21192	0	2	57	448	2277	4924	5954	4560	2386	571	14	0	(12)
(13)		CDH26.7	11728	0	0	11	122	1007	2924	3726	2647	1128	162	1	0	(13)
(14)	Wind	WSAvg	2.3	1.6	2.0	2.4	2.7	3.0	3.1	3.1	2.5	2.1	2.0	1.7	1.6	(14)
(15)	Precipitation	PrecAvg	211	35	35	47	29	17	3	1	0	1	5	14	25	(15)
(16)		PrecMax	363	84	104	100	81	71	17	11	4	14	32	34	76	(16)
(17)		PrecMin	94	6	1	4	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	55	19	25	27	21	14	4	3	1	3	8	11	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	21.1	28.0	32.7	36.5	40.2	41.0	40.0	36.4	32.8	25.2	18.9	(19)
(20)			MCWB	7.8	10.0	12.4	14.5	16.0	17.8	17.9	18.0	15.4	14.5	12.5	8.3	(20)
(21)		2%	DB	15.1	17.9	24.3	30.0	34.9	38.8	39.8	38.1	35.1	30.2	22.4	15.8	(21)
(22)			MCWB	7.1	8.8	11.5	14.2	16.0	16.9	17.9	17.6	15.2	14.1	11.2	7.2	(22)
(23)		5%	DB	13.1	15.8	22.4	27.8	33.2	37.2	38.5	36.8	33.8	28.4	20.2	14.0	(23)
(24)			MCWB	6.1	8.0	11.1	13.8	15.8	16.8	17.7	17.1	15.2	13.4	10.1	6.6	(24)
(25)		10%	DB	11.1	14.0	20.7	25.9	31.8	36.1	37.2	35.3	32.2	26.7	18.2	12.3	(25)
(26)			MCWB	5.3	7.1	10.4	13.0	15.5	16.6	17.6	16.4	15.1	12.9	9.4	6.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	11.6	14.4	16.4	18.8	20.2	21.7	20.8	18.5	15.6	13.6	9.9	(27)
(28)			MCDWB	12.1	17.3	19.8	26.1	32.4	35.9	37.0	36.9	32.4	28.8	21.7	14.4	(28)
(29)		2%	WB	8.4	10.2	13.1	15.3	17.8	19.2	20.4	19.5	17.1	14.7	12.1	8.6	(29)
(30)			MCDWB	12.7	15.5	20.9	26.2	31.2	35.1	35.7	35.1	31.7	27.8	20.5	12.9	(30)
(31)		5%	WB	7.2	9.0	12.1	14.6	16.9	18.4	19.5	18.6	16.1	13.9	11.1	7.8	(31)
(32)			MCDWB	12.1	14.5	20.7	25.3	30.1	34.5	35.0	33.9	31.1	26.7	18.5	12.2	(32)
(33)		10%	WB	5.9	7.9	11.1	13.9	16.2	17.7	18.7	17.7	15.4	13.2	10.2	6.9	(33)
(34)			MCDWB	10.3	12.8	19.4	23.6	29.3	33.8	34.3	33.1	30.5	25.4	16.8	11.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	9.1	10.1	10.6	11.3	12.2	12.3	13.2	13.1	11.8	10.0	9.2	(35)
(36)			MCDBR	10.6	10.9	11.3	11.9	12.4	12.8	13.1	13.6	13.8	12.5	11.0	10.8	(36)
(37)			MCWBR	6.0	5.7	5.0	4.4	4.5	4.5	4.7	5.1	5.5	5.2	5.5	5.9	(37)
(38)		5% WB	MCDBR	8.5	9.3	10.2	10.5	11.2	11.4	11.6	12.0	12.6	11.8	9.8	8.9	(38)
(39)			MCWBR	5.4	5.4	4.8	4.3	4.6	4.8	5.3	5.7	5.5	5.0	5.3	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.357	0.424	0.466	0.482	0.461	0.457	0.416	0.376	0.391	0.354	0.316	(40)	
(41)		taud	2.351	2.226	2.015	1.944	1.922	1.983	2.002	2.117	2.208	2.141	2.251	2.377	(41)	
(42)		Ebn at Noon	874	875	839	823	814	828	828	858	877	822	820	856	(42)	
(43)		Edh at Noon	95	121	164	185	192	180	176	153	133	130	105	88	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.80	3.70	4.86	6.06	7.11	8.09	7.95	7.42	6.25	4.68	3.32	2.65	(44)	
(45)		RadStd	0.26	0.34	0.28	0.36	0.37	0.24	0.13	0.23	0.16	0.17	0.23	0.24	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47)	Regional (4 neighbors)	+0.40	N/A	-1.79	+0.45	-1.18	-1.15	N/A	N/A	+89

Nomenclature: See separate page