

KERMANSHAH, Iran, Islamic Republic ofWMO: **407660**Lat: **34.3516N**Lon: **47.1534E**Elev: **4327**StdP: **12.54**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.0	22.8	-1.8	5.8	68.7	4.7	8.2	59.9	22.5	44.7	19.6	44.5	3.2	100	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.7	104.1	62.3	102.2	62.0	100.2	61.4	67.5	98.3	65.5	96.4	63.6	94.5	9.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.2	76.3	77.7	53.0	70.1	74.4	51.0	65.3	71.2	34.5	98.0	32.7	96.5	31.1	94.3	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.0	15.8	12.9	107.7	5.2	1.6	9.2	108.9	6.2	109.9	3.3	110.8	-0.5	111.9		
(5)			11.6	66.6	4.7	3.1	8.2	68.9	5.5	70.7	2.8	72.4	-0.6	74.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	37.7	41.1	48.7	56.4	66.1	76.9	83.6	82.8	73.7	63.2	49.6	41.6	
	DBStd	16.81	6.87	6.81	6.40	5.76	5.21	4.20	3.50	3.36	4.25	5.39	5.89	5.78	
	HDD50	1093	383	256	99	11	0	0	0	0	0	0	76	268	
	HDD65	3626	847	670	508	263	49	0	0	0	1	98	463	727	
	CDD50	4821	1	6	58	203	498	806	1041	1017	710	411	64	6	
	CDD65	1878	0	0	2	5	82	356	576	552	261	44	0	0	
	CDH74	31098	0	0	25	143	1588	5790	9411	8976	4237	923	5	0	
	CDH80	18452	0	0	1	25	549	3354	6179	5853	2251	240	0	0	
Wind	WSAvg	6.1	5.6	6.2	7.2	7.0	6.8	6.9	6.9	6.4	5.9	5.5	4.7	4.7	
Precipitation	PrecAvg	16.5	2.6	2.3	2.5	2.5	0.8	0.0	0.0	0.0	0.0	1.2	2.2	2.2	
	PrecMax	28.9	5.0	4.9	6.3	5.4	3.4	0.3	0.4	0.3	0.6	5.4	11.7	5.9	
	PrecMin	10.7	0.6	0.6	0.1	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	
	PrecStd	3.9	1.1	1.0	1.7	1.5	0.9	0.1	0.1	0.0	0.2	1.4	2.2	1.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	64.5	77.3	83.5	92.9	102.4	107.3	105.8	100.0	88.2	73.5	66.1	
		MCWB	42.9	46.1	50.8	55.5	59.7	61.2	62.7	62.2	59.9	56.3	49.7	46.6	
	2%	DB	55.7	60.7	71.2	77.4	89.1	99.9	104.9	103.9	96.8	85.7	69.4	59.5	
		MCWB	42.2	43.8	48.7	54.5	57.8	60.0	62.2	62.5	58.2	55.7	49.4	44.5	
	5%	DB	52.7	57.4	66.4	73.8	85.9	97.0	102.6	102.2	94.0	82.6	66.0	55.8	
		MCWB	41.2	42.8	46.8	52.4	56.9	59.6	62.0	62.1	57.5	54.6	47.9	43.1	
	10%	DB	49.6	53.9	62.7	71.1	82.6	94.7	100.5	100.2	91.4	79.6	62.3	53.0	
		MCWB	39.9	41.5	45.4	51.7	56.2	59.3	61.9	61.3	57.0	53.7	47.1	42.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	49.7	52.8	58.5	63.0	67.3	72.8	70.9	65.2	59.9	55.2	50.0
			MCDB	53.8	58.0	69.3	74.9	86.2	95.2	101.3	101.5	92.8	82.8	65.0	59.1
2%		WB	45.3	46.6	50.6	56.6	60.9	64.8	68.1	67.4	61.7	57.9	52.7	47.2	
		MCDB	50.9	56.4	66.4	71.7	82.2	93.1	98.9	99.3	90.8	80.2	61.4	55.5	
5%		WB	42.8	44.4	48.6	54.9	59.3	62.6	65.8	65.2	59.8	56.3	51.0	45.5	
		MCDB	49.5	53.9	62.3	69.2	79.2	91.0	96.8	97.7	89.0	77.0	60.2	53.1	
10%		WB	41.0	42.6	46.8	53.5	57.9	60.5	63.7	63.1	58.1	54.8	49.4	43.6	
		MCDB	47.8	51.5	59.4	66.6	77.1	90.3	95.4	95.6	87.5	74.5	58.7	50.5	
Mean Daily Temperature Range		5% DB	MDBR	18.8	21.1	23.5	25.1	29.7	34.7	34.7	35.6	35.5	29.8	23.7	20.6
			MCDBR	24.4	27.7	30.2	30.7	35.0	37.8	37.2	36.9	37.8	34.3	29.5	26.3
	MCWBR		13.4	14.1	14.2	13.1	13.8	14.7	14.2	14.8	16.2	16.9	14.6	14.6	
	5% WB	MCDBR	18.7	22.3	24.5	25.5	29.8	33.9	33.7	35.7	36.2	29.6	20.8	20.4	
		MCWBR	11.5	12.5	12.2	11.8	12.5	15.9	17.0	18.2	18.3	15.8	11.0	12.4	
Clear-Sky Solar Irradiance	taub		0.312	0.352	0.408	0.488	0.477	0.427	0.464	0.430	0.373	0.403	0.346	0.316	
	taud		2.343	2.218	2.051	1.873	1.923	2.056	1.955	2.049	2.201	2.093	2.278	2.361	
	Ebn at Noon		282	281	272	256	260	272	261	269	280	258	266	273	
	Edh at Noon		31	39	50	63	61	53	58	52	43	44	33	29	
All-Sky Solar Radiation	RadAvg		871	1167	1543	1838	2215	2640	2463	2285	1977	1417	1012	814	
	RadStd		58	95	128	164	148	107	84	81	77	109	109	78	