

BANDAR MAHSHAHR, Iran, Islamic Republic of

WMO: 407801

Lat: 30.556N

Lon: 49.152E

Elev: 2

StdP: 101.30

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	5.2	-4.8	2.5	20.8	-2.2	3.1	17.9	11.9	16.8	10.3	16.1	2.3	300	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	47.9	24.0	46.8	24.2	45.2	23.7	31.8	37.5	30.7	36.2	29.9	35.5	7.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.8	28.5	35.6	29.8	26.8	35.0	28.2	24.5	34.3	108.6	37.6	103.4	35.7	98.7	35.1	35.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.6	10.1	8.8	1.8	50.0	1.8	0.7	0.5	50.5	-0.6	50.9	-1.6	51.2	-2.9	51.7		
			0.4	33.2	2.1	1.2	-1.2	34.1	-2.4	34.8	-3.6	35.5	-5.2	36.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.4	13.4	15.9	20.7	26.0	32.4	36.3	37.5	37.0	33.5	28.1	20.0	15.0
	DBStd	9.13	3.36	3.40	3.15	3.21	2.61	1.94	1.66	1.50	2.18	3.11	3.48	2.88
	HDD10.0	13	9	2	0	0	0	0	0	0	0	0	0	1
	HDD18.3	379	154	81	13	1	0	0	0	0	0	0	23	108
	CDD10.0	5992	116	167	333	481	694	788	853	838	705	563	299	156
	CDD18.3	3316	2	11	88	231	436	538	595	579	455	304	72	5
	CDH23.3	52289	3	54	767	2648	6881	9506	10630	10061	7210	3864	641	26
	CDH26.7	36394	0	1	241	1290	4592	7129	8151	7584	4993	2215	198	0
Wind	WSAvg	3.7	3.3	3.5	3.8	3.8	4.3	5.1	4.7	4.0	3.5	3.0	2.6	2.9
Precipitation	PrecAvg	208	54	28	26	12	3	0	0	0	0	7	29	48
	PrecMax	333	138	88	90	53	9	1	0	0	3	85	202	122
	PrecMin	87	11	0	0	0	0	0	0	0	0	1	0	0
	PrecStd	72	34	25	24	15	2	0	0	0	1	19	49	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	26.2	34.0	38.1	45.2	48.8	49.8	48.8	46.0	41.8	32.9	25.2
		MCWB	15.4	15.3	17.8	20.2	23.4	23.7	24.5	25.5	23.9	20.7	18.7	16.2
	2%	DB	22.0	25.0	31.2	36.9	43.1	47.2	48.0	47.1	44.1	39.2	31.0	24.0
		MCWB	15.3	14.9	17.0	19.6	22.2	23.6	24.4	24.4	23.2	21.1	19.6	16.4
	5%	DB	20.8	23.8	29.1	34.9	41.7	46.0	46.8	46.0	42.9	37.9	29.0	22.2
		MCWB	14.6	14.8	16.3	19.0	21.5	23.3	24.5	23.9	22.8	21.3	18.9	15.5
	10%	DB	19.2	22.1	27.2	32.9	39.9	44.8	45.2	44.8	41.1	36.0	27.0	20.9
		MCWB	14.0	14.2	15.5	18.7	21.4	22.6	24.1	24.1	22.9	21.3	18.4	15.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.3	18.7	20.2	23.1	27.2	29.7	33.5	32.7	32.7	28.1	25.1	20.0
		MCDB	21.0	22.7	26.5	30.7	37.9	37.5	43.1	39.1	39.5	32.6	29.2	23.0
	2%	WB	17.3	17.6	19.3	22.0	25.2	28.5	31.3	31.9	30.8	27.0	22.9	18.5
		MCDB	20.1	21.2	25.7	30.3	35.6	37.0	38.1	37.3	35.1	31.8	26.9	21.4
	5%	WB	16.2	16.4	18.5	21.1	24.2	27.4	30.1	31.2	29.7	26.1	21.0	17.2
		MCDB	19.1	20.7	25.1	30.4	34.4	36.5	36.2	36.6	34.7	31.2	26.2	20.2
	10%	WB	15.1	15.5	17.6	20.4	23.3	26.1	29.1	30.3	28.6	24.9	19.5	16.0
		MCDB	18.1	20.2	24.5	29.6	34.6	37.7	36.0	35.6	34.2	30.3	24.6	19.4
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.5	11.9	12.2	13.5	16.2	15.1	14.9	15.8	14.5	12.1	10.6
		MCDBR	10.5	11.6	14.2	13.9	16.1	17.9	17.6	17.7	17.8	16.6	14.6	12.5
		MCWBR	6.3	5.4	5.5	5.1	6.4	6.6	6.6	7.0	7.6	7.3	7.6	7.1
	5% WB	MCDBR	8.0	8.8	10.7	11.3	13.2	14.5	12.8	12.0	12.2	11.8	10.9	8.7
		MCWBR	6.1	5.2	5.3	5.0	6.5	7.0	6.6	6.5	7.2	7.2	7.4	6.3
Clear-Sky Solar Irradiance	taub		0.473	0.513	0.571	0.665	0.655	0.605	0.666	0.619	0.542	0.546	0.503	0.468
	taud		1.918	1.829	1.691	1.558	1.573	1.636	1.555	1.642	1.775	1.777	1.871	1.944
	Ebn at Noon		721	734	723	676	687	720	674	701	738	692	684	700
	Edh at Noon		160	191	234	277	275	257	277	251	212	198	166	149
All-Sky Solar Radiation	RadAvg		3.28	4.27	5.46	6.09	7.26	8.12	7.72	7.27	6.40	4.98	3.63	3.06
	RadStd		0.22	0.27	0.24	0.35	0.30	0.17	0.17	0.15	0.15	0.18	0.27	0.29

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.29	N/A	N/A	+0.44	N/A	N/A	N/A	N/A	+85	+83

Nomenclature: See separate page