

QESHM INTL, Iran, Islamic Republic of

WMO: 407808

Lat: 26.751N

Lon: 55.898E

Elev: 41

StdP: 14.67

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.9	54.0	28.2	22.2	67.8	32.4	26.9	64.8	27.4	70.4	24.5	72.0	3.4	330	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	107.3	77.3	104.1	80.8	102.0	82.1	89.4	96.0	88.4	95.4	87.5	94.8	11.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
88.0	203.6	93.8	86.4	193.5	92.8	86.1	191.1	92.5	54.6	97.4	53.6	94.5	52.4	95.3	93.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
26.6	23.4	21.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			47.3	113.4	3.0	2.2	45.2	115.0	43.4	116.2	41.8	117.5	39.6	119.1
			40.9	91.1	2.6	1.8	39.1	92.4	37.6	93.5	36.1	94.5	34.3	95.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	64.9	66.9	72.8	79.5	85.7	91.1	94.7	93.9	90.6	84.8	75.2	68.3	(6)
(7)		DBStd	10.92	3.72	4.27	3.64	3.87	2.82	3.19	2.22	2.26	2.39	2.79	3.90	3.32	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	82	48	25	1	0	0	0	0	0	0	0	0	8	(9)
(10)		CDD50	11237	461	474	707	886	1107	1233	1386	1362	1218	1079	756	568	(10)
(11)		CDD65	5844	44	79	243	436	642	783	921	897	768	614	306	111	(11)
(12)		CDH74	78892	170	351	1490	4245	8608	11988	14810	14208	11635	8052	2677	658	(12)
(13)		CDH80	46535	2	43	332	1534	4410	7691	10346	9744	7338	4169	863	63	(13)
(14)	Wind	WSAvg	9.8	7.6	9.7	11.3	11.7	12.2	11.4	10.6	11.0	9.7	8.4	7.4	6.8	(14)
(15)	Precipitation	PrecAvg	5.7	2.1	1.3	1.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.9	(15)
(16)		PrecMax	12.4	7.6	6.6	4.4	0.6	0.1	0.1	0.7	0.2	0.4	0.7	0.9	2.8	(16)
(17)		PrecMin	1.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.1	1.8	1.6	1.4	0.2	0.0	0.0	0.2	0.0	0.1	0.2	0.3	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.1	84.5	89.9	98.4	102.0	111.5	111.0	109.4	104.4	99.0	91.5	84.5	(19)
MCWB			65.9	68.3	69.7	71.9	74.0	71.2	71.9	74.5	75.0	71.8	68.7	65.4	(20)	
2%		DB	77.3	80.6	86.3	93.4	98.6	105.6	106.1	106.0	102.0	96.6	89.4	81.0	(21)	
		MCWB	66.9	68.5	69.8	73.6	75.9	77.4	81.2	78.9	79.0	76.4	71.6	66.4	(22)	
5%		DB	75.6	77.4	83.8	91.1	95.4	102.1	103.8	102.6	99.0	94.6	87.5	79.2	(23)	
		MCWB	65.7	67.8	70.4	73.6	77.5	80.6	83.3	82.7	81.4	79.0	73.4	66.1	(24)	
10%		DB	73.8	75.5	80.8	87.8	93.3	98.8	101.6	100.4	97.0	92.9	84.6	77.4	(25)	
		MCWB	64.3	66.5	70.5	74.7	78.5	82.2	84.2	84.6	82.8	80.0	71.4	65.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	73.6	77.3	81.3	86.3	89.4	90.6	91.1	89.6	87.3	79.8	75.6	(27)
MCDWB			76.7	79.2	82.5	87.1	92.2	95.6	97.2	97.1	95.1	92.0	86.6	80.0	(28)	
2%		WB	69.9	71.5	74.7	79.2	84.3	87.6	89.3	89.5	88.1	85.7	77.9	72.3	(29)	
		MCDWB	75.4	77.6	80.4	86.2	90.4	95.3	96.3	96.2	94.2	91.4	85.4	77.5	(30)	
5%		WB	68.3	69.8	73.3	77.6	82.9	86.6	88.2	88.4	87.1	84.5	76.3	70.3	(31)	
		MCDWB	74.0	75.4	79.2	84.7	88.8	94.2	95.9	95.3	93.4	90.2	84.4	76.3	(32)	
10%		WB	66.7	68.6	72.0	76.3	81.7	85.6	87.4	87.3	86.1	83.2	74.7	68.3	(33)	
		MCDWB	72.9	74.2	78.0	83.6	87.9	93.1	95.3	94.5	92.6	89.3	82.6	75.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.8	16.5	15.6	15.2	15.6	16.1	14.6	14.1	14.7	16.5	18.7	19.2	(35)
MCDBR			19.2	18.6	20.4	21.4	20.3	22.1	18.8	18.6	18.1	19.0	20.2	21.0	(36)	
MCWBR			12.6	11.3	10.9	9.4	9.4	10.0	8.9	9.5	9.1	11.3	11.6	12.6	(37)	
5% WB		MCDBR	16.8	16.3	16.5	16.4	15.5	16.3	14.6	14.7	14.4	14.3	17.5	17.3	(38)	
		MCWBR	12.9	11.2	10.7	9.2	8.8	8.8	7.3	8.1	8.1	9.3	12.0	13.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.431	0.498	0.554	0.585	0.587	0.639	0.721	0.680	0.600	0.517	0.444	0.422	(40)	
taud		2.139	1.956	1.819	1.779	1.781	1.715	1.609	1.684	1.799	1.948	2.129	2.169	(41)		
Ebn at Noon		253	245	239	236	235	221	204	211	224	236	247	250	(42)		
Edh at Noon		43	55	67	71	71	75	84	77	67	55	43	40	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1254	1492	1832	2140	2426	2465	2287	2187	1997	1728	1369	1192	(44)	
(45)		RadStd	79	118	128	110	56	51	56	57	33	30	44	75	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	+0.72	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	+250	+241

Nomenclature: See separate page