

KHOR, Iran, Islamic Republic ofWMO: **407890**Lat: **33.7696N**Lon: **55.0813E**Elev: **2772**StdP: **13.28**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.3	31.2	5.8	8.2	49.5	9.2	9.7	49.2	18.9	54.4	16.5	52.2	0.7	N/A	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	108.9	66.8	106.7	66.0	104.4	65.2	69.5	101.1	67.9	100.9	66.8	99.2	6.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.0	79.5	85.2	55.7	73.1	83.2	53.5	67.6	82.9	35.4	100.3	33.9	101.2	32.9	99.1	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	14.7	12.2	23.5	113.0	5.6	0.9	19.5	113.6	16.3	114.2	13.1	114.6	9.1	115.3		
(5)			19.8	71.8	4.7	2.8	16.4	73.7	13.6	75.4	10.9	76.9	7.5	78.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	44.8	50.2	61.3	70.8	82.4	90.4	93.2	89.4	82.9	71.7	57.1	48.0	
	DBStd	18.01	7.45	7.39	8.14	7.37	5.43	4.77	4.50	4.06	4.70	6.66	7.64	5.91	
	HDD50	412	191	79	11	0	0	0	0	0	0	0	21	110	
	HDD65	2039	628	415	166	31	0	0	0	0	0	17	253	529	
	CDD50	7819	28	85	362	625	1004	1212	1340	1222	987	673	235	46	
	CDD65	3971	0	1	52	206	539	762	875	757	537	225	17	0	
	CDH74	56674	0	9	489	2072	6956	11951	14316	11546	6955	2232	147	1	
	CDH80	34847	0	1	134	773	3802	7935	9935	7374	3956	916	21	0	
Wind	WSAvg	3.4	2.1	2.9	3.9	4.1	5.0	5.0	5.2	4.2	2.7	2.3	1.6	1.4	
Precipitation	PrecAvg	3.1	0.6	0.5	0.7	0.4	0.2	0.0	0.0	0.0	0.0	0.1	0.2	0.4	
	PrecMax	4.8	1.6	1.5	2.4	1.4	1.3	0.2	0.0	0.0	0.1	0.7	1.3	0.9	
	PrecMin	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	PrecStd	1.1	0.5	0.4	0.7	0.4	0.3	0.0	0.0	0.0	0.0	0.2	0.3	0.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.5	74.5	90.6	95.1	102.5	110.4	112.0	110.4	104.3	96.0	82.8	69.8	
		MCWB	49.3	50.8	56.1	60.3	63.4	66.7	68.1	67.1	63.7	61.8	55.9	49.7	
	2%	DB	64.2	69.6	82.9	91.3	99.7	107.7	109.8	106.5	101.3	91.8	78.1	65.6	
		MCWB	46.9	49.9	54.0	58.8	62.5	65.8	67.4	65.9	62.5	60.0	54.5	48.3	
	5%	DB	60.3	66.0	78.8	87.9	97.5	105.4	107.7	103.7	98.4	88.7	74.2	61.9	
		MCWB	44.9	47.9	52.9	58.1	62.1	64.9	66.7	65.0	62.1	58.8	52.5	46.6	
	10%	DB	56.5	62.8	75.6	84.4	94.6	103.1	105.2	100.9	95.9	85.3	69.8	58.5	
		MCWB	42.9	46.1	51.9	56.8	61.4	64.2	66.1	64.1	61.8	57.8	50.7	44.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.5	54.3	59.0	62.0	66.2	69.1	73.7	71.5	67.2	63.1	58.9	51.8
			MCDB	65.1	66.0	75.5	89.0	96.0	102.7	104.2	98.8	96.0	90.5	77.4	63.0
2%		WB	47.8	51.6	57.0	60.7	64.5	67.5	70.3	68.9	65.2	61.5	55.9	49.7	
		MCDB	61.2	66.2	74.1	85.3	94.7	102.5	101.2	99.7	95.1	88.2	72.9	61.7	
5%		WB	45.6	49.5	54.9	59.4	63.3	66.4	68.5	66.9	63.9	59.9	53.9	48.0	
		MCDB	58.4	63.0	74.7	81.8	93.1	101.0	101.3	97.7	94.3	85.5	69.7	59.0	
10%		WB	43.5	47.5	53.3	58.1	62.3	65.3	67.4	65.5	62.6	58.5	52.1	46.3	
		MCDB	55.2	61.1	73.7	79.6	91.5	99.4	100.3	96.3	92.4	82.8	68.1	56.6	
Mean Daily Temperature Range		5% DB	MDBR	18.2	19.0	20.7	20.2	20.2	22.2	21.3	21.9	24.3	22.6	19.8	18.3
			MCDBR	22.3	22.8	23.9	23.6	22.6	24.3	23.3	24.0	26.8	25.4	23.5	22.1
	MCWBR		11.9	11.1	10.0	9.0	8.2	8.4	8.1	8.3	10.3	10.7	11.1	12.3	
	5% WB	MCDBR	20.4	20.1	20.8	20.1	20.8	23.1	22.1	21.7	25.0	23.5	20.2	19.1	
		MCWBR	11.4	10.3	9.4	7.9	7.8	8.0	8.1	8.0	10.1	10.0	9.9	11.0	
Clear-Sky Solar Irradiance	taub	0.334	0.370	0.437	0.508	0.516	0.503	0.509	0.462	0.417	0.414	0.369	0.328		
	taud	2.278	2.153	1.947	1.812	1.813	1.846	1.852	1.967	2.064	2.061	2.187	2.318		
	Ebn at Noon	274	275	264	251	250	252	250	260	266	255	257	269		
	Edh at Noon	33	42	56	67	68	66	65	57	49	45	36	30		
All-Sky Solar Radiation	RadAvg	1000	1287	1656	1986	2310	2584	2498	2339	1978	1532	1113	927		
	RadStd	69	77	82	95	89	74	49	68	42	42	65	64		