

KHOR, Iran, Islamic Republic ofWMO: **407890**Lat: **33.7696N**Lon: **55.0813E**Elev: **845**StdP: **91.58**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	-0.4	-14.5	1.2	9.7	-12.7	1.4	9.5	8.4	12.4	7.4	11.2	0.3	N/A	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	42.7	19.3	41.5	18.9	40.2	18.4	20.8	38.4	20.0	38.3	19.3	37.3	2.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.4	11.4	29.6	13.1	10.4	28.4	12.0	9.7	28.3	64.4	37.9	61.0	38.4	58.7	37.3	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.6	5.4	-4.7	45.0	3.1	0.5	-6.9	45.4	-8.7	45.6	-10.5	45.9	-12.7	46.3		
(5)			-6.8	22.1	2.6	1.5	-8.7	23.2	-10.2	24.1	-11.7	24.9	-13.6	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	7.1	10.1	16.3	21.6	28.0	32.5	34.0	31.9	28.3	22.1	14.0	8.9
	DBStd	10.01	4.14	4.11	4.52	4.10	3.02	2.65	2.50	2.26	2.61	3.70	4.24	3.28
	HDD10.0	229	106	44	6	0	0	0	0	0	0	0	12	61
	HDD18.3	1133	349	231	92	17	0	0	0	0	0	9	141	294
	CDD10.0	4344	16	47	201	347	558	673	744	679	548	374	131	26
	CDD18.3	2206	0	1	29	114	299	423	486	421	298	125	9	0
	CDH23.3	31486	0	5	272	1151	3864	6639	7953	6414	3864	1240	82	1
CDH26.7	19359	0	1	74	429	2112	4408	5519	4097	2198	509	12	0	
Wind	WSAvg	1.5	0.9	1.3	1.7	1.8	2.2	2.2	2.3	1.9	1.2	1.0	0.7	0.6
Precipitation	PrecAvg	79	15	12	18	10	6	1	0	0	0	2	6	9
	PrecMax	123	40	39	61	36	32	6	1	0	3	19	33	24
	PrecMin	22	1	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	28	13	11	17	9	7	1	0	0	1	4	7	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.3	23.6	32.5	35.1	39.2	43.6	44.5	43.6	40.2	35.5	28.2	21.0
		MCWB	9.6	10.5	13.4	15.7	17.4	19.3	20.1	19.5	17.6	16.5	13.3	9.9
	2%	DB	17.9	20.9	28.3	32.9	37.6	42.0	43.2	41.4	38.5	33.2	25.6	18.7
		MCWB	8.3	10.0	12.2	14.9	17.0	18.8	19.7	18.8	17.0	15.5	12.5	9.1
	5%	DB	15.7	18.9	26.0	31.1	36.4	40.8	42.0	39.8	36.9	31.5	23.4	16.6
		MCWB	7.2	8.8	11.6	14.5	16.7	18.3	19.3	18.3	16.7	14.9	11.4	8.1
	10%	DB	13.6	17.1	24.2	29.1	34.8	39.5	40.7	38.3	35.5	29.6	21.0	14.7
		MCWB	6.0	7.8	11.0	13.8	16.3	17.9	18.9	17.9	16.5	14.4	10.4	7.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	12.4	15.0	16.7	19.0	20.6	23.2	21.9	19.6	17.3	14.9	11.0
		MCDB	18.4	18.9	24.2	31.7	35.6	39.3	40.1	37.1	35.5	32.5	25.2	17.2
	2%	WB	8.8	10.9	13.9	15.9	18.0	19.7	21.3	20.5	18.5	16.4	13.3	9.8
		MCDB	16.2	19.0	23.4	29.6	34.8	39.2	38.4	37.6	35.0	31.2	22.7	16.5
	5%	WB	7.6	9.7	12.7	15.2	17.4	19.1	20.3	19.4	17.7	15.5	12.1	8.9
		MCDB	14.7	17.2	23.7	27.7	33.9	38.3	38.5	36.5	34.6	29.7	20.9	15.0
	10%	WB	6.4	8.6	11.8	14.5	16.8	18.5	19.6	18.6	17.0	14.7	11.1	7.9
		MCDB	12.9	16.2	23.1	26.5	33.1	37.5	37.9	35.7	33.6	28.2	20.0	13.7
Mean Daily Temperature Range	5% DB	MDBR	10.1	10.5	11.5	11.2	11.2	12.3	11.8	12.2	13.5	12.6	11.0	10.2
		MCDBR	12.4	12.7	13.3	13.1	12.6	13.5	13.0	13.3	14.9	14.1	13.1	12.3
		MCWBR	6.6	6.2	5.6	5.0	4.6	4.7	4.5	4.6	5.7	5.9	6.2	6.8
	5% WB	MCDBR	11.3	11.2	11.5	11.2	11.6	12.8	12.3	12.1	13.9	13.0	11.2	10.6
		MCWBR	6.4	5.7	5.2	4.4	4.3	4.4	4.5	4.5	5.6	5.6	5.5	6.1
Clear-Sky Solar Irradiance	taub	0.334	0.370	0.437	0.508	0.516	0.503	0.509	0.462	0.417	0.414	0.369	0.328	
	taud	2.278	2.153	1.947	1.812	1.813	1.846	1.852	1.967	2.064	2.061	2.187	2.318	
	Ebn at Noon	865	866	831	790	787	795	787	819	840	804	811	849	
	Edh at Noon	105	133	177	212	215	207	205	180	155	143	114	96	
All-Sky Solar Radiation	RadAvg	3.15	4.06	5.22	6.26	7.28	8.14	7.88	7.37	6.24	4.83	3.51	2.92	
	RadStd	0.22	0.24	0.26	0.30	0.28	0.23	0.15	0.21	0.13	0.13	0.20	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page