

TABAS, Iran, Islamic Republic of

WMO: 407910

Lat: 33.6033N

Lon: 56.9508E

Elev: 2333

StdP: 13.50

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.3	34.0	0.4	6.1	56.0	4.9	7.7	57.8	18.0	49.4	14.9	49.3	1.7	300	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	112.6	66.7	110.6	66.0	108.3	65.3	68.9	106.9	67.5	106.2	66.4	104.6	5.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
55.5	71.5	73.8	53.0	65.3	75.2	50.3	58.9	76.4	34.4	107.6	33.3	106.5	32.3	104.7	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.4	15.5	13.2	DB	27.4	116.1	2.1	1.3	25.9	117.0	24.6	117.8	23.4	118.5	21.9	119.5	
			WB	22.0	70.8	2.3	3.1	20.3	73.0	19.0	74.8	17.7	76.5	16.0	78.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	47.8	53.5	64.4	74.6	86.3	95.1	98.0	94.0	86.6	75.5	59.8	50.3	(6)
(7)		DBStd	18.53	6.45	7.26	7.38	7.32	5.37	4.44	3.79	4.34	4.65	6.30	7.09	5.62	(7)
(8)		HDD50	232	115	43	2	0	0	0	0	0	0	0	8	64	(8)
(9)		HDD65	1615	532	326	100	14	0	0	0	0	0	4	183	456	(9)
(10)		CDD50	8972	48	141	450	737	1125	1353	1487	1365	1099	791	303	73	(10)
(11)		CDD65	4880	0	4	82	302	660	903	1022	900	649	330	28	0	(11)
(12)		CDH74	75643	0	29	701	3334	9678	15673	18176	15107	9296	3445	203	1	(12)
(13)		CDH80	50625	0	2	189	1483	5872	11400	13716	10698	5652	1570	43	0	(13)
(14)	Wind	WSAvg	4.6	2.6	3.4	4.5	5.0	6.3	6.3	6.3	4.6	3.8	3.0	2.5	(14)	
(15)	Precipitation	PrecAvg	4.3	0.9	0.8	1.0	0.6	0.2	0.0	0.0	0.0	0.0	0.2	0.6	(15)	
(16)		PrecMax	9.6	2.1	1.8	3.9	2.4	1.2	0.2	0.0	0.1	0.0	0.7	1.8	(16)	
(17)		PrecMin	2.6	0.3	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
(18)		PrecStd	1.4	0.5	0.5	0.7	0.6	0.2	0.0	0.0	0.0	0.1	0.2	0.5	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.6	78.3	91.6	98.9	106.2	113.8	115.2	113.9	106.2	99.4	85.8	70.4	(19)
(20)		0.4%	MCWB	49.8	52.9	57.6	61.1	62.9	66.5	67.6	67.9	64.0	61.2	57.8	50.2	(20)
(21)		2%	DB	64.7	72.3	84.4	94.7	103.7	111.4	113.1	110.6	103.7	94.9	79.8	66.4	(21)
(22)		2%	MCWB	47.7	51.0	55.8	60.4	63.4	65.5	67.0	66.6	62.9	60.2	55.1	47.9	(22)
(23)		5%	DB	61.5	68.8	80.9	91.4	101.0	109.5	111.3	107.7	101.3	91.7	75.4	63.1	(23)
(24)		5%	MCWB	46.4	49.6	54.2	59.4	62.7	65.1	66.4	65.7	62.1	59.1	53.0	46.9	(24)
(25)		10%	DB	58.6	65.6	77.4	88.0	98.4	107.3	109.2	105.0	98.7	88.5	72.0	60.3	(25)
(26)		10%	MCWB	44.8	48.3	53.4	58.2	62.2	64.3	66.0	64.5	61.1	58.0	51.6	45.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	56.0	61.6	63.8	66.5	70.0	70.9	70.9	67.6	63.2	59.6	52.3	(27)
(28)		0.4%	MCDWB	62.7	67.5	74.1	88.7	99.4	102.7	108.5	107.5	101.0	93.5	79.8	63.1	(28)
(29)		2%	WB	50.4	54.0	59.1	62.3	65.0	67.4	69.0	68.4	64.5	61.2	56.9	50.2	(29)
(30)		2%	MCDWB	60.0	66.0	74.3	88.1	98.0	106.2	108.5	106.3	100.2	91.6	73.4	61.2	(30)
(31)		5%	WB	48.4	52.2	57.1	60.9	63.9	66.2	67.8	66.9	63.1	60.0	55.3	48.6	(31)
(32)		5%	MCDWB	59.0	64.8	75.6	85.6	96.2	105.2	107.5	104.4	98.3	89.3	71.8	59.8	(32)
(33)		10%	WB	46.3	50.2	55.3	59.6	62.9	65.1	66.6	65.5	61.9	58.6	53.4	47.1	(33)
(34)		10%	MCDWB	56.8	62.5	74.8	83.0	94.3	103.8	106.0	102.3	96.5	86.4	69.1	58.0	(34)
(35)	Mean Daily Temperature Range		MDBR	18.3	19.2	21.0	21.1	20.5	21.9	21.0	21.1	23.7	23.5	20.5	18.7	(35)
(36)		5% DB	MCDBR	21.3	22.5	24.4	23.7	22.7	23.9	23.6	22.9	25.7	26.0	23.4	21.5	(36)
(37)		5% DB	MCWBR	11.7	11.1	10.5	9.5	8.6	8.6	8.2	8.3	10.2	11.2	11.8	11.7	(37)
(38)		5% WB	MCDBR	18.0	19.0	21.3	21.2	21.1	22.8	22.6	21.6	24.7	24.1	19.9	18.6	(38)
(39)		5% WB	MCWBR	10.5	10.0	9.9	8.8	8.1	8.5	8.3	8.4	10.2	10.7	10.3	10.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.395	0.473	0.539	0.546	0.524	0.522	0.476	0.423	0.427	0.387	0.342	(40)	
(41)		taud	2.218	2.074	1.857	1.747	1.747	1.798	1.821	1.924	2.039	2.018	2.130	2.269	(41)	
(42)		Ebn at Noon	267	266	253	242	242	247	246	256	265	251	250	263	(42)	
(43)		Edh at Noon	36	46	62	72	73	69	67	60	50	48	39	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1012	1285	1676	2018	2342	2613	2542	2378	2017	1566	1149	946	(44)	
(45)		RadStd	77	91	76	92	93	74	41	66	43	48	63	66	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page