

SAFIABAD, Iran, Islamic Republic of

WMO: 407940

Lat: 32.267N

Lon: 48.417E

Elev: 83

StdP: 100.33

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.5	-3.9	2.7	18.5	-1.1	3.5	16.8	9.8	13.5	7.8	13.5	1.0	20	0.422

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	47.2	22.7	46.0	22.9	45.0	22.9	27.6	38.8	26.4	39.0	25.3	39.0	3.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	19.8	35.2	22.7	17.6	34.7	21.1	15.9	34.1	88.4	38.4	83.0	38.3	78.3	38.9	35.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	6.8	5.6	0.2	49.2	1.4	1.2	-0.8	50.1	-1.5	50.8	-2.3	51.4	-3.3	52.3
			-0.4	30.0	1.5	2.3	-1.5	31.6	-2.4	33.0	-3.3	34.3	-4.4	35.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	12.0	14.1	18.3	23.2	30.1	34.6	36.7	35.9	31.9	26.5	18.9	13.8	(6)
	DBStd	9.16	2.72	2.81	3.04	3.22	2.98	2.13	1.80	1.72	2.42	2.84	3.25	2.71	(7)
	HDD10.0	20	13	4	0	0	0	0	0	0	0	0	0	3	(8)
	HDD18.3	531	197	119	38	3	0	0	0	0	0	0	32	141	(9)
	CDD10.0	5394	74	119	257	397	622	737	827	804	658	510	268	122	(10)
	CDD18.3	2863	0	1	37	150	364	487	568	546	408	252	49	1	(11)
	CDH23.3	43888	1	12	381	1657	5313	8200	9924	9243	5963	2801	374	18	(12)
	CDH26.7	30287	0	0	99	758	3486	5986	7484	6823	4012	1540	97	1	(13)
(14) Wind	WSAvg	2.2	2.0	2.1	2.3	2.4	2.8	2.8	2.6	2.5	1.9	2.0	1.7	1.7	(14)
(15) Precipitation	PrecAvg	376	83	47	61	32	7	0	0	0	1	13	49	76	(15)
	PrecMax	596	194	164	207	111	45	2	1	2	13	68	239	224	(16)
	PrecMin	155	17	2	8	0	0	0	0	0	0	0	0	1	(17)
	PrecStd	115	44	39	51	26	11	0	0	0	3	17	52	61	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.9	25.1	32.0	38.0	44.0	47.7	49.2	47.8	44.8	39.4	31.1	25.5	(19)
		MCWB	13.9	15.1	18.7	21.2	21.3	22.8	22.8	22.9	22.7	21.3	18.3	15.2	(20)
	2%	DB	20.1	23.1	29.3	35.1	42.1	46.0	47.8	46.5	42.9	37.3	29.4	22.6	(21)
		MCWB	13.2	14.9	18.4	20.2	21.1	22.2	22.7	23.2	23.3	21.5	18.0	14.7	(22)
	5%	DB	18.6	21.7	27.1	32.9	40.4	45.0	46.6	45.3	41.4	35.7	27.4	20.5	(23)
		MCWB	13.0	14.5	17.3	19.7	20.6	22.0	22.8	23.6	23.4	21.3	17.8	14.2	(24)
	10%	DB	17.2	20.2	25.3	31.0	38.9	43.8	45.4	44.1	40.0	34.1	25.3	18.9	(25)
		MCWB	12.7	13.8	16.3	19.3	20.4	21.8	22.9	23.8	23.1	20.8	17.0	14.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.2	17.9	20.9	23.8	24.7	28.3	27.6	28.6	30.2	26.1	21.5	17.6	(27)
		MCDB	18.7	22.1	28.8	34.1	38.1	42.3	40.9	39.3	39.0	34.3	26.7	20.7	(28)
	2%	WB	15.3	16.7	19.4	22.0	23.2	24.9	25.9	27.2	27.9	24.0	20.1	16.5	(29)
		MCDB	18.0	20.4	26.9	32.0	37.5	40.8	41.7	39.9	37.0	32.7	25.9	19.9	(30)
	5%	WB	14.2	15.6	18.4	20.9	22.2	23.6	24.7	26.3	26.2	22.8	19.1	15.7	(31)
		MCDB	16.9	19.6	25.3	30.1	36.7	41.1	41.8	39.9	36.3	32.4	24.7	18.8	(32)
	10%	WB	13.4	14.6	17.4	20.1	21.4	22.6	23.8	25.4	24.8	21.8	18.0	14.8	(33)
		MCDB	16.2	18.8	23.7	28.8	35.6	41.0	42.0	39.7	36.3	31.7	23.8	17.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	11.3	13.1	14.1	16.2	18.6	18.3	17.7	17.5	15.3	12.2	10.6	(35)
		MCDBR	12.3	13.2	15.5	16.6	18.4	19.5	19.2	18.4	17.9	17.0	14.7	13.3	(36)
		MCWBR	6.7	6.6	7.5	6.9	5.6	5.7	5.2	6.0	6.8	6.9	6.0	6.7	(37)
	5% WB	MCDBR	9.3	10.5	13.6	14.5	16.5	18.7	18.0	16.8	16.4	15.7	11.6	9.7	(38)
		MCWBR	5.9	6.2	7.4	7.0	6.3	7.2	6.4	7.3	8.8	7.8	6.0	5.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.442	0.482	0.540	0.636	0.604	0.553	0.628	0.570	0.498	0.529	0.473	0.442	(40)
	taud		1.979	1.885	1.752	1.607	1.672	1.747	1.623	1.733	1.863	1.814	1.933	1.992	(41)
	Ebn at Noon		741	754	743	693	722	757	699	734	769	698	701	713	(42)
	Edh at Noon		147	177	218	262	248	229	258	228	192	188	152	138	(43)
(44) All-Sky Solar Radiation	RadAvg		3.02	3.97	5.17	5.91	7.01	8.20	7.74	7.28	6.35	4.74	3.44	2.83	(44)
	RadStd		0.23	0.28	0.35	0.42	0.40	0.25	0.20	0.19	0.19	0.29	0.28	0.28	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page