

SHAHID ASIYAE, Iran, Islamic Republic of

WMO: 408120

Lat: 32.002N

Lon: 49.271E

Elev: 1187

StdP: 14.08

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.6	42.5	12.5	10.9	89.1	18.0	14.2	90.2	16.6	57.9	13.9	58.4	1.0	330	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.7	116.6	69.3	114.8	68.8	113.1	68.5	75.1	104.9	72.9	106.3	71.3	106.9	8.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	97.6	86.6	62.7	89.1	79.8	60.6	82.7	75.3	39.4	105.7	37.4	106.0	35.9	107.0	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.2	13.8	12.0	35.2	120.4	2.8	1.7	33.2	121.6	31.5	122.6	30.0	123.6	27.9	124.9		
			33.2	78.6	3.2	2.1	30.9	80.1	29.1	81.3	27.3	82.5	25.0	84.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.7	53.8	57.8	66.1	76.1	88.7	97.7	101.5	100.9	93.2	82.1	66.9	57.6
	DBStd	17.81	5.12	5.47	6.07	6.13	5.42	3.57	3.36	2.98	4.04	5.44	6.35	4.92
	HDD50	34	23	7	0	0	0	0	0	0	0	0	0	4
	HDD65	898	347	206	56	3	0	0	0	0	0	0	52	234
	CDD50	10498	141	227	501	784	1200	1431	1598	1579	1295	996	507	239
	CDD65	5887	0	5	91	338	735	981	1133	1114	845	531	110	4
	CDH74	97561	2	41	868	3822	11678	17931	21156	20507	14036	6663	819	38
	CDH80	69827	0	2	276	1776	7659	13623	16692	16043	9836	3689	229	2
Wind	WSAvg	4.1	2.7	3.3	3.8	4.7	5.1	5.4	5.3	5.0	4.2	3.7	2.9	2.5
Precipitation	PrecAvg	19.8	5.0	2.8	3.5	1.9	0.3	0.0	0.0	0.0	0.0	0.5	2.2	4.4
	PrecMax	26.7	11.3	7.2	11.1	7.1	2.4	0.1	0.0	0.0	0.4	2.1	12.2	9.8
	PrecMin	12.3	1.6	0.2	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.6	0.6
	PrecStd	3.4	2.6	1.7	2.4	1.6	0.5	0.0	0.0	0.0	0.1	0.7	2.6	2.7
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	78.7	93.2	101.2	110.8	116.6	119.8	118.5	113.2	104.0	88.8
MCWB			54.8	57.7	59.6	63.4	66.7	67.0	70.4	69.3	67.6	64.9	60.8	57.0
2%		DB	68.4	74.8	86.9	96.2	107.8	114.6	117.0	116.2	110.4	100.6	85.8	73.3
		MCWB	55.3	56.5	59.1	62.6	65.7	67.1	69.6	69.6	67.8	64.9	59.8	57.3
5%		DB	65.6	71.5	82.2	92.8	104.6	112.8	115.2	114.5	107.8	98.2	82.3	69.4
		MCWB	54.1	55.6	58.0	61.9	64.6	66.6	69.0	69.6	67.5	64.1	59.8	56.1
10%		DB	62.7	68.2	78.5	89.4	102.2	111.0	113.3	112.8	105.8	95.1	78.7	66.2
		MCWB	53.8	54.7	56.8	61.1	64.3	66.4	68.5	69.6	66.7	63.4	58.7	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	62.7	65.5	67.7	70.7	71.2	76.6	78.6	77.3	71.1	67.5	63.8
		MCDB	65.7	69.9	74.2	81.6	100.0	109.6	104.2	102.4	98.5	94.6	75.3	67.5
	2%	WB	59.0	60.3	63.2	66.2	68.6	69.4	73.7	75.6	73.5	68.0	65.1	61.2
		MCDB	64.1	67.8	73.5	83.4	98.9	109.4	109.3	105.8	101.1	90.1	74.7	65.2
	5%	WB	57.2	58.3	61.5	65.0	67.1	68.4	72.0	73.4	70.6	66.3	63.4	59.3
		MCDB	62.0	66.7	73.8	83.5	96.8	108.6	110.3	106.2	102.3	89.4	73.8	64.9
	10%	WB	55.3	56.4	59.9	63.7	65.9	67.4	70.7	71.7	68.4	65.0	61.8	57.8
		MCDB	60.2	65.5	73.4	82.8	95.3	107.4	109.1	106.4	101.5	88.8	72.7	63.8
Mean Daily Temperature Range	5% DB	MDBR	15.9	17.8	20.4	21.6	22.5	24.5	22.7	23.3	24.6	23.0	18.9	17.0
		MCDBR	20.0	21.7	25.7	24.8	26.0	26.7	24.6	24.4	25.6	25.7	22.9	22.1
		MCWBR	10.0	9.3	8.9	7.8	8.3	8.4	7.7	8.0	9.0	9.4	8.4	10.0
	5% WB	MCDBR	15.4	16.9	19.7	21.0	22.3	24.8	23.0	22.4	22.5	21.0	16.1	15.8
		MCWBR	9.8	9.3	9.1	7.9	7.9	8.7	8.6	9.4	10.0	9.4	7.6	9.1
Clear-Sky Solar Irradiance	taub	0.406	0.449	0.506	0.599	0.571	0.530	0.599	0.548	0.474	0.489	0.437	0.401	
	taud	2.075	1.960	1.815	1.663	1.722	1.789	1.671	1.772	1.913	1.886	2.014	2.101	
	Ebn at Noon	249	250	245	229	237	246	228	239	251	234	236	243	
	Edh at Noon	42	52	65	79	75	70	78	70	58	56	45	39	
All-Sky Solar Radiation	RadAvg	942	1226	1613	1856	2247	2622	2459	2316	2044	1536	1094	891	
	RadStd	74	107	113	143	121	73	66	72	62	87	94	98	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page